

# RBC-SMCN61L Remote Controller ON/OFF Lock Lead

## Description and Contents

The lead will allow the on off function of the remote to be locked in the on or off position.


Contents: Lead with Connector

## Installation and Operating Instructions

### Installation

The interface lead must be plugged into the CN61 connector on the indoor unit PCB.

When the Green and White leads are linked out the on/off button is locked in the on or off status. The operation of the on / off function will not be permitted by the button on the remote controller, whilst the leads are connected together.



**For Technical Information Contact**  
TOSHIBA Air Conditioning

**Tel: 0870 8430333**