

NA 09.13 H

09 - 2011

connect 2

*Microchip and LCD display
electronic regulation and
signaling electronic module
for liquid coolers
and heat pumps*

*Installation
Operation
Commissioning
Maintenance*



CONTENTS

PAGE

1 IMPORTANT RECOMMENDATIONS	3
2 GENERAL	3
3 Composition	4
3.1 Main control board for machines with one refrigerating circuit	4
3.2 Additional board 1	5
3.3 Additional board 2	6
3.4 Control and display console	7
3.5 Connection via RS485 serial port for BMS or control console and Multiconnect with 500 kW module	8
3.6 Relay boards	9
4 DESCRIPTION	9
4.1 Main board	9
4.2 Expansion (additional) boards 1 and 2	9
4.3 Man-Machine Communication	10
5 ACCESS LEVELS	10
5.1 Selecting an authorised access level	10
5.2 Accessing the various access levels	10
5.3 Configuring access levels on the controller	12
5.4 Management of the numeric codes for accessing levels 2 and 3	12
5.5 Classification of the menus and their functions	12
6 LIST OF PARAMETERS PER ACCESS LEVEL	12
7 MANAGEMENT OF AERO-CONNECT PARAMETERS	20
8 CONTENTS OF THE MENU	21
8.1 MAIN menu	21
8.2 SETPOINTS menu	21
8.3 MACHINE STATUS menu	22
8.4 MEASURED VALUES menu	26
8.5 MACHINE PARAMETERS menu	26
8.6 ADJUSTMENT PARAMETERS menu	31
8.7 OPERATION PARAMETERS menu	39
8.8 FAULT MEMORY menu	50
8.9 TEST MODE menu	51
9 MANAGEMENT OF THE ON/OFF INPUTS	52
9.1 Automatic machine operation control	52
9.2 Load shedding control	52
9.3 Water flow switch	52
9.4 Fan fault (circuits 1 and 2)	53
9.5 Expansion valve fault	53
9.6 Phase controller fault	54
9.7 Pump fault	54
9.8 Compressor protection	55
9.9 Manual HP pressure switch fault on circuit 1 or 2	55
9.10 Setpoint selection via on/off input	56
9.11 Variable setpoint via 4-20 mA input	56
9.12 Operating mode selection	57
10 MANAGEMENT OF THE ANALOGUE INPUTS	57
10.1 Temperature sensor	57
10.2 Pressure sensor	60
11 MANAGEMENT OF THE WATER PUMPS	61
11.1 Pump 1	61
11.2 Pump 2	61
11.3 Pump management if P2 = 3 (reversible air-to-water) + heating mode + P111 = boiler	61
11.4 Unseizing and switching the pumps	61
12 WINTER PROTECTION	61
12.1 Frost protection of pumps and heat exchangers while unit is off:	61
12.2 Water loop winter protection	62

CONTENTS	PAGE
13 MANAGEMENT OF THE FUNCTIONS	62
13.1 Management of the compressor protections	62
13.2 Management of the time counters	63
13.3 Management of compressor start-up	63
13.4 Management of the reversing valves	64
13.5 Management of configurable output P111:	64
14 SELF-ADJUSTING FUNCTIONS	64
14.1 Self-adjusting function: water frost limit	64
14.2 Self-adjusting function: refrigerant frost limit	64
14.3 Self-adjusting function: HP pressure limit	65
14.4 Self-adjusting function: discharge protection, circuit 1 or 2	65
14.5 Self-adjusting function: minimum HP, circuit 1 or 2	65
14.6 Self-adjusting function for high water return temperatures	65
15 FAULT FUNCTIONS	65
15.1 Water frost limit fault on circuits 1 and 2	65
15.2 Refrigerant frost limit fault on circuits 1 and 2	66
15.3 HP pressure fault, circuits 1 and 2	66
15.4 Discharge temperature fault, circuit 1 or 2	67
15.5 LP fault on circuit 1 or 2	67
15.6 Management of superheat faults	68
16 CONTROLS	69
16.1 Main control in cooling and heating modes (Operating mode based on P119)	69
16.2 Water temperature setpoint adjustment	70
16.3 Adjustment of water temperature setpoint if P7 ≠ INVERTER	70
16.4 Adjustment of setpoint for the water supply and return temperatures (P141 = 1 or 2) if P7 =	73
16.5 Storage control	74
16.6 Control setpoint (P251) management	74
16.7 Automated self-regulating control	75
16.8 Control with AÉROCONNECT link in FREE COOLING mode	75
17 CONTROL OF CONDENSING PRESSURE FOR AIR-COOLED UNITS	75
17.1 Control during normal operation or on/off control	75
17.2 Forced and self-adjusting control for A, B and C	76
17.3 Fan speed control	77
17.4 Low Noise control (single-fan units only – Aquaciat2)	80
17.5 Total recovery control	80
17.6 Management of the air blades if P10 = Centrifugal	81
18 CONTROL OF CONDENSING PRESSURE FOR WATER-TO-WATER UNITS	82
19 RESTRICTION OF OPERATION OF THE MACHINES BASED ON THE OUTDOOR TEMPERATURE	82
19.1 Restriction to the minimum air temperature in heating mode	82
19.2 Restriction to the maximum air temperature in cooling mode	82
19.3 Restriction to the maximum air temperature in heating mode	83
19.4 Restriction to the minimum air temperature in cooling mode	83
20 MANAGEMENT OF THE AUXILIARY HEATER BOARD AND THE ELECTRIC AUXILIARY	84
21 MANAGEMENT OF THE BACK-UP BOILER	85
22 MASTER/SLAVE CONTROL	85
22.1 Case of two parallel-connected machines	85
23 ACTUATION OF THE ELECTRONIC EXPANSION VALVE	89
23.1 With Alco driver and display	89
23.2 With CIAT driver	89
24 IMPORTANT INFORMATION REGARDING THE CONTROL OF AN INVERTER COMPRESSOR	91
25 DEFROSTING OF THE EVAPORATOR COILS	92
26 HOURLY PROGRAMMING	92
26.1 Presentation	92
26.2 Definition of the programming stages	93
26.3 Definition of holiday zones	93
26.4 Operation	93
27 COMMUNICATION PROTOCOL	95
27.1 Registers accessible by customer	95
27.2 Customer access bit	96

1 IMPORTANT RECOMMENDATIONS

Your unit is equipped with a microprocessor-controlled electronic circuit board. To ensure the correct operation of your machine, you must follow the rules listed below.

① Electrical power supply

Remote control: 230 V AC/50 Hz.

If the machine's remote control is powered separately (transformer not supplied), provide the following:

- 1 - A power supply line running **directly** from a distribution point (this line must be used **only** to supply power to the machine's remote control).
- 2 - This power supply line must be at least 1 metre away from all power lines (400 V).

② Specifications of the CONNECT 2 board

Board power input: 35 Watts.

Maximum allowable voltage and current per input/output: 253 V AC -3.15 A.

The board is powered by an onboard screw-on three-pin connector. The terminals are identified as follows:

- 1 - Live,
- 2 - Neutral,
- 3 - Earth.

Board fuse specifications:

Schurter UMT 250 V AC/3.15 A. Time lag: 10 x 3.

Product code: 34031 0171.

Environmental conditions:

- In storage → -40/+80°C, 5/85% humidity without condensation.
- In use → -20/+70°C, 5/85% humidity without condensation.

Degree of pollution: 3.

③ Warning

Read the instructions in the manual before attempting to service the product.

Before attempting to service the board, disconnect its power source and make sure that no voltage is present.

To prevent the risk of electric shock, access to the board should be impossible while it is energised.

Certain parts of the board (USB and Ethernet connectors) may be hot. Based on the ambient temperature, they could cause burns. As a result, avoid touching these connectors while they are connected.

Warning:

There is a risk of explosion if the battery is replaced by an incorrect type.

Dispose of used batteries in accordance with local regulations.

④ Earthing

Compulsory (good earth quality in compliance with French standard NF C 15-100).

⑤ Connection of sensors

Keep connection cables away from power lines (400 V) or a remote control line (230 V). In the case of distances of over 6 m, use a shielded cable connected to the earth on the unit.

Maximum distance: 25 m.

⑥ Connection of communication buses and of the remote console

4-1 Connection cable specifications

- Flexible cable – RS 485 connection
- Two shielded wires
- Capacitance between cables and shield: 120 pF/m
- Resistance: 56 Ω/km

4-2 Connection of the shield

- Connect the shield on the BMS or micro-computer end to earth.
- Ensure bonding all the way to the last unit (the shield on the communication cable must be connected between each unit).
- Do not connect the shield to the earth connection on the units.
- The wires exiting the shield must be as short as possible (2 cm) on each unit.

4-3 Cable routing

- The cable must be at least 30 cm away from all 230 V or 400 V cables along its entire length.
- If a 230 V or 400 V cable must be crossed with a computer cable, they must cross each other at a right angle.

⑦ Connection of on/off inputs


•Distances of less than 30 metres:

- Use a shielded cable. Keep the cable at least 30 cm away from all lines that could generate interference. Connect the shield to the earth on the unit. If several shielded cables are used, connect each shield separately (if the risk of interference persists, install a relay for each input).

•Distances of greater than 30 metres:

- Install a relay for each input near the electronic circuit board (cable cross-section: 0.5 mm²)

•Example connection diagram:



K: Auxiliary relay (fit near the electronic circuit board)

CA: Automatic operation control (on each machine)

2 GENERAL

The CONNECT 2 control module is fitted as standard on water chillers (or water heaters) equipped one or two refrigerating circuits and scroll compressors. It is fitted on water-to-water, air-to-water and reversible air-to-water units.

Depending on the configuration, the board provides the following functions:


- ▶ Control of chilled water or hot water temperatures.
- ▶ Continuous monitoring of operating parameters.
- ▶ Diagnostics and fault storage.
- ▶ Setpoint drift based on the outdoor temperature (in heating and cooling modes).
- ▶ Communication with the console (remote or local) and the additional boards (fault reporting, BMS communication, Ethernet link for PC).

3 COMPOSITION

The CONNECT 2 control module consists of:

- ▶ One control and display panel fitted on the unit.
- ▶ One non-reversible circuit = one main board.
- ▶ One reversible circuit = one main board + one additional board (No. 1) → rotary switch in position 1.
- ▶ Two non-reversible circuits = one main board + one additional board (No. 2) two circuits → Rotary switch in position 1.
- ▶ Two reversible circuits = one main board + one additional board (No. 2) two circuits → Rotary switch in position 1. + one additional board (No. 2), two circuit changeover → Rotary switch in position 2.
- ▶ One auxiliary electric heater control board = additional board 1 → Rotary switch in position 2 (optional, ILD range).
- ▶ One remote console (optional).
- ▶ One relay board for operating states and faults (optional).

3.1 Main control board for machines with one non-reversible refrigerating circuit



SWITCH W3

End-of-line resistance for two-wire RS-485 link. The switch must be turned to the left for the last unit on the loop and to the right for the others.

TERMINAL BLOCK J2 (analogue outputs)

1-2 0-10 V output 1 two-way valve or three-way valve if unit type (P2) = water-to-water.

or circuit 1 fan speed if unit type (P2) = air-to-water or reversible air-to-water when P10 = centrifugal.

or air damper control if unit type (P2) = air-to-water or reversible air-to-water when P10 = centrifugal and P20 = yes.

3-4 0-10 V output 2 (Compressor INVERTER if P7 = INVERTER)

4-5 0-10 V output 3 (variable speed pumps).

TERMINAL BLOCK J3 (on/off inputs)

- 1 Stage control common
- 2 Stage 1, circuit 1 control
- 3 Stage 2, circuit 1 control
- or if P7 = INVERTER (compressor shut off order to driver)
- 4 Common for fans, heater and heat trace cable
- 5 Circuit 1, fan 1 control (and circuit 2 if intertwined coil)
- 6 Circuit 1, fan 2 control (and circuit 2 if intertwined coil)
- 7 Heater control
- 8 Heat trace cable control
- 9-10 Configurable control based on P111:
 - Max. power
 - Boiler
 - Cooling/Heating
- 11 Fault output common
- 12 NC contact for fault output
- 13 NO contact for fault output
- 14 Common for pumps
- 15 Pump 1 control
- 16 Pump 2 or reversing valve control, circuit 1

TERMINAL BLOCK J4 (power supply)

- 1 230 V board power supply - Line
- 2 230 V board power supply - Neutral
- 3 Earth

TERMINAL BLOCK J5 (on/off inputs)

- 1-2 Motor fault, stage 1, circuit 1
- 2-3 Motor fault, stage 2, circuit 1
- 4-5 Manual reset fault, HP, circuit 1
- 5-6 Expansion valve fault, circuit 1
- 7-8 Phase controller fault
- 8-9 Water flow fault
- 10-11 Pump 1 fault

TERMINAL BLOCK J6 (on/off inputs)

- 1-3 Pump 2 fault
- 2-3 Automatic operation control
- 4-6 Setpoint 1/setpoint 2 selection
- 5-6 Heating/cooling selection if unit type (P2) = water-to-water or fan fault if unit type (P2) = air-to-water or reversible air-to-water
- 7-9 Stage 1, circuit 1 load shedding control
- 8-9 Stage 2, circuit 1 load shedding control
- 10-11 Recovery control

TERMINAL BLOCK J7 (analogue inputs)

- 1-2 10 K outdoor temperature sensor
- 2-3 10 K water inlet temperature sensor, heat exchanger 1
- 4-5 10 K water outlet temperature sensor, heat exchanger 1
- 5-6 10 K hot water temperature sensor if unit type (P2) = water-to-water or exchanger amb. temp. if unit type (P2) = air-to-water or reversible air-to-water
- 7 +24 V power supply for pressure sensors
- 8 0-10 V input for water inlet sensor on circuit 1
- 9 0-10 V input for water outlet sensor on circuit 1
- 10 Common for pressure sensors
- 11 4-20 mA remote setpoint
- 12 Setpoint common

TERMINAL BLOCK J8 (analogue inputs)
 1-2 Refrigerant temperature sensor, circuit 1
 2-3 10 K suction temperature sensor, circuit 1
 4-5 10 K liquid temperature sensor, circuit 1
 6-7 50 K discharge temperature sensor, stage 1, circuit 1
 7-8 50 K discharge temperature sensor, stage 2, circuit 1
 9 +5 V power supply for pressure sensor
 10 0-5 V input - HP sensor
 11 0-5 V input - LP sensor
 12 Common for pressure sensors

TERMINAL BLOCK J9
 Link for chiller or MULTICONNECT

TERMINAL BLOCK J10
 Remote control console, relay board link - AEROCONNECT

TERMINAL BLOCK J11
 BMS link

TERMINAL BLOCK J12
 Local console link

TERMINAL BLOCK J13
 Link for additional boards

TERMINAL BLOCK J14
 Ethernet link for PC

On/off input specifications: 24 V - 15 mA

On/off output specifications: 250 V - 2 mA

3.2 Additional board 1

3.2.1 Rotary switch set to position 1 - One circuit reversal use or recovery frost protection

TERMINAL BLOCK J1
 Flash Memory connector

TERMINAL BLOCK J2
 Link with motherboard or another additional board

TERMINAL BLOCK J3
 Link with another additional board

TERMINAL BLOCK J4 (on/off inputs)
 1-2 Heating/cooling selection input if unit type (P2) = reversible air-to-water and number of circuits (P3) = 1
 2-3 Available
 4-5 Available

TERMINAL BLOCK J5 (on/off inputs)
 1 Common to all outputs
 2 Circuit 1 reversing valve control
 3 Circuit 1 pressure balance valve control
 4 Recovery frost protection heat trace cable
 5 Reverse rotation control for fans

TERMINAL BLOCK J6 (analogue inputs)
 1-2 Temperature sensor, coil A, circuit 1
 2-3 Temperature sensor, coil B, circuit 1

3.2.2 Rotary switch set to position 2 - Use of electric auxiliary heaters

TERMINAL BLOCK J1
 Flash Memory connector


TERMINAL BLOCK J2
 Link with motherboard or another additional board

TERMINAL BLOCK J3
 Link with another additional board

TERMINAL BLOCK J4 (on/off inputs)
 1-2 Programmable input (P113)
 2-3 Fault 1, electric stages
 4-5 Fault 2, electric stages

TERMINAL BLOCK J5 (on/off inputs)
 1 Common to all outputs
 2 Electric stage 1 output
 3 Electric stage 2 output
 4 Electric stage 3 output
 5 Electric stage 4 output

TERMINAL BLOCK J6 (analogue inputs)
 1-2 Available
 2-3 Available



3.3 Additional board 2

3.3.1 Rotary switch set to position 1 - Two circuit use

TERMINAL BLOCK J1

Flash Memory connector

TERMINAL BLOCK J2 (on/off inputs)

- 1-2 Motor fault, stage 1, circuit 2
- 2-3 Motor fault, stage 2, circuit 2
- 4-5 Manual reset fault, HP, circuit 2
- 5-6 Expansion valve fault, circuit 2
- 7-8 Load shedding input, stage 1, circuit 2
- 8-9 Load shedding input, stage 2, circuit 2

TERMINAL BLOCK J3 (on/off inputs)

- 1 Common for stages 1 and 2, circuit 2
- 2 Stage 1, circuit 2 control
- 3 Stage 2, circuit 2 control
- 4 Common for fan stages
- 5 Stage 1, circuit 2 fan control
- 6 Stage 2, circuit 2 fan control
- 7 Stage 3, circuit 1 fan control if coil type (P11) = split or stage 1, common fan if coil type (P11) = mixed
- 8 Stage 3, circuit 2 fan control if coil type (P11) = split or stage 3, common fan if coil type (P11) = mixed

TERMINAL BLOCK J4 (analogue inputs)

- 1-2 10 K water outlet temperature sensor, heat exchanger 2
- 2-3 10 K manifold water outlet temperature sensor
- 4-5 10 k refrigerant temperature sensor, circuit 2
- 5-6 50 K Discharge temperature 3 or 2 if 2 circuits and 1 stage per circuit (P3 =1) (stage 1, circuit 2)
- 7-8 50 K sensor, discharge temperature 4 (stage 2, circuit 2)
- 8-9 Circuit 2 suction temperature
- J4-10, J5-1 Circuit 2 liquid temperature

TERMINAL BLOCK J5 (analogue inputs)

- 1 Common
- 2 Available
- 3 +5 V power supply for pressure sensors
- 4 0-5 V input for HP sensor on circuit 2
- 5 0-5 V input for LP sensor on circuit 2
- 6 0 V power supply, HP-LP pressure sensors
- 7 +24 V power supply for water pressure sensors
- 8 0-10 V input for water inlet circuit on exchanger 2
- 9 0-10 V input for water outlet circuit on exchanger 2
- 10 0 V power supply for water pressure sensors

3.3.2 Rotary switch set to position 2 - Two circuit reversal use

TERMINAL BLOCK J1

Flash Memory connector

TERMINAL BLOCK J2 (on/off inputs)


- 1-2 Heating/cooling selection input if unit type (P2) = reversible air-to-water and number of circuits (P3) = 2
- 2-3 Available
- 4-5 Available
- 5-6 Available
- 7-8 Available
- 8-9 Available

TERMINAL BLOCK J3 (on/off inputs)

- 1 Common for reversing valves
- 2 Circuit 1 reversing valve control
- 3 Circuit 2 reversing valve control
- 4 Common for balance valves
- 5 Circuit 1 balance valve control
- 6 Circuit 2 balance valve control
- 7 Reverse rotation control for circuit 1 fans
- 8 Reverse rotation control for circuit 2 fans

TERMINAL BLOCK J4 (analogue inputs)

- 1-2 Temperature sensor, coil A, circuit 1
- 2-3 Temperature sensor, coil B, circuit 1
- 4-5 Temperature sensor, coil C, circuit 1
- 5-6 Temperature sensor, coil D, circuit 1
- 7-8 Temperature sensor, coil A, circuit 2
- 8-9 Temperature sensor, coil B, circuit 2
- 8-10 Temperature sensor, coil C, circuit 2



TERMINAL BLOCK J6 (analogue outputs)

- 1 0-10 V output for circuit 2 fan
- 2 Common for outputs
- 3 0-10 V output for common fan, circuits 1 and 2

TERMINAL BLOCK J7

Link with motherboard or another additional board

TERMINAL BLOCK J8

Link with another additional board

TERMINAL BLOCK J5 (analogue inputs)

- 1-2 Temperature sensor, coil D, circuit 2
- 3 +5 V power supply - Available
- 4 0-5 V input - Available
- 5 0-5 V input - Available
- 6 0 V power supply - Available
- 7 +24 V power supply - Available
- 8 0-10 V input - Available
- 9 0-10 V input - Available
- 10 0 V power supply - Available

TERMINAL BLOCK J6 (analogue outputs)

- 1 0-10 V output - Available
- 2 Common for 0-10 V output - Available
- 3 0-10 V output - Available


TERMINAL BLOCK J7

Link with motherboard or another additional board

TERMINAL BLOCK J8


Link with another additional board

3.4 Control and display console




The local console and the remote control console have the same front.

Mounting dimensions (in mm) of remote control console



3.5 Connection via RS485 serial port for BMS or control console and Multiconnect with 500 kW module



For connection to a CMS, refer to document 3991049.

Identification of Modbus connection terminals

- 1 → A or +
- 2 → B or -
- 3 → Earth (shield)



3.6 Relay boards

The dry contacts on the relay boards make it possible to remotely view the states of the stages that are on and all the fault states on the unit.

- A 230 V +6% -10% power supply must be provided for each relay board.
- Connect terminal block J1 (1-2) on each relay board to terminal block J10 on the main board.
- If the link between the motherboard and the relay board is defective, contact 1-2 on the relay board will chatter at a rate of one change in state per second.

These are NO dry contacts.

Terminal block layout:



Dimensions of boards

Main board	Additional board
Width: 105 mm	Width: 60 mm
Length: 208 mm	Length: 157 mm
Thickness: 65 mm	Thickness: 40 mm
Mounting centre distance:	Mounting centre distance: 50 x 147 mm

4 DESCRIPTION

4.1 Main board

Main board for units with one non-reversible refrigerating circuit:

• Analogue inputs:

Acquire signals measured by temperature sensors.
Acquire signals measured by pressure by sensors.

• On/Off inputs:

Acquire operating state signals from surrounding electromechanical components.

• Actions:

Comparison of setpoint and water temperature to calculate which stages are to be turned on or off.
Management of the protections for the machine's self-adjusting operation.

• Outputs:

Control stage control.
Pump control.
General fault.

• The board also features:

- An "end-of-line resistance" switch.

4.2 Expansion (additional) boards 1 and 2

These boards are used for units with two reversible refrigerating circuits.

They manage the inputs/outputs on the second circuit or required for reversing the circuits.

• Analogue inputs:

Acquire signals measured by temperature sensors.
Acquire signals measured by pressure by sensors.

• On/Off inputs:

Acquire operating state signals from surrounding electromechanical components.

• Outputs:

Control stage control.

4.3 Man-Machine Communication

●**Local console:**

- The controls on the local console are enabled regardless of the value of P103.
- Acknowledgment of faults is possible.

●**Remote control console:**

- All parameters may be read depending on the authorised access level.
- All unit controls are enabled if P103 = remote or BMS.
- In this case, the following parameters may be accessed for modification:
 - On/Off.
 - Cooling/Heating.
- All adjustment parameters are locked, depending on the authorised access level, except for the first 11 if P103 = local.
- Acknowledgment of faults is not possible.
- Test mode is possible.

●**BMS:**

- All parameters (except P100, P103, P104 and P105) are accessible in read mode..
- All parameters (except P1 to P99, P100, P103, P104 and P105) are accessible in write mode. However, access to parameters P1 to P99 is possible when P99 is unlocked on the machine's local console.
- Acknowledgment of faults is not possible.

NOTE: All the registers (see communication protocol) appear regardless of the value of P103.

To enable write mode, P103 must be set to 'remote or BMS'.

To be able to switch between heating and cooling, P199 must be set to 'cooling/heating' via the console.

To be able to switch between setpoints 1 and 2, P120 must be set to '2' via the console.

Locking the console:

⚠ Available only on the local console on the unit.

The factory setting for the console is 'unlocked'.
 The lock status is saved in the event of a mains power failure.
 If lock mode is enabled while modifying a parameter, any modifications made are aborted and the controller is reset to its

initial value.
 To lock the console, simultaneously hold down the + and - buttons for 5 seconds (possible in any menu on the console).
 The following message appears on the screen for 5 seconds then machine state reappears.

```

    C O N S O L E
    L O C K E D
    
```

All modifications from the local console are then inhibited.
 Any attempts to make modifications will cause the above message to appear for 3 seconds.

To unlock the console, simultaneously hold down the + and - buttons for 5 seconds. The following message appears on the screen for 3 seconds:

```

    C O N S O L E
    U N L O C K E D
    
```

5 ACCESS LEVELS

CONNECT 2 features three parameter access levels:

- Level 1: Users
- Level 2: Technicians/Maintenance
- Level 3: CIAT Technicians (full access)

5.1 Selecting an authorised access level

Authorised access levels are selected in menu 14 (ACC. LEVEL SELECT.). The following screen appears:

```

    C O N T R O L L E R   I N   L E V E L   x
    1 4 - 1   A C C E S S   T O   L E V E L   2
    1 4 - 2   A C C E S S   T O   L E V E L   3
    
```

- Level 3 provides automatic access to all levels (CIAT technicians).
- Level 2 provides access to levels 1 and 2 only (Technicians/Maintenance and CIAT technicians).
- Level 1 provides access to level 1 only (all users).

5.2 Accessing the various access levels

5.2.1 Restricting access to level 1 only

- Access level 2 is the default access level.
- If you are in a higher level and you want to restrict access to level 1 only, simultaneously hold down the **ESC** and **OK** buttons for 10 seconds.

- No password is needed to access level 1. The setpoint adjustment range is + or – 5 K lower than in the higher access levels.
- The restriction messages remain displayed in access level 1. Operating messages in optimised mode are visible only in access levels 2 and 3.
- Restriction of access to level 1 only is stored in memory in the event of a mains power failure.

5.2.2 Access to level 2:

- A numeric code must be entered to access level 2:
- The following menu for entering this code appears when LEVEL 2 is selected:

```

L E V E L   2
A C C E S S   C O D E
* * * *

```

- Using the + and – buttons, replace this first symbol (*) by the first character in the code and press **Enter**. Do the same for the second, third and fourth symbols. When the last character is entered and **Enter** is pressed, the following menu appears:

```

L E V E L   2
N E W   A C C E S S   C O D E
* * * *

```

- To select a new access code, proceed as described above. When the last character is entered and **Enter** is pressed, the screen displays the menu below followed by the main menu.

```

L E V E L   2
N E W   C O D E   S A V E D

```

- If you do not want to change the level 2 access code, press **ESC** to exit the new access code menu and go back to the main menu.
- If you have changed your access code but have forgotten it, you can reset it to the original code by entering the LEVEL 2 ACCESS CODE menu and simultaneously holding down the + and **Reset** buttons for 10 seconds.

5.2.3 Access to level 3

- A non-modifiable numeric code must be entered to access level 3:
- The following menu for entering this code appears when LEVEL 3 is selected:

```

L E V E L   3
A C C E S S   C O D E
* * * *

```

- Using the + and – buttons, replace this first symbol (*) by the first character in the code and press **Enter**. Do the same for the second, third and fourth symbols. When the last character is entered and **Enter** is pressed, the main menu appears.

5.2.4 Restricting access from level 3 to level 2

To restrict access from level 3 to level 2 only, go to the following menu:

```

1 4 - 1   A C C E S S   T O   L E V E L   2

```

Press **Enter**. The following menu appears:

```

A C C E S S   T O   L E V E L   2
O N L Y
Y E S / N O

```

To restrict the controller to access level 2, select 'Yes' and press **Enter**.

5.2.5 Displaying the access codes on the controller after incorrectly entering the access codes:

- The digits in the access codes are replaced by the* symbol. When the + or - buttons are pressed, this symbol is replaced by the digit 0. The digits in the code can then be selected using the + or - buttons.
- The * symbol appears when the digit is confirmed by pressing **Enter**.

- The following message appears for 5 seconds if the access code is not entered correctly:

```

W R O N G   C O D E

```

- When an access level is changed, the following message is displayed for 5 seconds:

A C C E S S L E V E L x

5.3 Configuring access levels on the controller

- All three access levels on all the boards are accessible for a total of 20 hours of 'on' time after the controller is first turned on. During this period any defective boards may be removed and their replacement boards configured and checked to ensure correct operation of machine. This time period will be automatically cancelled if a user switches to level 1 or level 2 before it ends. When the time period ends, level 2 will be authorised unless the person commissioning the system chooses to restrict access by the end user to level 1.

- If access level 3 is authorised in order to adjust the machine parameters and, for indeterminate reasons, it is left accessible to all users, only level 2 access will be possible after a period of 4 hours.
 - Commissioning of the machine can be prohibited simply by setting parameter P99 to 'No' in level 2. Only those with the level 2 access code may re-enable commissioning of the machine.

5.4 Management of the numeric codes for accessing levels 2 and 3

- Access to level 3 is direct for anyone with a PC running the program needed to communicate with CONNECT 2 and who connects to the board.
 - Access to levels 2 and 3 is restricted to **CIAT Service technicians**. Please contact your local **CIAT Service office**.

5.5 Classification of the menus and their functions

Level 1:

➤ Menu: Setpoint, machine status, measured values, control parameters, operation parameters, fault memory, hourly scheduling, communication and access level selection.
 ➤ Function: all functions accessible via the console: On/Off, **Reset**, Heating/Cooling selection; Setpoint 1/2 selection

Level 2:

➤ Menu: all level 1 menus + test mode and master/slave operation

Level 3:

➤ Menu: all level 2 menus + electronic expansion valve

6 LIST OF PARAMETERS

Access levels: **1** = Access to **User** parameters (level 1 parameters only)
2 = Access to visible and editable parameters (level 1 and 2 parameters). EDITABLE numeric code.
3 = Access to **CIAT technician** parameters (level 1, 2 and 3 parameters). UNEDITABLE numeric code

Access level	No.	Description	Setting	Default	Display conditions
CONFIGURATION OF THE MACHINE					
3	1	Refrigerant type	R407C, R134a, R404a, R22, R410A	R410 A	
3	2	Unit type	1-Water-to-Water 2-Air-to-Water 3-Reversible air-to-water	2	
3	3	Number of circuits	1-2	1	
3	4	Number of stages on circuit 1	1 or 2	1	
3	5	Number of stages on circuit 2	0, 1, 2	0 if P3 = 1 1 if P3 = 2	Hidden if P3 = 1
3	6	Number of evaporators	1 if P3 = 1, 1 if P3 = 1 and P2 = air-to-water 2 if P3 = 2	1 if P3 = 1 2 if P3 = 2	
3	7	Compressor supplier	Maneurop - Copeland - Inverter	Copeland	
3	8	Heat exchanger suppliers	CIAT - Swep - Swep double - Alfa laval	CIAT	
3	10	Fan type	Centrifugal - Propeller – Available pressure	Propeller	If P2 = 2, 3
3	11	Coil type	Intertwined - Split - Mixed	Intertwined	If P3 = 2, P10 = pressure , P2 = 2, 3
3	12	Pressure balance solenoid valve	No - Yes	No	If P2 = reversible air-to-water
3	13	Tandem type	Balanced Yes/No	Yes	
3	14	Number of coil sensors per circuit	1.2 or 4	1 if P3 (No. of circuits) = 1 2 if P3 = 2.	

Access level	No.	Description	Setting	Default	Display conditions
OPTION					
2	20	All-season operation	No - Yes	Yes	If P2 = 2, 3
2	21	Variable speed drive	1 - Without 2 - With acoustic optimisation 3 - With energy optimisation	Without	If P2 = 2, 3 P10 = Propeller Value 3 accessible only if P42 = CIAT
2	22	Electric auxiliary heaters	No - Yes	No	If P2 = 1 or 3
2	25	Number of pumps delivered by CIAT	0-1-2 if P2 = 2 and 0-1 if P2 = 3	0	Visible if P2 = 2 or 3
2	26	0-10 V configurable output	2WV - 3WV	2WV	2WV, Visible if P2 = water/water and P3 = 1 3WV, Visible if P2 = water/water
2	27	Pump controlled by operation of boiler	Yes/No	No	Visible if P2 = 3 and P111 = Boiler
2	28	Master/slave control of two machines	Yes/No	No	
2	29	Total recovery	Yes/No	No	If P2 = 2
2	29.1	Frost protection during heat recovery	Yes/No	No	
Breakdown					
3	30	High pressure, HP 1 sensor	10 to 50 b (resolution: 0.1)	34 45 with R410A	
3	31	Low pressure, HP 1 sensor	-1 to 10 b (resolution: 0.1)	-0.5 0 with R410A	
3	32	High pressure, HP 2 sensor	10 to 50 b (resolution: 0.1)	34 45 with R410A	If P3 = 2
3	33	Low pressure, HP 2 sensor	-1 to 10 b (resolution: 0.1)	-0.5 0 with R410A	If P3 = 2
3	36	High pressure, LP 1 sensor	10 to 50 b (resolution: 0.1)	34 45 with R410A 17.3 b if P42 = CIAT	
3	37	Low pressure, LP 1 sensor	-1 to 10 b (resolution: 0.1)	-0.5 0 with R410A	
3	38	High pressure, LP 2 sensor	10 to 50 b (resolution: 0.1)	34 45 with R410A 17.3 b if P42 = CIAT	If P3 = 2
33	39	Low pressure, LP 2 sensor	-1 to 10 b (resolution: 0.1)	-0.5 0 with R410A	If P3 = 2
3	42	Electronic expansion valve	No/ALCO/CIAT	No	
3	43	Superheat protection	Yes/No	No	
3	44	Minimum superheat	0 to 5 K (resolution: 0.1)	0.5 K	If P43 = Yes
3	45	Maximum overheating	10 to 20 K (resolution: 0.1)	15.0 K	If P43 = Yes
3	50	SCP (runtime + off)	3 to 10 min. (resolution: 1)	5	
3	51	Discharge temperature limit	60 to 145°C (resolution: 1)	145°C if Cop.** 135°C if Man.** 125°C if R410A and P7 = Cop**	
3	52	Water line frost protection limit	-25 to 6°C (resolution: 0.1)	2 if P1 = R22, 4 if P1 = 407C, R134a, R404 and 3 if R410A	P52 ≥ 2°C if P22 = Yes
3	53	Δ for refrigerant frost protection limit/P52	2 to 15 K (resolution: 0.1)	10 5 with R410A 7 if P7 = INVERTER	Refrigerant frost protection limit = P52 - P53
3	54	HP fault threshold	15 to 45 b (resolution: 0.1)	27.5 if P1 = R407C or R22 19 if P1 = R134a 24 if P1 = R404a 40.2 b if R410A	

**Cop. = Copeland; Man. = Maneurop

Access level	No.	Description	Setting	Default	Display conditions
Breakdown (continued)					
3	55	LP fault threshold	0.1 to 5 b (resolution: 0.1)	If P2 = 3: 0.5 b If P2 ≠ 3: (1.5 b if P1 = R22, R407C, R404a) and (0.5 b if P1 = R134a) 2.5 b with R410A	
3	58	LP slope factor	0 to 5 b (resolution: 0.5)	1	If P2 = 1, 2 or 3
3	59	Water outlet temperature slope factor	0 to 1 (resolution: 0.1)	0 if P2 = 1 0.5 if P2 = 2 and 3	If P2 = 1, 2, 3
3	63	Minimum HP limit	5 to 25 b (resolution: 0.1)	13 if R22-R407C 8b with R134a 15 b with R404a 18 b with R410A	If P2 = water-to-water
3	64	Optimised frost protection	Yes - No	Yes	If P1 = R410A, P2 = 2 or 3
3	65	Delta T/Heat exchanger type	0 - 10	0	If P64 = Yes: confirm
3	66	Start-up time delay	0 to 300 seconds	120s	If P7 = INVERTER
3	67	Oil warming time delay	Yes - No	Yes	If P7 = INVERTER
3	99	Parameter locking	No - Yes	No	
CUSTOMER CONFIGURATION					
2	100	Language	F - GB - D - SP - I	F	
2	101	Date	DAy/MOnth/YEar		
2	102	Time	HOurs/MInutes		
1	103	Control type	Local - remote (BMS)	Local	
2	108	Pump 2 control	Depending on control mode Depending on On/Off if P2 = 1	Depending on On/Off	Visible if P2 = 1
2	109	Pump 2 'on' time delay	15 to 90 seconds (resolution: 5 seconds)	15	Visible if P2 = 1 and P108 = f (Control)
2	111	Configurable output	Max. power/Boiler/Cooling-heating / Helping on all faults on air-to-water only	P max	
2	112	Number of electric stages	1 to 4	2	Visible if P22 = Yes
2	113	Configurable input	Disabled/Load shedding/Override	Disabled	Visible if P22 = Yes
3	115	Exchanger frost detection enabled	Yes - No	Yes	Visible if P2 = 1, 2, 3
3	116	AEROCNECT LINK	Yes - No	No	
Setpoint Management					
1	119	Operating mode	1 - Cooling 2 - Heating 3 - Cooling/heating via console 4 - Cooling/heating via on/off input 5 - Automatic cooling/heating based on outdoor temperature	Cooling	If P2 = 1 or 3 = All If P2 = 2 = Cooling only
1	120	Number of setpoints	1 - 2 via console - 2 via on/off input - 3 Setpoint managed by 4-20 mA signal	1	
1	121	Cooling setpoint 1	P52 + 1 K at 30°C (resolution: 0.1)	10	If P2 = 1, 2 or 3 P119 ≠ Heating
1	122	Cooling setpoint 2	P52 + 1 K at 30°C (resolution: 0.1)	12	If P120 = 2, P2 = 1, 2 or 3, P119 ≠ Heating
1	123	Heating setpoint 1	20 to 60°C (resolution: 0.1)	40	P119 ≠ Cooling
1	124	Heating setpoint 2	20 to 60°C (resolution: 0.1)	35	P119 ≠ Cooling, P120 = 2
1	125.1	Low setpoint (4-20 mA) during cooling:	P52 + 3 K at 30°C	P52 + 3	Displayed if P120 = 3 and in cooling mode
1	125.2	Low setpoint (4-20 mA) during heating:	10 to 60°C	20	Displayed if P120 = 3 and in heating mode
1	126.1	High setpoint (4-20 mA) in cooling mode:	P125.1 ± 5 K at 30°C with minimum value of P52 + 3	20	Displayed if P120 = 3 and in cooling mode
1	126.2	High setpoint (4-20 mA) in heating mode:	P125.2 ± 5 K at 60°C with minimum value of 10°C.	40	Displayed if P120 = 3 and in heating mode

Access level	No.	Description	Setting	Default	Display conditions
Setpoint Management (CONTINUED)					
1	127	Cooling setpoint adjustment = f (out. temp.)	No - Yes	No	If P2 = 1, 2 or 3 and P119 ≠ Heating
1	128	Drift start	-20 to 55°C (resolution: 1)	25	If P127 = Yes
1	129	Drift end	P128 + 5 K at 60°C (resolution: 1)	35	If P127 = Yes
1	130	Maximum setpoint at end of drift	P52 + 1 K at 30°C (resolution: 0.1)	15	If P127 = Yes
1	131	Heating setpoint adjustment = f (out. temp.)	No - Yes	No	If P2 = 1 or 3 and P119 ≠ Cooling
1	132	Drift start	-20 to 55°C (resolution: 1)	15	If P131 = Yes
1	133	Drift end	-25 to P132 - 5 K (resolution: 1)	5	If P131 = Yes
1	134	Maximum setpoint at end of drift	Highest setpoint if P120 ≠ 1 or setpoint if P120 = 1 at 60°C (resolution: 0.1)	P123	If P131 = Yes
1	135	Minimum boiler drift setpoint	30 to 55°C	50°C	If P111 = Boiler
1	136	Maximum air temperature in automatic heating mode	- 5 to 25°C (resolution 1)	16	If P119 = 5
1	137	Minimum air temperature in automatic cooling mode	P136 + 2 to 40°C (resolution: 1)	20	If P119 = 5
2	141	Control mode	1- Return 3- Water supply 4- Supply with compensation	1	
2	142	Water loop winter protection	No - Yes	No	Visible if P2 = 1 and P141 = 1 and heating mode Visible if P2 = 1 and cooling mode Visible if P2 = 2 or 3
2	143	Stage differential	0.5 to 5 K (resolution: 0.5)	2 1.5	If P141 = 1, 2 if P7 = INVERTER
2	144	Interstage differential	0.5 to 5 K (resolution: 0.5)	1.5	
Supply with compensation by return					
2	145	P coefficient	0.3 to 2 (resolution: 0.1)	1	If P141 = 3, 4 and P7 ≠ INVERTER
2	146	I coefficient	0 to 1 (resolution: 0.1)	0	If P141 = 3, 4 and P7 ≠ INVERTER
2	147	D coefficient	0 to 1 (resolution: 0.1)	0	If P141 = 3, 4 and P7 ≠ INVERTER
2	148	T coefficient	10 to 240 seconds (resolution: 10)	60	If P141 = 3, 4 and P7 ≠ INVERTER
2	150	Compensation of coefficient	0.1 to 1 (resolution: 0.1)	0.5	If P141 = 4
2	151	Compensation of time	5 to P148-2 (resolution: 1)	10	If P141 = 4
For storage control (CRISTOPIA)					
3	154	Storage	Yes/No	No	If P119 ≠ 2, P120 ≠ 1 and P120 ≠ 4
3	155	ΔT of control	0.5 to 10°C (resolution: 0.5)	5	If P154 = Yes
Defrosting					
3	157	Temperature at start of defrosting	-5 to 0°C (resolution: 0.5)	-2	If P2 = 3
3	158	Temperature at end of defrosting	10 to 30°C (resolution: 1)	15 if R407C otherwise 25	If P2 = 3
3	159	Frosting time calculation	Fixed time Optimised	Optimised	If P2 = 3
3	160	Fixed time	30-45-60	45	If P2 = 3
3	161	Coil frosting factor	0 to 2 (resolution: 0.01)	0.3	If P159 = Optimised
3	162	DTD correction based on outdoor temperature	0 to 1 (resolution: 0.01)	0.2	If P159 = Optimised
3	163	CP off time delay for defrosting cycle	0 to 5 min.	60s	P2 = 3 if P7 ≠ INVERTER
3	164	ΔP interlocking ventilo HP	1 to 20 b (resolution: 0.5)	2	If P2 = 3, (P HPR = P54 - P164)
3	165	DHP differential	1 to 5 b (resolution: 0.5)	2	If P2 = 3
3	166	Defrosting HP control coefficient	1 to 5 b (resolution: 1)	3	If P21 ≠ 1
Charge limit					
2	171	Maximum return temperature, stage 2	20 to 50°C (resolution: 1)	35	If P4 + P5 ≥ 2 and P119 ≠ Heating

Access level	No.	Description	Setting	Default	Display conditions
FAN MANAGEMENT					
2	180	Number of HP control stages per circuit	1 to 2 if P3 = 1 2 to 4 if P3 = 2 and P11 = intertwined 2 or 3 if P3 = 2 and P11 = split 3 if P3 = 2 and P11 = mixed	1 if P3 = 1 2 if P3 = 2 and P11 = intertwined 2 if P3 = 2 and P11 = split 3 if P3 = 2 and P11 = mixed	Visible if P2 = 2 or 3 + P10 = propeller
2	181	HP control setpoint	12 to 17 b (resolution: 0.5) if P1 = R407C or R22 14 to 20 b (resolution: 0.5) if P1 = R404a 7 to 13 b (resolution: 0.5) if P1 = R134a 19 to 27 b (resolution: 0.5) if P1 = R410A 13.4 to 27 b if P7 = INVERTER	12 14 7 19	Visible if P2 = 3 or P2 = 2 + P10 = propeller
2	182	Outdoor air temperature, forced HP	10 to 40 (resolution: 1)	25	Visible if P2 = 3 or 2 + P10 = propeller
2	183	Stage differential, HP control	2 to 8 b (resolution: 0.5)	4	Visible if P2 = 3 or 2 + P10 = propeller
2	184	Interstage differential, HP control	0.5 to 3 (resolution: 0.5) 2 to 4 (resolution: 0.5)	1 3	Visible if P2 = 3 or 2 + P10 = propeller If P180 = 1 (Low noise function)
HIGH PRESSURE CONTROL					
3	191	Low Noise operation	Yes - No	No	If P1 = R410A and P2 = 2, 3 or 4 and P180 = 1
2	192	Max. fan speed threshold	5 to 10 V	8.0 5.6 V if P7 = INVERTER	- If P7 ≠ Inverter and P10 = Pressure (P21 = 2 or 3, P180 = 1 and hidden) If P7 = Inverter and P21 = Yes
3	193	Shifting of HP setpoint during total recovery	5 to 14 (resolution: 0.5)	8 if P21 = 1 12 if P21 = 2 or 3	If P29 = Yes
3	195	ΔP	0.1 to 1 b (resolution: 0.1)	0.3	If P4 = P5 ≠ 1
3	196	ΔP	0.1 to 2 b (resolution: 0.1)	1 1.5 with R410A	Visible if P2 = 3 or 2 + P10 = propeller
2	197	Value at 0 V	19 to 28 if P26 = 2WV 10 to 25°C if P26 = 3WV	19b 20°C	Visible if P2 = Water-to-Water and P3 = 1 Visible if P2 = Water-to-Water
2	198	Value at 10 V	28 to 39 if P26 = 2WV 25 at 40°C if P26 = 3WV	28b 30°C	Visible if P2 = Water-to-Water and P3 = 1 Visible if P2 = Water-to-Water
Limits					
3	220	Outdoor temperature, unit winter protection	2 to 10°C (resolution: 1)	2	If cooling and P142 = Yes If P2 = Air-to-water
3	222	Outdoor temperature differential, unit winter protection	1 to 10 K (resolution: 1)	2	If cooling and P142 = Yes If P2 = Air-to-water
3	225	Minimum outdoor air temperature in HEATING mode	-25 to 5°C (resolution: 1)	-10 -20	If P119 ≠ cooling and P2 = 3 If P7 = INVERTER
3	225.1	Maximum outdoor air temperature in COOLING mode	35 to 50°C (resolution: 1)	DISABLED	
3	225.2	Maximum outdoor air temperature in HEATING mode	-5 to +25°C (resolution: 1)	DISABLED	if P2 = water-to-water and reversible air-to-water when P119 ≠ 1
3	225.3	Minimum outdoor air temperature in COOLING mode	-20 to +25°C (resolution: 1)	DISABLED	if P2 = water-to-water and reversible air-to-water when P119 ≠ 2
3	226	Outdoor temperature Boiler operation authorisation	P225 at 25°C if P2 = 3 and P119 ≠ cooling -20 to 25°C if P2 = 1 and P119 ≠ cooling	5	(resolution: 1)
2	230	On authorisation, stage 1 circuit 1	No - Yes	Yes	
2	231	On authorisation, stage 2 circuit 1	No - Yes	Yes	If P4 = 2
2	232	On authorisation, stage 1 circuit 2	No - Yes	Yes	If P3 = 2
2	233	On authorisation, stage 2 circuit 2	No - Yes	Yes	If P5 = 2, P3 = 2
2	235	On authorisation, electric stage 1	No - Yes	Yes	If P22 = Yes
2	236	On authorisation, electric stage 2	No - Yes	Yes	If P22 = Yes
2	237	On authorisation, electric stage 3	No - Yes	Yes	If P22 = Yes
2	238	On authorisation, electric stage 4	No - Yes	Yes	If P22 = Yes and P112 = 4
Read-only					
1	250	LED test			

Access level	No.	Description	Setting	Default	Display conditions
Read-only (CONTINUED)					
1	251	Control setpoint			If P141 ≠ 5 and ≠ 6
1	252	Outdoor air temperature			
1	255	Water inlet temperature, heat exchanger 1			
1	256	Water outlet temperature, heat exchanger 1			
1	257	Hot water inlet temp., condenser			If P2 = 1 and P141 = 1
1	258	Hot water outlet temp., condenser			If P2 = 1 and P141 = 3
1	259	Refrigerant temperature, circuit 1 coils A-B C-D			If P2 = 3 If P2 = 3 and P14 = 2 If P2 = 3 and P14 = 4
1	260	Refrigerant temperature, heat exchanger 1			If P2 = 1 or 2
1	261	Manifold water outlet temperature			If P6 = 2 - P2 = 1, 2 or 3
1	262	Water outlet temperature, heat exchanger 2			If P6 = 2
1	263	Refrigerant temperature, circuit 2 coils A-B C-D			If P2 = 3 and P3 = 2 If P2 = 3 and P3 = 2 and P14 = 2 If P2 = 3 and P3 = 2 and P14 = 4
1	264	Refrigerant temperature, heat exchanger 2			If P2 = 1 or 2 and if P6 = 2
1	265	Exchanger ambient temperature			If P2 = Air-to-water
1	266	Calculated frosting time, circuit 1			If P2 = 3,
1	267	Calculated frosting time, circuit 2			If P2 = 3 and P3 = 2
1	268	Value of reference ΔT for defrosting of circuit 1			If P159 = Optimised
1	269	Value of reference ΔT for defrosting of circuit 2			If P159 = Optimised and P3 = 2
1	285	Runtime in heating mode			If P119 ≠ Cooling
1	286	Runtime in cooling mode			If P119 ≠ Heating
1	287	Pump 1 runtime (in hours)			
1	288	Pump 2 runtime (in hours)			If (P2 = 1) or P25 = 2
1	289	No. of times P99 set to "No"			
1	290	No. of water flow cut-offs in 1 hour			Visible if (cooling and P2 = 1) or if P2 = 3 or if P2 = 2 and P25 ≠ 2
Circuit 1					
1	300	Circuit 1 HP			
1	300.1	Circuit 1 HP control setpoint			If P3 = 1 or 2 and P11 = Intertwined
1	301	Circuit 1 condensation temperature	See appendix		
1	302.1	Discharge temperature 1			
1	302.2	Discharge temperature 2			If P4 = 2
1	303.1	Desuperheat on discharge 1	P302.1 - P301		
1	303.2	Desuperheat on discharge 2	P302.2 - P301		If P4 = 2
1	304	Circuit 1 LP			
1	305	Circuit 1 evaporation temperature	See appendix		
1	306	Circuit 1 suction temperature	°C		
1	307	Circuit 1 superheat	°C		
1	308	Number of HP1 cut-offs in 24 hours			
1	309	Number of LP1 cut-offs in 24 hours			
1	310	Number of starts, stage 1, circuit 1			
1	311	Runtime (in hours), stage 1, circuit 1			
1	312	SCP, stage 1, circuit 1			
1	313	Number of starts, stage 2, circuit 1			If P4 = 2
1	314	Runtime (in hours), stage 2, circuit 1			If P4 = 2
1	315	SCP, stage 2, circuit 1			If P4 = 2
1	322	No. of water line frost protection cut-offs, circuit 1			
1	323	No. of refrigerant line frost protection cut-offs, circuit 1			If P2 ≠ 3
1	324.1	No. of cut-offs caused by discharge temperature 1 in 24 hours			
1	324.2	No. of cut-offs caused by discharge temperature 2 in 24 hours			If P4 = 2

Access level	No.	Description	Setting	Default	Display conditions
Circuit 1 (CONTINUED)					
1	325	Opening of circuit 1 expansion valve	%		If P42 = CIAT and P3 = 1
1	326	Circuit 1 liquid temperature	°C		If P2 = 1 or 2 or (3 + cooling mode)
1	327	Circuit 1 subcooling	°C		If P2 = 1 or 2 or (3 + cooling mode)
1	328	No. of cut-offs caused by C1 electronic expansion valve fault in 24 hours			If P42 = ALCO
Circuit 2					
1	330	Circuit 2 HP			If P3 = 2
1	330.1	Circuit 2 HP control setpoint			If P3 = 2 and #Intertwined
1	331	Circuit 2 condensation temperature	See appendix		If P3 = 2
1	332.1	Discharge temperature 3 Discharge temperature 2	°C		If P3 = 2 and P4 = 2 If P3 = 2 and P4 = 1
1	332.2	Discharge temperature 4	°C		If P3 = 2 and P5 = 2
1	333.1	Desuperheat on discharge 3 Desuperheat on discharge 2	P332.1 - P331		If P3 = 2 and P4 = 2 If P3 = 2 and P4 = 1
1	333.2	Desuperheat on discharge 4	P332.2 - P331		If P3 = 2 and P5 = 2
1	334	Circuit 2 LP			If P3 = 2
1	335	Circuit 2 evaporation temperature	See appendix		If P3 = 2
1	336	Circuit 2 suction temperature	°C		If P3 = 2
1	337	Circuit 2 superheat	°C		If P3 = 2
1	338	Number of HP2 cut-offs in 24 hours			If P3 = 2
1	339	Number of LP2 cut-offs in 24 hours			If P3 = 2
1	340	Number of starts, stage 1, circuit 2			If P3 = 2
1	341	Runtime (in hours), stage 1, circuit 2			If P3 = 2
1	342	SCP, stage 1, circuit 2			If P3 = 2
1	343	Number of starts, stage 2, circuit 2			If P3 = 2, P5 = 2
1	344	Runtime (in hours), stage 2, circuit 2			If P3 = 2, P5 = 2
1	345	SCP, stage 2, circuit 2			If P3 = 2, P5 = 2
1	352	No. of water line frost protection cut-offs, circuit 2			If P3 = 2 and P2 ≠ 4, 5
1	353	No. of refrigerant line frost protection cut-offs, circuit 2			
1	354.1	No. of cut-offs caused by discharge T° 2 in 24 hours No. of cut-offs caused by discharge T° 3 in 24 hours			If P3 = 2 and P4 = 1 If P3 = 2 and P4 = 2
1	354.2	No. of cut-offs caused by discharge T° 4 in 24 hours			If P3 = 2 and P5 = 2
1	355	Opening of circuit 2 expansion valve	%		P42 = CIAT and P3 = 2
1	356	Circuit 2 liquid temperature	°C		If [P2 = 1 or 2 or (3 + cooling mode)] and P3 = 2
1	357	Circuit 2 subcooling	°C		If [P2 = 1 or 2 or (3 + cooling mode)] and P3 = 2
1	358	No. of cut-offs caused by C1 electronic expansion valve fault in 24 hours			If P42 = ALCO
INPUTS					
1	400	Automatic machine operation control	Open/Closed		
1	402	Setpoint 1/Setpoint 2 selection	Open/Closed		If P120 = 2 via On/Off control
1	403	Water flow check	Open/Closed		
1	404	Fan fault check	Open/Closed		If P2 ≠ 1 or 5
1	405	Cooling/Heating input check	Open/Closed		If P119 = Cooling/Heating via On/Off control
1	406	Phase controller	Open/Closed		
1	407	Recovery operating mode selection	Open/Closed		If P29 = Yes
1	408	Check of fault input for auxiliary electric heater 1	Open/Closed		If P22 = Yes
1	409	Check of fault input for auxiliary electric heater 2	Open/Closed		If P22 = Yes
1	410	Check of configurable auxiliary electric heater input	Open/Closed		If P22 = Yes
1	414	Check of override/load shedding input 1	Open/Closed		
1	415	Check of override/load shedding input 2	Open/Closed		If P4 = 2
1	416	Check of override/load shedding input 3	Open/Closed		If P3 = 2
1	417	Check of override/load shedding input 4	Open/Closed		If P5 = 2

Access level	No.	Description	Setting	Default	Display conditions
INPUTS (CONTINUED)					
1	418	Check of manual HP1 pressure switch input	Open/Closed		
1	419	Check of stage 1, circuit 1 fault input	Open/Closed		
1	420	Check of stage 2, circuit 1 fault input	Open/Closed		If P4 = 2
1	422	Check of manual HP2 pressure switch input	Open/Closed		If P3 = 2
1	423	Check of stage 1, circuit 2 fault input	Open/Closed		If P3 = 2
1	424	Check of stage 2, circuit 2 fault input	Open/Closed		If P5 = 2
1	425	Check of fault input for circuit 1 electronic expansion valve	Open/Closed		If P42 = ALCO
1	426	Check of fault input for circuit 2 electronic expansion valve	Open/Closed		If P42 = ALCO
OUTPUTS					
1	430	Pump 1 control state	On/Off		
1	431	Pump 2 control state	On/Off		If (P2 = 1) or P25 = 2
1	432	State of circuit 1 Y/C control output	On/Off		If P2 = 3
1	433	State of circuit 2 Y/C control output	On/Off		If P2 = 3 and P3 = 2
1	435	State of heat trace cable control output	On/Off		If P2 ≠ 1 (water-to-water)
1	436	State of heater control output	On/Off		If P2 ≠ 1 (water-to-water)
1	437	State of recovery heat trace cable control output	On/Off		If P2 ≠ 1 (water-to-water) and P29.1 = Yes
1	438	State of maximum power output	On/Off		If P111 = Max. power
1	439	State of boiler output	On/Off		If P111 = Boiler
1	440	State of cooling/heating output	On/Off		If P111 = Cooling/Heating
1	441	State of HP control output, stage 1, circuit 1	On/Off if P21 = without High Temperature mode/Low Noise mode/Off if P191 = acoustic		If P21 = without, P2 = 2, 3
1	442	State of HP control output, stage 2, circuit 1	On/Off		If P180 = 2 and P3 = 1, P2 = 2, 3
1	443	State of HP control output, stage 1, circuit 2	On/Off		If P180 = 1 and P3 = 2, P2 = 2, 3
1	444	State of HP control output, stage 2, circuit 2	On/Off		If P180 = 2 and P3 = 2, P2 = 2, 3
1	445	State of HP control output, stage 3, circuit 1 or State of HP control output, common stage 1	On/Off		If P180 = 3 and P3 = 2 P11 = split P2 = 2, 3 or If P180 = 3 and P3 = 2 P11 = mixed
1	446	State of HP control output, stage 3, circuit 2 or State of HP control output, common stage 3	On/Off		If P180 = 3 and P3 = 2 P11 = split P2 = 2, 3 or If P180 = 3 and P3 = 2, P11 = mixed
1	447	Driving voltage, stage 1, HP control	0-10 V		If P21 = 2 or 3 and P11 = Intertwined
1	448	Driving voltage, stage 1, circuit 1, HP control	0-10 V		If P21 = 2 or 3 and P11 = split or mixed
1	449	Driving voltage, stage 1, circuit 2, HP control	0-10 V		If P21 = 2 or 3 and P11 = split or mixed
1	450	Driving voltage, common stage 1, HP control	0-10 V		If P21 = 2 or 3 and P11 = Mixed
1	451	State of circuit 1 balance valve output	On/Off		If P12 = Yes
1	452	State of circuit 2 balance valve output	On/Off		If P12 = Yes
1	530	State of electric stage 1	On/Off		If P22 = Yes
1	531	State of electric stage 2	On/Off		If P22 = Yes
1	532	State of electric stage 3	On/Off		If P22 = Yes
1	533	State of electric stage 4	On/Off		If P22 = Yes and P112 = 4
1	535	Air blade percentage information	0-100%		If P20 = Yes and P10 = Centrifugal
1	555	CPU version number			
1	556	Console version number	*		
1	557	Version number of circuit 2 board			If P3 = 2
1	558	Version number of changeover board			If P2 = reversible air-to-water
1	559	Version number of auxiliary heater board			If P22 = Yes
1	560	Version number of circuit 1 expansion valve	XX.YY VCM XX.YY		If P42 = CIAT and P3 = 1
1	561	Version number of circuit 2 expansion valve	XX.YY VCM XX.YY		If P42 = CIAT and P3 = 2
1	570	"SO" order number"			To be entered via a PC
1	571	MO number			To be entered via a PC
1	572	Machine identification name			To be entered via a PC
1	573	Machine identification number			To be entered via a PC

Access level	No.	Description	Setting	Default	Display conditions
ELECTRONIC EXPANSION VALVE					
Circuit 1					
3	601	Circuit 1 valve type	EX4 - EX5 - EX6 - EX7 - EX8	EX4	If P42 = CIAT and P3 = 2
3	602	Circuit 1 superheat setpoint	0.5 to 30°C	6	If P42 = CIAT and P3 = 1
3	603	Circuit 1 MOP point	Yes - No	No	If P42 = CIAT and P3 = 1
3	604	Circuit 1 MOP value	+ 5 to 25°C	15	If P42 = CIAT and P603 = Yes and P3 = 1
3	605	Opening of C1 valve when air conditioning started	10 to 100%	50	If P42 = CIAT and P3 = 1
3	606	Opening of C1 valve when heat pump started	10 to 100 %	20	If P42 = CIAT and P3 = 1 and P2 = reversible air-to-water
3	607	Opening time at start-up, C1	1 to 60 seconds	5	If P42 = CIAT and P3 = 1
3	608	Circuit 1 slow mode	Yes/No	No	If P42 = CIAT and P3 = 1
Circuit 2					
3	611	Circuit 2 valve type	EX4 - EX5 - EX6 - EX7 - EX8	EX4	If P42 = CIAT and P3 = 2
3	612	Circuit 2 superheat setpoint	0.5 to 30°C	6	If P42 = CIAT and P3 = 2
3	613	Circuit 2 MOP point	Yes - No	No	If P42 = CIAT and P3 = 2
3	614	Circuit 2 MOP value	+ 5 to 25°C	15	If P42 = CIAT and P609 = Yes and P3 = 2
3	615	Opening of C2 valve when air conditioning started	10 to 100 %	50	If P42 = CIAT and P3 = 2
3	616	Opening of C2 valve when heat pump started	10 to 100 %	20	If P42 = CIAT and P3 = 2 and P2 = reversible air-to-water
3	617	Opening time at start-up, C2	1 to 60 seconds	5	If P42 = CIAT and P3 = 2
3	618	Circuit 2 slow mode			If P42 = CIAT and P3 = 2
COMMUNICATION					
1	700	Communication protocol	BUS MODE	BUS MODE	
1	701	Transmission speed	Adjustable: 4800, 9600 baud or 9600 jbus	9600 baud	
1	702	Parity	Without, even or odd	without	
1	703	Number of stop bits	1 or 2	1	
1	704	Swapped real number format	Yes or No	Yes	
1	705	Bus number	0 to 255	1	
MASTER/SLAVE (2 MACHINES) If P28 = Yes					
2	800	Master machine on loop	Yes/No	No	If P28 = Yes
2	801	Backup machine	Yes/No	No	If P28 = Yes
2	802	Switch backup machine	Yes/No	No	If P28 = Yes
2	803	Name of backup machine	Master/Slave	Slave	If P28 = Yes
2	804	Loop control type	CASCADE or PARALLEL or PROGRESSIVE	CASCADE	If P28 = Yes
2	805	Machine differential	0.5 to 5°C	1.5	If P28 = Yes
2	806	Differential between machines	1 to 10°C	4.0	If P28 = Yes
2	807	Maximum differential, additional machine	1 to 10°C	0.0	if P801 = Yes
2	808	Time delay between machines	0 to 60 min.	1	If P28 = Yes
2	809	Machine 1 'on' authorisation	Yes/No	Yes	If P28 = Yes
2	810	Machine 2 'on' authorisation	Yes/No	Yes	If P28 = Yes
2	811	Pump turned off by control	No Yes, except for one Yes, machine off		

7 MANAGEMENT OF AERO-CONNECT PARAMETERS

To access all AERO-CONNECT parameters in read/write mode, set parameter P116 (AERO-CONNECT link) to 'Yes'.

1 3 - A E R O - C O N N E C T

- Menu 13 allows all information about AEROCONNECT to be displayed on the CONNECT 2 console without having to use the AEROCONNECT console.
- The AERO-CONNECT parameters are preceded by the letter A to differentiate them from the CONNECT 2 parameters.
- If a dry cooler equipped with its AERO-CONNECT console is connected to CONNECT 2 and P116 is set to 'Yes', neither console has priority over the other.
- If menu 13 remains open for 1 hour and no buttons are pressed during this time, the screen switches to the CONNECT 2 display.
- Parameter A99 (lock parameters) cannot be set to 'No' via the CONNECT 2 console.
- Parameter A116 (CIAT CW unit link) is not accessible via the CONNECT 2 console because setting A116 to 'No' will delete the link with the console.
- Parameter A250 is not accessible because the LED test on the CONNECT 2 console is performed via parameter P250 on CONNECT 2.
- The forced fan operation function on the console is not accessible via the CONNECT 2 console.

8 CONTENTS OF THE MENUS

The ° symbol stands for °C in the electronic programming system.

Analogue values are displayed with one decimal place. The hundreds digit may be replaced by a negative sign when appropriate.

A selection symbol flashes at the left of the display.

Holding down the + or - buttons will cause increasingly faster scrolling (and change the units) in the list of parameters or when modifying parameter values.

8.1 MAIN menu

Scrolling through menus occurs line by line.

The + button is used to increment values and the - button is used to decrement values.

The first square at the top left flashes.

```

1 - S E T P O I N T S
2 - S T A T U S   O F   M A C H I N E S

3 - M E A S U R E D   V A L U E S
4 - M A C H I N E . P A R A M E T E R S

5 - A D J U S T M E N T . P A R A M E T E R S
6 - R E A D I N G . P A R A M E T E R S

7 - F A U L T   M E M O R Y
8 - T E S T   M O D E

9 - P R O G R A M M I N G
10 - E L E C T R O   E X P A N S I O N   V A L

11 -   C O M M U N I C A T I O N
12 -   M A S T E R / S L A V E

13 -   A E R O - C O N N E C T
14 -   A C C E S S   L E V E L   S E L E C T .

```

8.2 SETPOINTS menu

This menu gives quick access to settings for the control setpoints depending on the control mode and the selected operating mode.

<pre> P x x x S T P 1 C O O L I N G - x x . x ° P x x x S T P 2 C O O L I N G - x x . x ° P x x x : S T P 1 H E A T I N G - x x . x ° P x x x : S T P 2 H E A T I N G - x x . x ° </pre>	<pre> } If P119 ≠ heating } If P120 = 2 and if P119 ≠ heating } If P119 ≠ cooling } If P120 = 2 and P119 ≠ cooling </pre>
--	---

To move from parameter to parameter, press the + or - buttons. The letter **P** flashes when a parameter is selected.

To change the value of a selected parameter, press **OK**. The value can be changed when the cursor flashes at the bottom right. Use the + button to raise the value, and the - button to lower it. When finished, press **OK** to confirm or **ESC** to cancel the changes.

When returning to menu 1 the last parameter consulted is displayed.

8.3 MACHINE STATUS menu

To enter the MACHINE STATUS menu, use the + or - buttons to position the cursor on 2 then press OK.

8.3.1 Main table

This screen reappears automatically after one hour if

No general faults occur, no controls are activated (via the console, modem, etc.), no general faults are reported and no automatic controls are closed:

```

          C O N N E C T 2                h h / m n
R E T U R N   T E M P . : - x x . x °
S E T P O I N T       : - x x . x °           ↓
⊖ 1 O F F ⊖ 2 O N ⊖ 3 S C P ⊖ 4 S C P
    
```

The ↓arrow appears if there is another message.

- If a general fault occurs on the main machine, the messages are displayed on lines 2 and 3 in the following order of importance:

```

          M A C H I N E   O F F
W A T E R   F L O W   F A U L T
    
```

```

W A T E R   F L O W   F A U L T
X   C U T ( S )   I N   1 H
    
```

```

          M A C H I N E   O F F
O U T   T E M P .   T O O   L O W
    
```

```

          M A C H I N E   O F F
O U T   T E M P .   T O O   H I G H
    
```

```

          M A C H I N E   O F F
P H A S E   C T R L L R   F A U L T
    
```

```

C O M P R E S S O R
D R I V E R   F A U L T
    
```

} If P7 = INVERTER

```

O U T .   T E M P .   S E N S O R   F A U L T
                    J 7 / 1 - 2
    
```

} If machine off

```

C O N D E N S E R   I N L E T
S E N S O R   F A U L T   J 7 / 5 - 6
    
```

```

C O N D E N S E R   O U T L E T
S E N S O R   F A U L T   J 7 / 5 - 6
    
```

```

M A N I F . W A T E R   O U T L E T
S E N S O R   F A U L T   A D D 2   J 4 / 2 - 3
    
```

} If machine off

```

E X C H . 1   W A T E R   O U T L E T
S E N S O R   F A U L T   J 7 / 2 - 3
    
```

```

M A C H I N E   O F F
O P E R A T I N G   M O D E   C H A N G E
    
```

If an automatic operation control is activated → the On/Off LED flashes:

```

M A I N T A I N   W A T E R   L O O P
T E M P E R A T U R E   A T   3 0 °
    
```

```

W A T E R   C I R C U L A T I O N
P U M P   F O R C E D   O N
    
```

```

U N I T   S T O P   B Y
R E M O T E   C O N T A C T
    
```

```

          M A C H I N E   O F F
O N / O F F
    
```


8.3.2 MACHINE STATUS table

This table appears only if any of the following messages must be displayed using the ↑ and ↓ buttons.
The messages are displayed in the following order of priority:

M A C H I N E S T A T U S F A N F A U L T
P U M P 1 O N x x s
P U M P 2 O N x x s
W A T E R R E T U R N T . L I M I T P O W E R R E D U C .
E X C H A N G E R A M B . T E M P . D U R I N G F R O S T P R O T E C .
N O . S T A G E S T O B E S H U T O F F : X
U N I T D I S C H . T . L I M I T O P T I M I S E D O P E R A T I O N
E L E C A U X C T R L O U T T E M P . T O O L O W
W A T E R T E M P . R I S I N G F O R D E F R O S T I N G
O U T . T E M P . S E N S O R F A U L T J 7 / 1 - 2
M A N I F . W A T E R O U T L E T S E N S O R F A U L T A D D 2 J 4 / 2 - 3
E X C H A N G E R A M B I E N T T E M P . S E N S O R F A U L T J 7 / 5 - 6
H P P R E S S U R E C O N T R O L S T A G E 1 O N L Y
S E L F - A D J U S T I N G C O N T R O L M O D E

8.3.3 Table of "MACHINE STATUS circuit x fault" messages:

This table appears only if any of the following messages must be displayed using the ↑ and ↓ buttons.
The messages are displayed in the following order of priority:

C I R C U I T 2 O F F L I N K F A U L T
M O T O R F A U L T S T A G E x C I R C U I T x
C I R C U I T X O F F W A T E R F R O S T F A U L T
C I R C X H 2 O F R O S T F A U L T X C U T (S) I N 2 4 H

CIRCUIT x OFF REFRIG. FROST FAULT	
CIRC X REF FROST FAULT x CUT (S) IN 24 H	
CIRCUIT X OFF HP FAULT	
HP FAULT CIRC x x x m n x CUT (S) IN 24 H	
CIRCUIT X OFF MANUAL HP FAULT	
CIRCUIT X OFF LP FAULT	
CIRCUIT x LP FAULT x CUT (S) IN 24 H	
STAGE x OFF DISCHARGE FAULT	
CIRCUIT x OFF DEFROSTING IMPOSSIBLE	
D. TEMP FAULT x x x m n x CUT (S) IN 24 H	
CIRCUIT X OFF EXP. VALVE FAULT	{ If P42 ≠ NO
FAULT ON EXV X x CUTS IN 24 H	{ If P42 ≠ NO
BOARD LINK FAULT CIRCUIT X EXV	{ If P 42 = CIAT
ACTUATOR FAULT CIRCUIT X EXV	{ If P42 ≠ CIAT
CIRCUIT X OFF MIN. SUPERHEAT FAULT	
CIRCUIT X OFF MAX. SUPERHEAT FAULT	
MIN SUPERHEAT FAULT CX x CUT (S) IN 1 H	
MAX SUPERHEAT FAULT CX x CUT (S) IN 1 H	
EXCH. 1 WATER INLET SENSOR FAULT J 7 / 2 - 3	
EXCH. x WATER OUTLET SENSOR FAULT J X / X - X	

S U C T I O N T E M P . S E N S O R F A U L T C I R C . x J x / x x - x x
E X C H . x R E F R . F R O S T P R O T . S E N S . F A U L T J x / x - x
C O I L x C I R C U I T x S E N S O R F A U L T J x / x - x
D . T E M P . S E N S O R X F A U L T J x / x - x
L I Q U I D T E M P . S E N S O R F A U L T C I R C . x J x / x x - x x
x P x S E N S O R F A U L T I N L E T J x / x x - x x
S T A G E x C I R C U I T x A T M I N . S T O P x x m n x x S
S H O R T - C Y C L E P R O T E C T I O N S T A G E x C I R x x x m n x x S
C I R C U I T x S T A G E x F O R C E D O F F
S T A G E x C I R C U I T x T U R N I N G O F F

Informational messages:

C X R E F R I G F R O S T L I M . P O W E R R E D U C .
C I R C . x W A T E R F R O S T L I M . P O W E R R E D U C .
C I R C U I T x H P L I M I T P W R R E D U C T I O N x x m n
C I R C . X D . T E M P L I M I T R E D U C T I O N x x m n
C I R C . x M I N . H P L I M . P O W E R R E D U C .
H P x P R E S S U R E C O N T R O L S T A G E 1 O N L Y
C I R C U I T X B E I N G D E F R O S T E D

8.3.4 Electric stages table:

E L E C . S T A G E S S H U T O F F B Y L O A D S H E D D I N G I N P U T
E L E C . S T A G E S O V E R R I D D E N B Y O V E R R I D E I N P U T
E L E C T R I C S T A G E F O R C E D O F F x

8.4 Measured values menu

To access the MEASURED VALUES menu, use the + or - buttons to position the cursor on 3, then press **OK** (the list of submenus can then be accessed).
 Position the cursor on **CIRCUIT 1** or **CIRCUIT 2** then press **OK**.
 The values for the circuit selected appear.

Use the + and - buttons to scroll through the tables at a rate of three rows at a time.
 The square at the bottom right flashes for the reading.
 Press the **ESC** button to return to the main menu.

Example:

Visible if P3 = 2 }

C I R C U I T 1
C I R C U I T 2

For circuit 1:

Visible if P141 = 3 }	C L G R E T U R N C T R L	↑	
	C T R L S T P : - x x . x °	↓	
	W A T E R I N L E T : - x x . x °		
Visible if P3 = 2 }	W A T E R o r M A N O U T L E T : x x . x °		
	H P 1 : x x x . x b C O N T : + x x . x °	↑	
	B P 1 : x x x . x b E V A T : + x x . x °	↓	
	S U C T I O N T . x : + x x . x °		
	O V E R H E A T 1 : x x . x °	↑	
	D I S . T 1 : x x x ° D I S . T 2 : x x x °	↓	
	O U T D O O R T . : - x x . x °		
	Visible if water-to-water and operating mode ≠ heating }	W A T E R O U T L E T 1 : - x x . x °	↑
		W A T E R O U T L E T 2 : - x x . x °	↓
		M A N . W A T E R O U T : - x x . x °	
Visible if P2 = 1 or 2, or 3 + cooling mode }	R E F R I G . T . 1 + x x . x °	↑	
	L I Q U I D T E M P . 1 + x x . x °	↓	
	H O T W A T E R T . - x x . x	↓	

For circuit 2:

The menu for circuit 2 is the same as for circuit 1, but with the digit 1 replaced by the digit 2. Thus, discharge temperature **REF 1** becomes **REF 2** (or **3** depending on the number of compressors per circuit) and **REF 2** becomes **DISCHARGE 4**.
 Message on first row:

H O T S U P P L Y C T R L	↑
H O T R E T U R N C T R L	↓
C L G R E T U R N C T R L	↑
S T O R A G E C T R L	↓
C O M P E N S A T I O N C T R L	↑


8.5 MACHINE PARAMETERS menu

To access the MACHINE PARAMETERS menu, use the + or - buttons to position the cursor on 4 then press **OK**.
 The display shows the list of configuration parameters.
 Use the + and - buttons to scroll through the tables at a rate of two rows at a time.
 To modify a parameter the configuration must be unlocked (via parameter P99). This turns off the machine.

•To change a value:

Press **OK** to enter the parameter. Use the + or - buttons to increment or decrement the value of the parameter then press **OK** to confirm the changes. Press **OK** to save the change or **ESC** to

cancel. When a parameter value is being changed, the square at the bottom right should flash.
 In the case of parameters, the letter **P** flashes.
 The text in messages scrolls in a loop.
 Numerical values (with adjustment ranges), however, do not scroll in a loop.

If a parameter is locked (P99 = yes), the  symbol is displayed at the top left.

To return to the main menu, press the **ESC** button repeatedly.

4 - M A C H I N E . P A R A M E T E R

If the user tries to access a locked parameter, the following message appears for 2 seconds before the parameter is redisplayed:

P A R A M E T E R L O C K E D
M O D I F I C A T I O N . I M P O S S I B L E

Once the user sets the "locking" parameter to "NO", the text is marked Pxx and the button symbol disappears. The following parameters can then be accessed:

Refrigerant type:

P 0 1	R 4 0 7 c
R E F R I G E R A N T	
P 0 1	R 1 3 4 a
R E F R I G E R A N T	
P 0 1	R 4 1 0 a
R E F R I G E R A N T	
P 0 1	R 2 2
R E F R I G E R A N T	

Unit type:

P 0 2	W A T E R - T O - W A T E R
U N I T	
P 0 2	A I R - T O - W A T E R
U N I T	
P 0 2	R E V E R S I B L E A I R - T O -
W A T E R U N I T	

Number of circuits:

P 0 3	N U M B E R O F C I R C U I T S	1
P 0 3	N U M B E R O F C I R C U I T S	2

Number of stages per circuit:

P x x	N O . O F S T A G E S O N	1
C I R C U I T x		
P x x	N O . O F S T A G E S O N	2
C I R C U I T x		

Number of evaporators:

P 0 6	N O . O F E V A P O R A T O R S	1
P 0 6	N O . O F E V A P O R A T O R S	2

Compressor suppliers:

P 0 7	M A N E U R O P
C O M P R E S S O R	
P 0 7	C O P E L A N D
C O M P R E S S O R	
P 0 7	I N V E R T E R
C O M P R E S S O R	

Heat exchanger suppliers:

P 0 8	E X C H A N G E R	C I A T
P 0 8	E X C H A N G E R	S W E P
P 0 8	E X C H A N G E R	S W E P D O U B L E
P 0 8	E X C H A N G E R	A L F A L A V A L

Fan type:

P 1 0	F A N T Y P E	P R O P E L L E R
P 1 0	F A N T Y P E	C E N T R I F U G A L
P 1 0	F A N T Y P E	P R E S S U R E

Coil type:

P 1 1	C O I L T Y P E	I N T E R T W I N E D
P 1 1	C O I L T Y P E	S P L I T
P 1 1	C O I L T Y P E	M I X E D

Presence of balance solenoid valve:

P 1 2	B A L A N C E S V	Y E S
P 1 2	B A L A N C E S V	N O

Tandem type:

P 1 3	B A L A N C E D T A N D E M	Y E S
P 1 3	C O M P R E S S O R S	
P 1 3	B A L A N C E D T A N D E M	N O
P 1 3	C O M P R E S S O R S	

Number of coil sensors per circuit:

P 1 4	N U M B E R O F C O I L S E N S O R	
P 1 4	P E R C I R C U I T	1
P 1 4	N U M B E R O F C O I L S E N S O R	
P 1 4	P E R C I R C U I T	2
P 1 4	N U M B E R O F C O I L S E N S O R	
P 1 4	P E R C I R C U I T	4

All-season operation:

P 2 0	A L L - S E A S O N	
P 2 0	O P E R A T I O N	N O

P 2 0 A L L - S E A S O N O P E R A T I O N	Y E S
---	-------

Variable speed control board:

P 2 1 V A R I A B L E S P E E D W I T H O U T	
P 2 1 V A R I A B L E S P E E D A C O U S T I C O P T I M I S A T I O N	
P 2 1 V A R I A B L E S P E E D E N E R G Y O P T I M I S A T I O N	

Electric auxiliary heater board:

P 2 2 E L E C T R I C A U X I L I A R Y H E A T E R S	N O
P 2 2 E L E C T R I C A U X I L I A R Y H E A T E R S	Y E S

Number of pumps:

P 2 5 N U M B E R O F P U M P S S U P P L I E D B Y C I A T	0
P 2 5 N U M B E R O F P U M P S S U P P L I E D B Y C I A T	1
P 2 5 N U M B E R O F P U M P S S U P P L I E D B Y C I A T	2

0-10 V configurable output:

P 2 6 0 - 1 0 V P R O G R A M M A B L E O U T P U T 2 - W A Y V A L V E	
P 2 6 0 - 1 0 V P R O G R A M M A B L E O U T P U T 3 - W A Y V A L V E	

Pump controlled by operation of boiler:

P 2 7 P U M P C O N T R O L L E D B Y B O I L E R	N O
P 2 7 P U M P C O N T R O L L E D B Y B O I L E R	Y E S

Master/slave control of two machines:

P 2 8 M A S T E R S L A V E 2 M A C H I N E S	N O
P 2 8 M A S T E R S L A V E 2 M A C H I N E S	Y E S

Total recovery:

P 2 9 T O T A L R E C O V E R Y	N O
P 2 9 T O T A L R E C O V E R Y	Y E S

Frost protection for recovery option:

P 2 9 . 1	H E A T	R E C O V .	E X C H .
F R O S T	P R O T E C T I O N		N O
P 2 9 . 1	H E A T	R E C O V .	E X C H .
F R O S T	P R O T E C T I O N		Y E S

HP1/HP2 sensor high pressure:

Same with LP (Low Pressure) }	P x x	H P x	S E N S O R	
	H I G H	V A L U E		x x . x b

HP1/HP2 sensor low pressure:

Same with LP (Low Pressure) }	P x x	H P x	S E N S O R	
	L O W	V A L U E		x x . x b

Compressor short-cycle protection:

P 5 0	C O M P R E S S O R	S H O R T	
C Y C L E	P R O T E C T I O N		x x m n

Discharge temperature limit:

P 5 1	D I S C H A R G E	T E M P .	
L I M I T			x x x °

Water line frost protection limit:

P 5 2	H 2 O	F R O S T	P R O T .
L I M I T			- x x . x °

Refrigerant frost protection differential:

Gives the freon
frost limit = water
frost limiteau -
this differential

P 5 3	R E F R I G E R A N T	F R O S T	
P R O T .	D I F F .		x x K

HP fault threshold:

P 5 4	H P	F A U L T	T H R E S H O L D
			x x . x b

LP fault threshold:

P 5 5	L P	F A U L T	T H R E S H O L D
			x x . x b

LP slope factor:

P 5 8	L P	S L O P E	
F A C T O R			x . x

Water outlet T slope factor:

P 5 9	W A T E R	O U T L E T	
T . S L O P E	F A C T O R		x . x

LP fault threshold:

P 6 3	M I N .	H P	T H R E S H O L D
			x x x . x b

Parameter locking:

P 9 9	L O C K		N O
P 9 9	L O C K		Y E S

8.6 ADJUSTMENT PARAMETERS menu

To access the ADJUSTMENT PARAMETERS menu, use the + or - buttons to position the cursor on 5 then press **OK**. The display shows the list of control parameters.

Example:

```

P x x   S T A G E
D I F F E R E N T I A L           x x . x K
    
```

Pressing on the + and - buttons scrolls through the parameters two lines at a time.

•To change a value:

Press **OK** to enter the parameter. Use the + or - buttons to increment or decrement the value of the parameter then press **OK** to confirm the changes or **ESC** to cancel.

To return to the main menu, press the **ESC** button repeatedly.

```

5 - A D J U S T M E N T . P A R A M E T E R S
    
```

Language:

```

P 1 0 0   L A N G U A G E           F R A N C A I S
P 1 0 0   L A N G U A G E           E N G L I S H
P 1 0 0   L A N G U A G E           D E U T S C H
P 1 0 0   L A N G U A G E           E S P A Ñ O L
P 1 0 0   L A N G U A G E           N E D E R L A N D S
P 1 0 0   L A N G U A G E           I T A L I A N O
P 1 0 0   L A N G U A G E           P Y C C K
    
```

Control type:

```

P 1 0 3   C O N T R O L   T Y P E           L O C A L
P 1 0 3   C O N T R O L   T Y P E
          R E M O T E   ( B M S ,   e t c . )
    
```

Pump 2 control:

```

P 1 0 8   P U M P   2   C O N T R O L
          F U N C T I O N   ( C T R L )
P 1 0 8   P U M P   2   C O N T R O L
          F U N C T I O N   ( O N / O F F )
    
```

Based either on the control or on the On/Off status of the unit }

Pump 2 'on' time delay:

```

P 1 0 9   P U M P   2   O N
          T I M E   D E L A Y   x x S
    
```

Configurable output:

```

P 1 1 1   P R O G R A M M A B L E   O N / O F F
          O U T P U T   M A X .   P O W E R
    
```

P 1 1 1 P R O G R A M M A B L E O N / O F F
O U T P U T B O I L E R

P 1 1 1 P R O G R A M M A B L E O N / O F F
O U T P U T C O O L I N G / H E A T I N G

Number of electric stages:

P 1 1 2 N O . O F E L E C T R I C
S T A G E S 0

Configurable input:

P 1 1 3 P R O G R A M M A B L E I N P U T
A U X . H E A T E R D I S A B L E D

P 1 1 3 P R O G R A M M A B L E I N P U T
L O A D S H E D A U X . H E A T E R

P 1 1 3 P R O G R A M M A B L E I N P U T
O V E R R I D E A U X . H E A T E R

Enable exchanger frost protection:

P 1 1 5 E X C H F R O S T P R O T E C .
E N A B L E D Y E S

Link with AEROCONNECT controller:

P 1 1 6 L I N K W I T H
A E R O C O N N E C T Y E S

Operating mode:

P 1 1 9 O P E R A T I O N
C O O L I N G

P 1 1 9 O P E R A T I O N
H E A T I N G

P 1 1 9 O P E R A T I O N
H T G / C L G V I A C O N S O L E

P 1 1 9 O P E R A T I O N
C L G / H T G V I A O N / O F F

P 1 1 9 O P E R A T I O N
A U T O C L G / H T G / O U T T E M P .

Number of setpoints:

P 1 2 0 N O . O F S E T P O I N T S
1

P 1 2 0 N O . O F S E T P O I N T S
2 V I A C O N S O L E O R B M S

P 1 2 0 N O . O F S E T P O I N T S
2 V I A O N / O F F I N P U T

P 1 2 0 N O . O F S E T P O I N T S
V I A 4 - 2 0 M A I N P U T

Cooling setpoint 1:

```
P 1 2 1 C O O L I N G S E T P O I N T 1
- x x . x °
```

Cooling setpoint 2:

```
P 1 2 1 C O O L I N G S E T P O I N T 2
- x x . x °
```

Heating setpoint 1:

```
P 1 2 3 H E A T I N G S E T P O I N T 1
- x x . x °
```

Heating setpoint 2:

```
P 1 2 4 H E A T I N G S E T P O I N T 2
- x x . x °
```

Adjustment of the cooling setpoint based on the outdoor temperature:

```
P 1 2 7 C O O L I N G S T P B A S E D
O N ( T e x t ) Y E S

P 1 2 7 C O O L I N G S T P B A S E D
O N ( T e x t ) N O
```

Start of drift in cooling mode:

```
P 1 2 8 D R I F T S T A R T
C O O L I N G x x °
```

End of drift in cooling mode:

```
P 1 2 9 D R I F T E N D
C O O L I N G x x °
```

Maximum setpoint at end of drift in cooling mode:

```
P 1 3 0 M A X S T P A T D R I F T
E N D C O O L I N G x x °
```

Adjustment of the heating setpoint based on outdoor the temperature:

```
P 1 3 1 H E A T I N G S T P B A S E D
O N ( T e x t ) Y E S

P 1 3 1 H E A T I N G S T P B A S E D
O N ( T e x t ) N O
```

Start of drift in heating mode:

```
P 1 3 2 D R I F T S T A R T
H E A T I N G x x °
```

End of drift in heating mode:

```
P 1 3 3 D R I F T E N D
H E A T I N G x x °
```

End of drift setpoint in heating mode:

```
P 1 3 4 M A X S T P A T D R I F T
E N D H E A T I N G x x °
```

Control mode:

P 1 4 1	REGULATION TYPE	
	ON INLET	
P 1 4 1	REGULATION TYPE	
	ON OUTLET	
P 1 4 1	REGULATION TYPE	
	ON OUTLET + COMPENSATION	

Water supply control with compensation by water return

Water loop winter protection:

P 1 4 2	WATER LOOP WINTER PROTECTION	YES
P 1 4 2	WATER LOOP WINTER PROTECTION	NO

•Return and supply control:

Stage differential:

P 1 4 3	STAGE DIFFERENTIAL	x . x K
----------------	--------------------	---------

Interstage differential:

P 1 4 4	INTERSTAGE DIFFERENTIAL	x . x K
----------------	-------------------------	---------

Proportional coefficient:

P 1 4 5	P . COEFFICIENT	x . x
----------------	-----------------	-------

Integral coefficient:

P 1 4 6	I . COEFFICIENT	x . x
----------------	-----------------	-------

Derivative coefficient:

P 1 4 7	D . COEFFICIENT	x . x
----------------	-----------------	-------

Time coefficient:

P 1 4 8	T . COEFFICIENT	x x x S
----------------	-----------------	---------

Control with compensation:

P 1 5 0	COMPENSATION COEFFICIENT	x . x
----------------	--------------------------	-------

P 1 5 1	COMPENSATION TIME	x x x S
----------------	-------------------	---------

Storage control:

P 1 5 4	STORAGE CONTROL	YES
P 1 5 4	STORAGE CONTROL	NO

P 1 5 5 S T O R A G E C T R L
D I F F E R E N T I A L x . x K

•Defrosting:

Temperature at start of defrosting:

P 1 5 7 T E M P E R A T U R E S T A R T
D E F R O S T I N G - x x . x °

Temperature at end of defrosting:

P 1 5 8 T E M P E R A T U R E E N D
D E F R O S T I N G - x x . x °

Frosting type:

P 1 5 9 F R O S T I N G T Y P E
F I X E D T I M E
P 1 5 9 F R O S T I N G T Y P E
O P T I M I S E D

Frosting cycle time:

P 1 6 0 F R O S T I N G T I M E
F I X E D x x m n

Frosting factor:

P 1 6 1 F R O S T I N G
F A C T O R 0 . 3

Correction with respect to the reference outdoor temperature during optimised frosting:

P 1 6 2 C O R R E C T I O N T O R E F
O U T D O O R T E M P 0 . 2

Time delay for turning off the compressors during defrosting:

P 1 6 3 C O M P O F F T I M E D E L A Y
D U R I N G D E F R O S T x x x S

Differential for turning on the fans during defrosting:

P 1 6 4 H P O N D I F F
D E F R O S T I N G x x . x b

Differential for shutting off the fans during defrosting:

P 1 6 5 H P O F F D I F F
D E F R O S T I N G x x . x b

Charge limit function:

P 1 7 1 M A X W A T E R T E M P .
S T A G E 2 L O A D S H E D - x x . x °

Load shedding via ON/OFF input:

P 1 7 5 T Y P E O F L O A D S H E D .
V I A O N / O F F I N P U T A U T O
P 1 7 5 T Y P E O F L O A D S H E D
V I A O N / O F F I N P U T . S E L E C T .

●Fan control:

Number of fan stages:

P 1 8 0 N O . O F H P C T R L
S T A G E S / C I R C U I T X

HP control setpoint:

P 1 8 1 H P C O N T R O L
S E T P O I N T x x . x b

Outdoor air temperature, forced fan operation:

P 1 8 2 O U T . A I R T E M P .
F O R C E D F A N S x x . x °

Fan stage differential:

P 1 8 3 H P C T R L S T A G E
D I F F E R E N T I A L x x . x b

Fan interstage differential:

P 1 8 4 H P C T R L I N T E R S T A G E
D I F F E R E N T I A L x x . x b

●High Pressure control:

Low Noise operation:

P 1 9 1 L O W N O I S E
O P E R A T I O N Y E S
P 1 9 1 L O W N O I S E
O P E R A T I O N N O

Maximum fan speed threshold:

P 1 9 2 M A X . F A N S P E E D
T H R E S H O L D x x . x V

Shifting of HP setpoint during recovery:

P 1 9 3 H P S T P S H I F T
R E C O V E R Y x x . x b

Differential used to reduce power before cutting off the HP:

P 1 9 5 H P D I F F . F O R
P O W E R R E D U C . x . x b

Differential used to return to normal condensing pressure control:

P 1 9 6 H P D I F F . H P R E T U R N
C O N D P R E S S C T R L x . x b

Value at 0 V:

P 1 9 7 O U T P U T L I N K T O P 2 6
V A L U E A T 0 V x x . x b

Value at 10 V:

P 1 9 8 O U T P U T L I N K T O P 2 6
V A L U E A T 1 0 V x x . x b

Outdoor temperature at which the heating elements are turned on:

P 2 2 0 O U T . T E M P E R A T U R E
W I N T E R P R O T E C . - x x . x °

Differential used to shut off these heating elements:

P 2 2 2	OUT . TEMP . DIFF .	
W I N T E R	P R O T E C .	- x x . x °

Minimum air temperature for operation in heating mode:

P 2 2 5	MIN . AIR TEMP . IN	
H E A T I N G	M O D E	- x x °

Maximum air temperature for operation in cooling mode:

P 2 2 5 . 1	MAX . AIR TEMP . IN	
C O O L I N G	M O D E	- x x °

Maximum air temperature for operation in heating mode

P 2 2 5 . 2	MAX . AIR	
T E M P .	I N H E A T I N G	- x x °

Minimum air temperature for operation in cooling mode

P 2 2 5 . 3	MIN . AIR	
T E M P .	I N C O O L I N G	- x x °

Air temperature at which the electric auxiliary heaters or boiler may be turned on:

P 2 2 6	OUT . TEMP .	
A U X I L .	A U T H . O N	- x x °

Authorisation for compressor stages to turn on:

Same when 'No' }	P 2 3 0	S T A G E 1	C I R C U I T 1	
	O N			Y E S
	P 2 3 1	S T A G E 2	C I R C U I T 1	
	O N			Y E S
	P 2 3 2	S T A G E 1	C I R C U I T 2	
	O N			Y E S
	P 2 3 3	S T A G E 2	C I R C U I T 2	
	O N			Y E S

Authorisation for electric stages to turn on:

Same when 'No' }	P 2 3 5	E L E C T R I C	S T A G E 1	
	O N			Y E S
	P 2 3 6	E L E C T R I C	S T A G E 2	
	O N			Y E S
	P 2 3 7	E L E C T R I C	S T A G E 3	
	O N			Y E S
	P 2 3 8	E L E C T R I C	S T A G E 4	
	O N			Y E S

Electronic expansion valve:

P 6 0 1	C I R C U I T 1	
V A L V E	T Y P E	E X 4

P 6 0 2	C I R C U I T 1	
S U P E R H E A T	S T P	6 ° C

P 6 0 3	C I R C U I T 1	
M O P	P O I N T	Y E S

P 6 0 4	C I R C U I T 1	
M O P	V A L U E	1 5 ° C
P 6 0 5	% O P N G C 1 E X V	
S T A R T	A I R C O N	X X X %
P 6 0 6	% O P N G C 1 E X V	
S T A R T	H E A T P U M P	X X X %
P 6 0 7	O P E N I N G T I M E	
S T A R T - U P	C 1	X X S
P 6 0 8	C I R C U I T 1	
S L O W	M O D E	N O
P 6 1 1	C I R C U I T 2	
V A L V E	T Y P E	E X 4
P 6 1 2	C I R C U I T 2	
S U P E R H E A T	S T P	6 ° C
P 6 1 3	C I R C U I T 2	
M O P	P O I N T	Y E S
P 6 1 4	C I R C U I T 2	
M O P	V A L U E	1 5 ° C
P 6 1 5	% O P N G C 2 E X V	
S T A R T	A I R C O N	X X X %
P 6 1 6	% O P N G C 2 E X V	
S T A R T	H E A T P U M P	X X X %
P 6 1 7	O P E N I N G T I M E	
S T A R T - U P	C 2	X X S
P 6 1 8	C I R C U I T 2	
S L O W	M O D E	N O

•Communication:

Control type:

P 1 0 3	C O N T R O L T Y P E	
		L O C A L
P 1 0 3	C O N T R O L T Y P E	
	R E M O T E (B M S , e t c .)	

Communication protocol:

P 7 0 0	C O M M U N I C A T I O N
P R O T O C O L	B U S M O D E

Transmission speed:

P 7 0 1	T R A N S M I S S I O N
S P E E D	4 8 0 0 b a u d s

Parity:

P 7 0 2	P A R I T Y
	W I T H O U T

Number of stop bits:

P 7 0 3	N U M B E R O F S T O P	
B I T S		1

Format of real numbers:

P 7 0 4	S W A P P E D R E A L N U M B E R	
F O R M A T		Y E S

Bus number:

P 7 0 5	B U S N U M B E R	
		0 0 0

•Master/slave configuration:

P 8 0 0	M A S T E R M A C H I N E	
O N L O O P		Y E S

P 8 0 1	B A C K U P	
M A C H I N E		Y E S

P 8 0 2	S W I T C H B A C K U P	
M A C H I N E		Y E S

P 8 0 3	B A C K U P M A C H I N E	
N A M E		S L A V E

P 8 0 4	L O O P C O N T R O L	
T Y P E		P A R A L L E L

P 8 0 5	M A C H I N E	
D I F F E R E N T I A L		x x . x °

P 8 0 6	D I F F E R E N T I A L	
B T W N M A C H I N E S		x x . x °

P 8 0 7	M A X . D I F F .	
A D D I T I O N A L M A C H .		x x °

P 8 0 8	T I M E D E L A Y	
B T W N M A C H I N E S		x x m n x x

P 8 0 9	A U T H O R I S E	
M A C H I N E 1 O N		Y E S

P 8 1 0	A U T H O R I S E	
M A C H I N E 2 O N		Y E S

8.7 OPERATION PARAMETERS menu

To access the OPERATION PARAMETERS menu, use the + or – buttons to position the cursor on 6 then press **OK**. The display shows the list of operation parameters.

Example:

P x x x	E X C H . 1 I N L E T W A T E R	
T E M P .		1 2 . 5 °

Pressing on the + and – buttons scrolls through the parameters two lines at a time. The values of these parameters cannot be changed. To return to the main menu, press the **ESC** button repeatedly.

6 - O P E R A T I O N . P A R A M E T E R S

LED test: used to turn on the console LEDs corresponding to the machine configuration:

P 2 5 0 L E D T E S T

Control setpoint:

P 2 5 1 C O N T R O L
S E T P O I N T x x . x °

Outdoor air temperature:

P 2 5 2 O U T D O O R A I R
T E M P E R A T U R E x x . x °

Water inlet temperature in heat exchanger on circuit 1:

P 2 5 5 E X C H . 1 W A T E R
I N L E T T E M P . x x . x °

Water outlet temperature in heat exchanger on circuit 1:

P 2 5 6 E X C H . 1 W A T E R
O U T L E T T E M P . x x . x °

Hot water temperature at condenser inlet (water-to-water unit):

P 2 5 7 W A T E R T E M P E R A T U R E
C O N D E N S E R I N L E T x x . x °

Hot water temperature at condenser outlet (water-to-water unit):

P 2 5 8 W A T E R T E M P E R A T U R E
C O N D E N S E R O U T L E T x x . x °

Circuit 1 coil temperature:

P 2 5 9 C I R C . 1 C O I L T E M P .
A : - x x . x ° B : - x x . x °
C : - x x . x ° D : - x x . x °

Circuit 1 coil temperature where P14 = 1:

P 2 5 9 C I R C . 1 C O I L T E M P .
- x x . x °

Refrigerant temperature on circuit 1 heat exchanger:

P 2 6 0 E X C H . 1
R E F R . T E M P . - x x . x °

Water temperature measured on manifold (case of two heat exchangers):

P 2 6 1 M A N I F O L D W A T E R
O U T L E T T E M P . - x x . x °

Water outlet temperature on circuit 2 heat exchanger:

P 2 6 2 E X C H . 2 W A T E R
O U T L E T T E M P . - x x . x °

Circuit 2 coil temperature:

P 2 6 3 C I R C . 2 C O I L T E M P .
A : - x x . x ° B : - x x . x °
C : - x x . x ° D : - x x . x °

Refrigerant temperature on circuit 2 heat exchanger:

```

P 2 6 4   E X C H .   2
R E F R .   T E M P .           - x x . x °

```

Ambient temperature of heat exchanger:

```

P 2 6 5   E X C H A N G E R
A M B I E N T   T E M P .           - x x . x °

```

Calculated frosting time, circuit 1:

```

P 2 6 6   C A L C U L A T E D   F R O S T .
T I M E   C I R C U I T   1           x x m n

```

Calculated frosting time, circuit 2:

```

P 2 6 7   C A L C U L A T E D   F R O S T .
T I M E   C I R C U I T   2           x x m n

```

Value of referenced Delta-T for optimised defrosting on circuit 1:

```

P 2 6 8   O P T I   D E F R O S T I N G   C 1
D T R E F = x x . x °           D T D = x x . x °

```

Value of referenced Delta-T for optimised defrosting on circuit 2:

```

P 2 6 9   O P T I   D E F R O S T I N G   C 2
D T R E F = x x . x °           D T D = x x . x °

```

Control time delay:

```

P 2 7 0   C O N T R O L L E R
T I M E   D E L A Y           x x x s

```

Heating mode runtime (in hours):

```

P 2 8 5   H E A T I N G   M O D E
R U N T I M E           x x x x x x H

```

Cooling mode runtime (in hours):

```

P 2 8 6   C O O L I N G   M O D E
R U N T I M E           x x x x x x H

```

Pump 1 runtime (in hours):

```

P 2 8 7   P U M P   1
R U N T I M E           x x x x x x H

```

Pump 2 runtime (in hours):

```

P 2 8 8   P U M P   2
R U N T I M E           x x x x x x H

```

Number of times P99 set to 'No':

```

P 2 8 9   N O .   T I M E S   P 9 9
S E T   T O   ' N O '           x x x x x x

```

Number of water flow cut-offs in 1 hour:

```

P 2 9 0   N O .   W A T E R   F L O W
C U T S           I N   1 H   x

```

●Circuit 1 information:

Circuit 1 High Pressure value:

P 3 0 0 H P 1 P R E S S U R E x x . x b

Value of calculated High Pressure control setpoint:

P 3 0 0 . 1 H P 1 C O N T R O L S E T P O I N T x x . x b

Circuit 1 condensing temperature value resulting from the previous pressure level and the refrigerant selected:

P 3 0 1 C I R C U I T 1 C O N D . T E M P . x x . x °

Stage 1, circuit 1 discharge temperature value:

P 3 0 2 . 1 D I S C H A R G E T E M P E R A T U R E 1 x x x °

Stage 2, circuit 1 discharge temperature value:

P 3 0 2 . 2 D I S C H A R G E T E M P E R A T U R E 2 x x x °

Desuperheat temperature on discharge 1 (= discharge temperature – condensation dew point temperature)

P 3 0 3 . 1 D I S C H A R G E 1 D E S U P E R H E A T x x . x °

Desuperheat temperature on discharge 2 (= discharge temperature – condensation dew point temperature)

P 3 0 3 . 2 D I S C H A R G E 2 D E S U P E R H E A T x x . x °

Circuit 1 Low Pressure value:

P 3 0 4 L P 1 P R E S S U R E x x . x b

Circuit 1 evaporating temperature value resulting from the previous pressure value and the refrigerant selected:

P 3 0 5 C I R C U I T 1 E V A P . T E M P . x x x . x °

Circuit 1 suction temperature value:

P 3 0 6 C I R C U I T 1 S U C T I O N T E M P . x x x . x °

Circuit 1 superheat temperature:

P 3 0 7 C I R C U I T 1 S U P E R H E A T x x x . x °

Number of cut-offs caused by a High Pressure fault on circuit 1 in 24 hours:

P 3 0 8 N O . H P 1 C U T S I N 2 4 H O U R S x

Number of cut-offs caused by a Low Pressure fault on circuit 1 in 24 hours:

P 3 0 9 N O . L P 1 C U T S I N 2 4 H O U R S x

Number of times stage 1 on circuit 1 turned on:

P 3 1 0	N O .	S T A R T S							
S T A G E 1	C I R C U I T	1						x	x x x x x

Runtime of stage 1 on circuit 1:

P 3 1 1	S T A G E 1	C I R C U I T 1							
R U N T I M E									x x x x x H

Short-cycle protection on stage 1 of circuit 1:

P 3 1 2	S T A G E 1	C I R C U I T 1							
S C P									x x m n x x S

Number of times stage 2 on circuit 1 turned on:

P 3 1 3	N O .	S T A R T S							
S T A G E 2	C I R C U I T	1							x x x x x

Runtime of stage 2 on circuit 1:

P 3 1 4	S T A G E 2	C I R C U I T 1							
R U N T I M E									x x x x x H

Short-cycle protection on stage 2 of circuit 1:

P 3 1 5	S T A G E 2 ,	C I R C U I T 1							
S C P									x x m n x x S

Number of cut-offs caused by frost protection on circuit 1 water line in 24 hours:

P 3 2 2	N O .	H 2 O	F R O S T	P R O T					
C U T S	C I R C	1							x

Number of cut-offs caused by frost protection on circuit 1 refrigerant line in 24 hours:

P 3 2 3	N O	F R O S T	P R O T	C U T S					
C 1	R E F R I G								x

Number of cut-offs caused by discharge temperature on stage 1 in 24 hours:

P 3 2 4 . 1	N O .	D I S C H A R G E	1						
C U T S	I N	2 4 H							X

Number of cut-offs caused by discharge temperature on stage 2 in 24 hours:

P 3 2 4 . 2	N O .	D I S C H A R G E	2						
C U T S	I N	2 4 H							X

Percentage of opening for the electronic expansion valve on circuit 1:

P 3 2 5	C 1	E X V							
O P E N I N G		%							X X X %

Circuit 1 liquid temperature:

P 3 2 6	C I R C U I T	1							
L I Q U I D	T E M P .								x x . x °

Circuit 1 subcooling value:

P 3 2 7	C I R C U I T	1							
S U B C O O L I N G									x x . x °

Number of cut-offs caused by circuit 1 expansion valve fault:

P 3 2 8 N O . C U T O F F S C A U S E D B Y C 1 E X V I N 2 4 H X

●Circuit 2 information:

Circuit 2 High Pressure value:

P 3 3 0 H P 2 P R E S S U R E x x . x b

Value of calculated HP control setpoint:

P 3 3 0 . 1 H P 2 C O N T R O L S E T P O I N T x x . x b

Circuit 2 condensing temperature value resulting from the previous pressure value and the refrigerant selected:

P 3 3 1 C I R C U I T 2 C O N D . T E M P . x x . x °

Stage 1, circuit 2 discharge temperature value:

P 3 3 2 . 1 D I S C H A R G E T E M P E R A T U R E 2 x x x °

P 3 3 2 . 1 D I S C H A R G E T E M P E R A T U R E 3 x x x °

Stage 2, circuit 2 discharge temperature value:

P 3 3 2 . 2 D I S C H A R G E T E M P E R A T U R E 4 x x x °

Desuperheat temperature on circuit 2 stage 1 discharge (= discharge temperature – condensation dew point temperature)

P 3 3 3 . 1 D I S C H A R G E 2 D E S U P E R H E A T x x . x °

P 3 3 3 . 1 D I S C H A R G E 3 D E S U P E R H E A T x x . x °

Desuperheat temperature on circuit 2 stage 2 discharge (= discharge temperature – condensation dew point temperature)

P 3 3 3 . 2 D I S C H A R G E 4 D E S U P E R H E A T x x . x °

Circuit 2 Low Pressure value:

P 3 3 4 L P 2 P R E S S U R E x x . x b

Circuit 2 evaporating temperature value resulting from the previous pressure value and the refrigerant selected:

P 3 3 5 C I R C U I T 2 E V A P . T E M P . x x x . x °

Circuit 2 suction temperature value:

P 3 3 6 C I R C U I T 2 S U C T I O N T E M P . x x x . x °

Circuit 2 superheat temperature:

P 3 3 7 C I R C U I T 2 S U P E R H E A T x x x . x °

Number of cut-offs caused by a High Pressure fault on circuit 2 in 24 hours:

P 3 3 8	N O .	H P 2	C U T S	
I N	2 4	H O U R S		x

Number of cut-offs caused by a Low Pressure fault on circuit 2 in 24 hours:

P 3 3 9	N O .	L P 2	C U T S	
I N	2 4	H O U R S		x

Number of times stage 1 on circuit 2 turned on:

P 3 4 0	N O .	S T A R T S		
S T A G E 1	C I R C U I T	2		x x x x x

Runtime of stage 1 on circuit 2:

P 3 4 1	S T A G E 1	C I R C U I T 2		
R U N T I M E				x x x x x H

Short-cycle protection on stage 1 of circuit 2:

P 3 4 2	S T A G E 1 ,	C I R C U I T 2		
S C P				x x m n x x S

Number of times stage 2 on circuit 2 turned on:

P 3 4 3	N O .	S T A R T S		
S T A G E 2	C I R C U I T	2		x x x x x

Runtime of stage 2 on circuit 2:

P 3 4 4	S T A G E 2	C I R C U I T 2		
R U N T I M E				x x x x x H

Short-cycle protection on stage 2 of circuit 2:

P 3 4 5	S T A G E 2 ,	C I R C U I T 2		
S C P				x x m n x x S

Number of cut-offs caused by frost protection on circuit 2 water line in 24 hours:

P 3 5 2	N O .	H 2 O	F R O S T	P R O T
C U T S	C I R C	2		x

Number of cut-offs caused by frost protection on circuit 2 refrigerant line in 24 hours:

P 3 5 3	N O	F R O S T	P R O T	C U T S
C 2	R E F R I G			x

Number of cut-offs caused by discharge temperature on stage 1 of circuit 2 in 24 hours:

P 3 5 4 . 1	N O .	D I S C H A R G E	2	
C U T S	I N	2 4 H		X

P 3 5 4 . 1	N O .	D I S C H A R G E	3	
C U T S	I N	2 4 H		X

Number of cut-offs caused by discharge temperature on stage 2 of circuit 2 in 24 hours:

P 3 5 4 . 2	N O .	D I S C H A R G E	4	
C U T S	I N	2 4 H		X

Percentage of opening for the electronic expansion valve on circuit 2:

P 3 5 5	C 2	E X V		
O P E N I N G	%			X X X %

Circuit 2 liquid temperature:

P 3 5 6	C I R C U I T 2	
L I Q U I D	T E M P .	x x . x °

Circuit 2 subcooling value:

P 3 5 7	C I R C U I T 2	
S U B C O O L I N G		x x . x °

Number of cut-offs caused by circuit 2 expansion valve fault:

P 3 5 8	N O . C U T O F F S	C A U S E D
B Y C 2	E X V I N 2 4 H	X

•Inputs:

State of unit automatic operation control input:

P 4 0 0	A U T O . O P E R A T I O N	
C T R L	I N P U T	O P E N

State of setpoint selection input (1 or 2):

P 4 0 2	S E T P O I N T	S E L E C T I O N
I N P U T		1

State of water flow fault input:

P 4 0 3	W A T E R F L O W	
F A U L T	I N P U T	O P E N

} Same when 'Closed'

State of fan fault input:

P 4 0 4	F A N F A U L T	
I N P U T		O P E N

State of operating mode selection input:

P 4 0 5	H E A T I N G / C O O L I N G	
M O D E	I N P U T	O P E N

State of phase controller fault input:

P 4 0 6	P H A S E C O N T R O L L E R	
F A U L T	I N P U T	O P E N

State of recovery operating mode selection input:

P 4 0 7	R E C O V E R Y O P E R A T I O N	
I N P U T		O P E N

State of fault input 1 on ADDitional board 1 for units equipped with auxiliary electric heaters P22 = Yes:

P 4 0 8	F A U L T I N P U T 1	
E L E C T R I C	A D D 1	O P E N

State of fault input 2 on ADDitional board 1 for units equipped with auxiliary electric heaters P22 = Yes:

P 4 0 9	F A U L T I N P U T 2	
E L E C T R I C	A D D 1	O P E N

State of configurable input on ADDitional board 1 for units equipped with auxiliary electric heaters P22 = Yes and P113 = load shedding or forced:

P 4 1 0	C O N F I G U R A B L E I N P U T	
E L E C T R I C	A D D 1	O P E N

State of stage 1 override input:

P 4 1 4	S T A G E	1	O V E R R I D E
I N P U T			O P E N

State of stage 2 override input:

P 4 1 5	S T A G E	2	O V E R R I D E
I N P U T			O P E N

State of stage 3 override input:

P 4 1 6	S T A G E	3	O V E R R I D E
I N P U T			O P E N

State of stage 4 override input:

P 4 1 7	S T A G E	4	O V E R R I D E
I N P U T			O P E N

State of manual High Pressure switch input on circuit 1:

P 4 1 8	M A N U A L	H P 1	
F A U L T	I N P U T		O P E N

State of stage 1, circuit 1 fault input:

P 4 1 9	S T A G E 1	C I R C U I T 1	
F A U L T	I N P U T		O P E N

State of stage 2, circuit 1 fault input:

P 4 2 0	S T A G E 2	C I R C U I T 1	
F A U L T	I N P U T		O P E N

State of manual High Pressure switch input on circuit 2:

P 4 2 2	M A N U A L	H P 2	
F A U L T	I N P U T		O P E N

State of stage 1, circuit 2 fault input:

P 4 2 3	S T A G E 1	C I R C U I T 2	
F A U L T	I N P U T		O P E N

State of stage 2, circuit 2 fault input:

P 4 2 4	S T A G E 2	C I R C U I T 2	
F A U L T	I N P U T		O P E N

State of fault input for electronic expansion valve on circuit 1:

P 4 2 5	C I R C 1	E X V	
F A U L T	I N P U T		O P E N

State of fault input for electronic expansion valve on circuit 2:

P 4 2 6	C I R C 2	E X V	
F A U L T	I N P U T		O P E N

•Outputs:

Pump 1 contact:

P 4 3 0	P U M P	1	O U T P U T
			O N

Pump 2 contact:

P 4 3 1 P U M P 2 O U T P U T
O N

Circuit 1 Y/C contact:

P 4 3 2 C I R C U I T 1
Y / C O U T P U T O N

Circuit 2 Y/C contact:

P 4 3 3 C I R C U I T 2
Y / C O U T P U T O N

Heat trace cable contact:

P 4 3 5 H E A T T R A C E
O U T P U T O N

Heater contact:

P 4 3 6 H E A T E R
O U T P U T O N

Contact for frost protection heat trace cable (recovery option):

P 4 3 7 R E C O V E R Y F R O S T
P R O T . O U T P U T O N

Configurable output contact:

P 4 3 8 M A X I M U M
P O W E R O U T P U T O N

P 4 3 9 B O I L E R O U T P U T
O F F

P 4 4 0 C L G / H T G R E P O R T
O U T P U T O F F

Control contact for fan stages if P180 = 1:

P 4 4 1 F A N
O F F
O N
H S
L S

} HS (High Speed) =
high temperature
LS = Low Speed

Control contact for fan stages P180 = 2 (2 stages) and P3 = 1 (1 circuit)

P 4 4 1 H P C O N T R O L
S T A G E 1 O U T P U T O N

P 4 4 2 H P C O N T R O L
S T A G E 2 O U T P U T O N

Control contact for fan stages P180 = 2 (2 stages) and P3 = 2 (2 circuits):

P 4 4 1 H P C O N T R O L
S T A G E 1 C 1 O U T P U T O N

P 4 4 2 H P C O N T R O L
S T A G E 2 C 1 O U T P U T O N

P 4 4 3 H P C O N T R O L
S T A G E 1 C 2 O U T P U T O N

P 4 4 4 H P C O N T R O L
S T A G E 2 C 2 O U T P U T O N

Control contact for fan stages P180 = 3 (3 stages) and P3 = 2 (2 circuits) and P11 = split
P441, P442, P443 and P444 same as P180 = 2 (2 stages) and P3 = 2 (2 circuits):

P 4 4 5	H P	C O N T R O L	
S T A G E	3	C 1 O U T P U T	O N

P 4 4 6	H P	C O N T R O L	
S T A G E	3	C 2 O U T P U T	O N

Control contact for fan stages P180 = 3 (3 stages) and P3 = 2 (2 circuits) and P11 = mixed
P441, P442, P443 and P444 same as P180 = 2 (2 stages) and P3 = 2 (2 circuits):

P 4 4 5	H P	C O N T R O L	
C O M S T A G E	1	O U T P U T	O N

P 4 4 6	H P	C O N T R O L	
C O M S T A G E	3	O U T P U T	O N

Speed control information (intertwined coil):

P 4 4 7	H P	S T A G E	1
D R I V I N G	V O L T A G E		X X . X V

Speed control information (split or mixed coil), stage 1, circuit 1:

P 4 4 8	H P	S T A G E	1	C 1
D R I V I N G	V O L T A G E		X X . X V	

Speed control information (split or mixed coil), stage 1, circuit 2:

P 4 4 9	H P	S T A G E	1	C 2
D R I V I N G	V O L T A G E		X X . X V	

Speed control information (mixed coil), common stage 1:

P 4 5 0	H P	C O M S T A G E	1
D R I V I N G	V O L T A G E		X X . X V

Circuit 1 balance valve output contact:

P 4 5 1	C 1	B A L A N C E	V A L V E
O U T P U T			O N

Circuit 2 balance valve output contact:

P 4 5 2	C 2	B A L A N C E	V A L V E
O U T P U T			O N

Electric stage output:

P 5 3 x	E L E C T R I C	S T A G E	x
O U T P U T			O N

Air blade information:

P 5 3 5	A I R	B L A D E	
O P E N I N G	%		x x x %

Version:

P 5 5 5	C P U	V E R S I O N	N O .
			x x - x x

P 5 5 6	C O N S O L E	V E R S I O N	
N O .			x x - x x

P 5 5 7	C I R C U I T	2	B O A R D
V E R S I O N	N O .		x x - x x

P 5 5 8	R E V E R S A L	B O A R D	
V E R S I O N	N O .		x x - x x

} Stages 1 to 4

```

P 5 5 9   A U X .   B O A R D
V E R S I O N   N O .               x x - x x

```

Version number of circuit 1 electronic expansion valve:

```

P 5 6 0   C I R 1   E X V   V E R S I O N
N O .   X X . Y Y   V C M   X X . Y Y

```

Version number of circuit 2 electronic expansion valve:

```

P 5 6 1   C I R 2   E X V   V E R S I O N
N O .   X X . Y Y   V C M   X X . Y Y

```

“SO” order number:

```

P 5 7 0   S O   O R D E R
N U M B E R               X X X X X X X X

```

MO number:

```

P 5 7 1   M O   N U M B E R
N U M B E R               X X X X X X X X

```

Machine identification name:

```

P 5 7 2   M A C H I N E   L O C A T I O N
X X X X X X X X X X X X X X X X X X X X

```

Machine identification number:

```

P 5 7 3   M A C H I N E   N U M B E R
N U M B E R               X X X X X X X X

```

8.8 FAULT MEMORY menu

This menu records the last 20 faults on the machine and the associated values measured at the time the faults occurred.

To enter the FAULT MEMORY menu, use the + or - buttons to position the cursor on 7 then press **OK**.

The list of faults appears on the display. Press the + or - buttons to scroll through the faults.

●Accessing the fault memory:

To access measured values when a fault occurred, press **OK**.

⚠ **Measured values cannot be accessed in the event of a mains power failure.**

Press the + or - buttons to scroll through the faults line by line. To go back to the main menu, press the button **ESC** until the menu appears.

Below is the list of messages that appear in the fault memory regardless of the fault type (main circuit fault, main unit fault, temporary fault).

```

x - M A I N S   P O W E R   F A I L U R E
x - P H A S E   C O N T R O L L E R
x - W A T E R   F L O W   R A T E
x - W A T E R   F R O S T   P R O T .   x
x - R E F R .   F R O S T   P R O T .   X
x - C P   D E L T A   P
x - C O M P   D R I V E R
x - C I R C U I T x   H P
x - M A N U A L   H P x
x - C I R C U I T x   L P
x - M O T O R   S T A G E x   C I R x
x - M I N   S U P E R H E A T   C X
x - M A X   S U P E R H E A T   C X
x - R E F . T .   x
x - M I N .   T E M P . / A I R
x - M A X .   T E M P . / A I R
x - F A N
x - E X C H .   H 2 O   I N . S E N S O R
x - E X C H . x   H 2 O   O U T . S E N S .
x - O U T . T E M P .   S E N S O R
x - E X C H . x   F R O S   P R O T . S E N S O

```

} On refrigerant

```

x - CONDENSER IN SENSOR
x - CONDENSER OUT SENSOR
x - CIR x COIL A SENSOR
x - DISCH. SENSOR x
x - MANIF. H2O SENSOR
x - EXCH. AMB. SENSOR
x - SUCTION SENSOR
x - LP SENSOR x
x - HP SENSOR x
x - PUMP X
x - PUMPS 1 AND 2
x - SELF-ADJ CTRL
x - CIRCUIT x DEFROST
x - CX EXP. VALVE
x - EXP. VALVE X LINK
x - EXCH. FROST PROT. x
FAULT MEMORY EMPTY

```

Reading for saving faults to memory:

•**Reading if a circuit fault occurs:** information on circuit that cut off

```

HPX : x x x . x b TCOND : + x x . x ° ↑
LPx : x x x . x b TEVAP : + x x . x °
SUCTION T. x : + x x . x °
SUPERHEAT x : x x . x ° ↓

DIS.T1 : x x x ° DIS.T2 : x x x ° ↑
WATER INLET : - x x . x °
WATER OUTLET : - x x . x °
OUTDOOR T. : - x x . x ° ↓

REFRIG. T. x + x x . x ° ↑
HOT WATER T. - x x . x

```

•**if a unit fault occurs:**

```

OUTDOOR T. : - x x . x ° ↑
CTRL SETPOINT : - x x . x °
WATER INLET : - x x . x °
MAN. WATER OUT : x x . x ° ↓
HOT WATER T. - x x . x ° ↑

```

Manifold water outlets (if two circuits) or water outlet 1 (if one circuit)

8.9 TEST MODE menu

TEST MODE is used to shorten time delays and eliminate limits (but keep the protections on).

The other menus (measured values, parameters, fault memory, etc.) can be accessed while in test mode.

When test mode is on for a circuit, the Voltage LED flashes quickly (the same LED on the remote control console flashes).

To turn on test mode:

➤ Via menu 8.

```

TEST MODE YES
TEST MODE NO

```

Select YES or NO with the + and – buttons. Press **OK** to confirm your choice.

To turn off test mode:

➤ Select NO in the submenu of menu 8 or wait 1 hour for test mode to turn off (NO) automatically.

Test mode remains on for 1 hour.

9 MANAGEMENT OF THE ON/OFF INPUTS

9.1 Automatic machine operation control

This control allows customers to remotely prevent the machine from operating.

- The On/Off LED flashes when this control is on.
- Message on display: SHUT OFF BY MACHINE AUTO CONTROL

Contact state: closed or connected by a jumper (automatic machine operation control = Yes)

9.2 Load shedding control

The load shedding controls on the main board are used to turn off the stages on circuit 1.

The load shedding controls on the main board are used to turn off the stages on circuit 2.

The stages to be shut off are selected by:

- Balancing the runtimes (P175 = Automatic) and the number of closed inputs. Associated message: "NO. STAGES TO BE SHUT OFF".

The controller turns off the stages that have been running the longest.

- Or they can be shut off selectively (P175 = Selective): Input 1 on circuit 1 turns off stage 1 on circuit 1. Input 2 on circuit 1 turns off stage 2 on circuit 1. Input 1 on circuit 2 turns off stage 1 on circuit 2. Input 2 on circuit 2 turns off stage 2 on circuit 2, and the following

9.3 Water flow switch

The information is sent to an open on/off input on the water flow switch.

9.3.1 Management for water-to-water units in cooling mode, air-to-water units and reversible air-to-water units

- The water flow switch is read 10 second after pump 1 or 2 is authorised to turn on if P25 = 2 and while at one of the pumps is running.

The contact must remain open for at least 3 seconds in order to detect a fault.

•If ≤ 3 shutdowns occur in 1 hour

➤ If a fault occurs:

- Pump shut off, compressor and electric stages shut off
- 1-minute time delay (10 seconds in test mode).
- Saved in fault memory
- Machine fault output not active

➤ Display:

```
W A T E R   F L O W   F A U L T
X   C U T ( S )   I N   1 H
```

➤ Resetting: The fault is automatically acknowledged after the 1-minute time delay.

•If > 3 shutdowns occur in 1 hour

➤ If a fault occurs:

- Pumps shut off, compressor and electric stages shut off
- Saved in fault memory
- Machine fault output on

➤ Display:

```
      M A C H I N E   O F F
W A T E R   F L O W   F A U L T
```

➤ Resetting: Press the **Reset** button.

•If reversible air-to-water + boiler (P111 = boiler)

A) If P27 = Yes (pump controlled by boiler operation):

- If a flow switch fault occurs on the heat pump, the boiler is authorised to turn on.

B) If P27 = No (pump controlled only by on/off):

- If a flow switch fault occurs on the heat pump, the boiler is shut off.

9.3.2 Management for water-to-water units in heating mode

A time delay is necessary to manage this fault.

This time delay is:

- Determined by P109 if P108 = depending on control mode
- 10 seconds if P108 = depending on On/Off.

The water flow switch is read after this time delay, after pump 2 is turned on and while pump 2 is running.

•If ≤ 3 stops in 1 hour

➤ If a fault occurs:

- Pump 2 is shut off
- Thermodynamic stages shut off; auxiliary heaters may remain on
- Saved in fault memory
- Fault output off
- General fault LED on console lit steady

➤ Display:

```
W A T E R   F L O W   F A U L T
X   C U T ( S )   I N   1 H
```

➤ Resetting: The fault disappears automatically after 1 minute

message appears: "STAGE x CIRCUIT x TURNED OFF".

State of on/off contact: open at rest

These stages can also be shut off via the Modbus protocol (bits 515 to 518). Refer to the communication protocol section at the end of these instructions.

- If P175 = Selective, OR is placed between the on/off inputs and the information from the bus.

- If P175 = Automatic, the compressors will be shut off by the greatest number of inputs between the on/off inputs and the bus.

Load shedding is cancelled if no information is sent by the bus for more than 6 hours.

Changing the fault management mode resets the number of water flow faults.

- If a water flow fault occurs during the 1-minute circulation delay (after the last control stage), it will not be managed as a fault but the pump will be shut off.

- Water flow fault relay on optional board in Off position

- General fault LED on console flashes

- Number of faults over a 1-hour period managed.

- Water flow fault relay on optional board in On position

- General fault LED on console lit steady

- Number of faults over a 1-hour period managed.

- If a water flow fault occurs during the 1-minute circulation delay (after the last control stage), it will not be managed as a fault but the pump will be shut off.

- Time delay increased by 10 seconds before water flow fault read

- The time delay value obtained is stored in memory so that it can be applied the next time the pump is turned on.

- The increased time delay is reset if P109 is changed.

•If ≥ 3 stops in 1 hour

- If a fault occurs:
 - Pump 2 is shut off
 - Thermodynamic stages shut off; auxiliary heaters may remain on
 - Saved in fault memory
 - Fault output on

- General fault LED on console flashes
- The time delay value obtained is stored in memory so that it can be applied the next time the pump is turned on.
- The increased time delay is reset if P109 is changed.

➢ Display

```

M A C H I N E   O F F
W A T E R     F L O W   F A U L T

```

➢ Resetting: Press **Reset**

9.4 Fan fault (circuits 1 and 2)

Fan faults are managed in series. As a result, there is only one fan fault input. Faults are read on terminals 5-6 of terminal block J6.

When P121 = Yes or P10 = Pressure, this input should not be read until 10 seconds after the unit is turned on and IS NOT TAKEN INTO ACCOUNT WHEN THE UNIT IS SHUT OFF.

•If P10 ≠ centrifugal:

- If a fault occurs:
 - Machine and fans shut off by HP safety.
 - Fault saved to fault memory
 - Fan fault relay on relay board in On position

- General fault LED on console flashes
- Fault acknowledged automatically when input closed

•Si P10 = centrifugal:

- If a fault occurs:
 - Machine shut off because fan shut off
 - Fault saved to fault memory
 - General fault relay on relay board in On position

- General fault LED on console lit steady
- Fault acknowledged manually

➢ Display:

```

M A C H I N E   S T A T U S
F A N     F A U L T

```

Saved in fault memory

```

x - F A N

```

➢ Resetting:

When the input is closed the fault is acknowledged automatically
Special case: a fan fault will turn off units in the LJA range (air-to-

water and centrifugal fan).

9.5 Expansion valve fault

•If P42 = ALCO

This configuration corresponds to using the electronic expansion valve with the Alco driver module and display.
Only fault feedback signals from the valve are managed in this case.
The fault signal contact on the electronic expansion valve on

circuit 1 must be wired to terminals 5-6 on terminal block J5 on the motherboard. The contact on the valve on circuit 2 must be wired to terminals 5-6 on terminal block J2 on ADDitional board 2 for circuit 2.

➢ Operation:

Corresponding circuit shut off when its input opens.

•If < 3 shutdowns occur in 24 hours

- If a fault occurs:
 - Corresponding circuit shut off
 - Fault output on
 - Saved in fault memory

- Circuit fault LED on console flashes
- Number of faults over a 24-hour period managed.

➢ Display:

```

F A U L T   O N   E X V   X
X   C U T S   I N   2 4 H

```

• If ≥ 3 shutdowns occur in 24 hours

- If a fault occurs:
 - Corresponding circuit shut off
 - Fault output on
 - Saved in fault memory

- Circuit fault LED on console lit steady
- Number of faults over a 24-hour period managed.

➢ Display:

```

C I R C U I T   X   O F F
E X P .   V A L V E   F A U L T

```

➤ Resetting:

If the number of faults in 24 hours < 3: The fault is automatically acknowledged after 120 seconds and the fault input is closed.

Reset on the console and by closing the fault input.

If the number of faults in 24 hours ≥ 3: Acknowledge by pressing

➤ Fault memory:

F A U L T O N E X V C X

•If P42 = CIAT (bus link)

Expansion valve actuator and expansion valve board protection:

If any of these four faults is detected on the corresponding refrigerating circuit, the circuit is shut off and the fault is reported.

The circuit may restart when the fault disappears.

- Link fault in machine status

B O A R D L I N K F A U L T
C I R C U I T 1 E X V

- Link fault in fault memory

- E X P A N S I O N V A L V E 1 L I N K

EXV actuator fault in machine status

A C T U A T O R F A U L T
C I R C U I T 1 E X V

EXV actuator fault in fault memory

- E X V 1 A C T U A T O R

Expansion valve VCM board fault

C I R C U I T X O F F
E X P . V A L V E F A U L T

F A U L T O N E X V X
X C U T S I N 2 4 H

9.6 Phase controller fault

The phase controller protects the entire machine. It must be wired to terminals 7-8 on terminal block J5 on the motherboard.

The machine is shut off when a fault occurs on the phase controller (contact opens).

➤ Fault message:

M A C H I N E O F F
P H A S E C O N T R O L L E R F A U L T

➤ If a fault occurs:

- Fault saved in fault memory
- Relay in On position

- Phase control fault relay on relay board in On position
- General fault LED on console lit steady

➤ Resetting:

The opening of the input starts a 2-minute time delay. The fault is acknowledged at the end of this period provided the contact is closed.

The input is not read during this time delay.

➤ Message in fault memory:

X - P H A S E C O N T R O L L E R

9.7 Pump fault

Pump faults are automatically reset. They disappear when acknowledged on the circuit breakers.

•If P25 = 0:

No pumps supplied by CIAT. Only pump 1 fault is managed in the same way if P25 = 1.

If a pump fault occurs after the last control stage is shut off but before the pump is shut off (1 minute after), the water flow fault is not managed. Instead, the pump is shut off.

•If P25 = 1:

Only one pump supplied.

If the pump fault is detected, the unit is shut off and the following message appears:

M A C H I N E O F F
P U M P 1 F A U L T

- Compressor and electric stages shut off
- Saved in fault memory
- Machine fault output on
- Pump 1 fault relay on optional board in On position
- General fault LED on console lit steady

•If P25 = 2 then P2 = air-to-water or reversible air-to-water: two pumps supplied

A) If a fault occurs on the pump that is on, the unit is shut off then turned back on with the other pump operating. A pump fault is reported.

P U M P X F A U L T
B A C K U P P U M P O N

- Saved in fault memory
- Machine fault output on
- Pump 1 fault relay on optional board in On position
- General fault LED on console flashes

B) If a fault occurs on the second pump as well, the unit is shut off and the following message appears:

M A C H I N E O F F
P U M P 1 A N D 2 F A U L T

- Saved in fault memory
- Machine fault output on
- Pump 1 fault relay on optional board in On position
- Pump 2 fault relay on optional board in On position
- General fault LED on console lit steady

C) If the machine is turned on:

- The available pump (i.e. without a fault) is turned on and the faulty pump is reported.

9.8 Compressor protection

➤ Operation:

Information is received by the following open inputs:

- Terminals 1-2 on terminal block J5 on motherboard: Stage 1, circuit 1
- Terminals 2-3 on terminal block J5 on motherboard: Stage 2, circuit 1
- Terminals 1-2 on terminal block J2 on circuit 2 ADD2 board:
- Stage 1, circuit 2
- Terminals 2-3 on terminal block J2 on circuit 2 ADD2 board: Stage 2, circuit 2

These inputs are read 10 seconds after a mains power failure (slowness of switch INT69 causing a fault). They must be open for more than 5 seconds for the fault to be taken into account.

➤ Main circuit fault:

- Corresponding circuit shut off; fault displayed on LCD
- Circuit fault LED lit steady
- Fault stored in memory in case of a mains power failure
- Fault saved in fault memory
- Relay in On position
- Stage x fault relay on relay board in On position

This fault must be acknowledged manually and the motor fault must disappear (closed).

➤ Display:

M O T O R F A U L T
S T A G E x C I R C U I T x

Saved in fault memory

x - M O T O R S T A G E x C I R x

➤ Resetting: Press **Reset**

9.9 Manual HP pressure switch fault on circuit 1 or 2

➤ Operation:

These two inputs monitor the status of the HP pressure switches on each refrigerating circuit.

They are associated with the operation of their respective circuits. They are read 3 seconds after a stage on the circuit turns on.

➤ If a fault occurs:

- Corresponding circuit shut off.
- General fault output on
- Circuit x HP fault relay on optional board in On position
- Circuit LED on console lit steady.

➤ Display:

C I R C U I T X O F F
M A N U A L H P F A U L T

Saved in fault memory

x - M A N U A L H P x

➤ Resetting:

Reset the HP switch manually then reset the fault by pressing **Reset**.

9.10 Setpoint selection via on/off input

If the number of setpoints = 2 with selection via on/off input (the on/off input corresponds to terminals 4-6 on terminal block J6 on the motherboard).

•In cooling mode:

- If the setpoint is not adjusted based on the outdoor temperature or there is a fault on the outdoor temperature sensor, the control setpoint = P121 if the on/off input is open or P122 if the on/off input is closed.

- If the setpoint is adjusted based on the outdoor temperature and there are no faults on the outdoor sensor:
The setpoint is calculated using P121 if the on/off input is open. If the input is closed, the setpoint is calculated using P122.


• In heating mode:

- If the setpoint is not adjusted based on the outdoor temperature or there is a fault on the outdoor temperature sensor, the control setpoint = P123 if the on/off input is open or P124 if the on/off input is closed.

- If the setpoint is adjusted based on the outdoor temperature and there are no faults on the outdoor sensor:
The setpoint is calculated using P123 if the on/off input is open. If the input is closed, the setpoint is calculated using P124.

9.11 Variable setpoint via 4-20 mA input

•In heating mode:



- Displayed if P120 = 3 and in HEATING mode:

P 1 2 5 . 2	S T P	F O R	4 m A
H E A T I N G		- X X . X °	


P 1 2 6 . 2	S T P	F O R	2 0 m A
H E A T I N G		- x x . x °	

If setpoint adjustment based on outdoor temperature = No or there is an outdoor sensor fault → Control setpoint = result of diagram 1

The result of diagram 1 is taken as the setpoint (P123 or P124).
If P120 is set to '3', P131 automatically switches to 'No'.
- To reverse the direction of the slope, simply set P125.2 to > P126.2 with a minimum difference of 5 K.

If the setpoint is adjusted based on the outdoor temperature = Yes and there are no faults on the outdoor sensor:
The derived setpoint is calculated using the outdoor temperature.

• In cooling mode:



Displayed if P120 = 3 and in cooling mode:

P 1 2 5 . 1	S T P	F O R	4 m A
C O O L I N G		- x x . x °	

P 1 2 6 . 1	S T P	F O R	2 0 m A
C O O L I N G		- x x . x °	

If setpoint adjustment based on outdoor temperature = No or there is an outdoor sensor fault → Control setpoint = result of diagram 2
If setpoint adjustment based on outdoor temperature = Yes and there are no faults on the outdoor sensor → The derived setpoint is calculated using the outdoor temperature . The result of

diagram 2 is taken as the setpoint (P121 or P122).
If P120 is set to '3', P127 automatically switches to 'No'
- To reverse the direction of the slope, simply set P125.1 to > P126.1 with a minimum difference of 5 K

IMPORTANT NOTE ABOUT THIS FUNCTION: operating problems may occur if parameters P127 and P131 are set to 'Yes' and the controller delivering the 4-20 mA signal has its own function for shifting the setpoint based on the outdoor temperature.
If the minimum value of the signal becomes less than 4 mA, the value of the setpoint will not drop below the minimum setpoint.

9.12 Operating mode selection

•If P119 = 4 (cooling/heating via on/off input):

The unit is controlled, during water heating or water chilling, based on the mode selected via the input located:

- Between terminals 5-6 on terminal block J6 on the motherboard if P2 = water-to-water
 - Between terminals 1-2 on terminal block J4 on additional board 1 if P2 = reversible air-to-water, 1 circuit
 - Between terminals 1-2 on terminal block J2 of additional board 2 (cycle reversal) if P2 = reversible air-to-water, 2 circuits
- The contact must be closed in order to be able to select heating

mode, and it must be open in order to be able to select cooling mode.

- If P2 = water-to-water, the machine must be shut off via the On/Off button or the automatic operation control and winter protection must be shut off before the operating mode may be changed.

➤ A fault will occur if the operating mode is changed while the machine is running:

- Unit shut off,
- General fault LED on
- LED of initial mode flashes; fault control contact closed (not stored in fault memory)

M A C H I N E O F F
O P E R A T I N G M O D E C H A N G E

➤ Automatic acknowledgment:


- The operating mode changes if the change is confirmed via the On/Off button or the automatic operation control.
- If the input returns to its original state, the unit resumes its initial operating mode.

If P2 = reversible air-to-water, the operating mode may be switched with the unit running. After the operating mode is changed, the unit will stop and restart in its new operating mode and take into account the short-cycle protection.

10 MANAGEMENT OF THE ANALOGUE INPUTS

10.1 Temperature sensor

Diagram of sensors: All sensor faults are taken into account in the fault memory.



•Water inlet sensor: CTN 10 K at 25°C (if P2 = 1, 2 or 3)

This sensor monitors the water temperature on the exchanger inlet in order to:

- Adjust the unit (water return control).
- Monitor the operation of the unit if the water return temperature is too high (load limiting).
- Display the chilled water or hot water inlet temperature (display range: -40 to 99°C, resolution: 0.1 K).
- This fault is acknowledged automatically

E X C H . 1 W A T E R I N L E T
S E N S O R F A U L T J 7 / 2 - 3

- Sensor wire cut and short circuit:

➤ In cooling mode:

- Unit shut off, message on LCD, unit fault LED lit steady, fault saved in fault memory, fault relay in On position.

➤ In heating mode:

- Water-to-water unit → No effect on control, message on LCD, unit fault LED flashes, fault saved in fault memory.
- Reversible air-to-water unit and water return control → Unit shut off, message on LCD, unit fault LED lit steady, fault saved in fault memory, fault relay in On position.
- Reversible air-to-water unit and water return control → No effect on control, message on LCD, unit fault LED flashes, fault saved in fault memory.

•Water outlet sensor on heat exchanger 1: CTN 10 K at 25°C (if P2 = 1, 2 or 3)

This sensor monitors the water temperature on the exchanger outlet in order to:

- Adjust the unit (to water supply) → (P6 = 1) and (P141 = 3 or 4) and cooling mode or (P02 = 3), (P6 = 1) and (P141 = 3 or 4) and heating mode
- Enable the frost protection
- Display the water outlet temperature (display range: -40 to 99.9°C, resolution: 0.1 K).
- This fault is acknowledged automatically

E X C H . 1 W A T E R O U T L E T
S E N S O R F A U L T J 7 / 4 - 5

- Sensor wire cut and sensor short circuit → Fault relay in On position

If this sensor is used for control, the unit is shut off (message from table 1 in machine status menu shown on LCD, unit fault LED lit steady, fault saved in fault memory). If heating mode is on: the electric auxiliary heaters are turned on if possible and the boiler relay is in the On position if P111 = boiler).

If the sensor is not used for control (i.e. it is used only for the frost limit), the fault is a circuit fault (message from circuit 1 table in machine status menu shown on LCD, circuit fault LED lit steady, fault saved in fault memory).

•**Water outlet sensor on heat exchanger 2:** CTN 10 K at 25°C (if P2 = 1, 2 or 3)(if P6 = 2 → two sensors + manifold sensors).

This sensor monitors the water temperature on the exchanger outlet in order to:

- Enable the frost protection 99.9°C, resolution: 0.1 K).
- Display the water outlet temperature (display range: -40 to - This fault is acknowledged automatically

E X C H . 2 W A T E R O U T L E T
S E N S O R F A U L T A D D 2 J 4 / 1 - 2

- Sensor wire cut and sensor short circuit → Fault relay in On position

This sensor is not used for control (i.e. it is used only for frost protection; control is provided by the manifold sensor). The fault is

a circuit fault (message on LCD, circuit fault LED lit steady, fault saved in fault memory).

•**Outdoor air sensor:** CTN 10 K at 25°C

This sensor monitors the temperature of the outdoor air in order to:

- Adjust the system based on the outdoor temperature (cooling and heating). If the sensor wire is cut (open circuit) or the sensor short-circuits, the unit is adjusted to the setpoint value (heating and cooling) and a fault is displayed.
- Limit the operation of the unit based on the minimum

temperature in heating mode.

- Display the outdoor air temperature (display range: -40 to 99.9°C, resolution: 0.1 K).
- This fault is acknowledged automatically

O U T . T E M P . S E N S O R F A U L T
J 7 / 1 - 2

- Sensor wire cut and short circuit:

. Control based on outdoor temperature inhibited; control using setpoint.
. If the unit is running in heating mode and can run with the electric stages, the compressors are shut off, control is on the electric stages, a message appears on the LCD, the unit fault LED flashes, and the fault is saved in fault memory.

. If P2 = water-to-water, the unit continues to operate and the fault is reported (message from table 2 in machine status menu shown on LCD, unit fault LED flashes, fault saved in fault memory)

. In all other cases: unit shut off, message on LCD (table 1 in machine status menu), unit fault LED lit steady, fault saved in fault memory, heat trace cabled turned on, fault relay in On position, boiler relay in On position if heating mode on and P111 = boiler.

•**Frost protection sensor for refrigerant in heat exchanger (1 or 2):** CTN 10 K at 25°C (if P2=1, 2 or 3 unless P1 = R407C, P2 = 3 and P3 = 2).

This sensor monitors the temperature of the refrigerant at the heat exchanger inlet in order to:

- Protect the heat exchanger from frost:
- . Power reduced if several control stages are used
- . Slope of fans changed
- . Unit shut off

- Refrigerant frost protection temperature displayed (display range: -40 to 99.9°C, resolution: 0.1 K)
- This fault is acknowledged automatically

E X C H . x R E F R . F R O S T
P R O T . S E N S . F A U L T J x / x - x

- If the sensor wire is cut or the sensor short-circuits, the corresponding circuit is shut off, a message appears on the LCD, the circuit x fault LED is lit steady, the fault is saved in the fault

memory, the general fault relay is in the On position, and the auxiliary heaters are turned on if heating mode is on.

•**Coil sensor (A to D):** CTN 10 K at 25°C

If P2 = reversible air-to-water, this sensor manages the freon temperature at the coil outlet in order to:

- Manage (turn on and off) a defrosting cycle resolution 0.1 K).
- Display the coil temperature (display range: -40 to 99.9°C, - This fault is acknowledged automatically

C O I L x C I R C U I T x
S E N S O R F A U L T J x / x - x

If the sensor wire is cut or the sensor short-circuits:

➤ In cooling mode:

Normal operation, message on LCD, circuit x fault LED flashes, fault saved in fault memory.

➤ In heating mode:

- If outdoor temperature ≥ 10°C → normal operation, message on LCD, circuit x fault LED flashes, fault saved in fault memory.

- If outdoor temperature < 10°C → circuit x shut off, message on LCD, circuit fault LED flashes, fault saved in fault memory.

•**Condenser hot water sensor:** CTN 10 K at 25°C (if P2 = 1 and P141 = 3 or 4) = P258 (if P2 = 1 and P141 = 1) = P257

This sensor monitors the water temperature at the condenser exchanger's inlet (or outlet) in order to:

- Adjust in heating mode
- Display the condenser's water temperature (display range: -40 to 99.9°C, resolution: 0.1 K)
- This fault is acknowledged automatically

C O N D E N S E R I N L E T S E N S O R
F A U L T J 7 / 5 - 6

- Sensor wire cut and short circuit:

➤ In cooling mode:

Normal control, message on LCD, unit fault LED flashes, fault saved in fault memory, general fault relay in On position.

➤ In heating mode:

Unit shut off, message on LCD, unit fault LED flashes, fault saved in fault memory, general fault relay in On position, boiler relay in On position if P111 = boiler.

•Heat exchanger ambient sensor: CTN 10 K at 25°C (if P2 = 2)

This sensor monitors the temperature inside the hydraulic enclosure housing the heat exchanger(s) in order to:

- Turn on the heaters to 99.9°C, resolution: 0.1 K)
- Display the temperature inside the enclosure (display range: -40 - This fault is acknowledged automatically

```

E X C H A N G E R   A M B I E N T   T E M P .
S E N S O R   F A U L T   J 7 / 5 - 6
    
```

- Sensor wire cut and short circuit: heaters turned on (relay in On position), message on LCD, unit fault LED flashes, fault saved in fault memory + general fault relay in On position.

•Control stage discharge sensor (1, 2, 3 or 4): CTN 50 K at 25°C (all configurations)

- Monitors the discharge temperature on the compressors
- Displays the discharge temperature (display range: 5 to 150°C, resolution 1 K).

```

D . T E M P .   S E N S O R   X   F A U L T
                                     J x / x - x
    
```

- If the sensor wire is cut (check 5 minutes after compressor turned on) and the sensor short-circuits (continuous monitoring), the corresponding control stage is turned off and the auxiliary heaters are turned on if need be. If there are no auxiliary heaters, the boiler relay moves to the On position if P111 = boiler.

A message appears on the LCD, the circuit fault LED is lit steady, and the fault is saved in the fault memory.
 - This fault must be acknowledged manually if the temperature < 145°C. The discharge fault must also be acknowledged.

•Water manifold outlet sensor: CTN 10 K at 25°C (if P2 = 1, 2 or 3 and P6 = 2)

This sensor monitors the water temperature on the exchanger outlet in order to:

- Adjust the unit (to water return) (display range: -40 to 99.9°C, resolution: 0.1 K).
- Display the common water outlet temperature - This fault is acknowledged automatically

```

M A N I F . W A T E R   O U T L E T
S E N S O R   F A U L T   A D D 2   J 4 / 2 - 3
    
```

- Sensor wire cut and short circuit:
- . If water return control or if P2 = water-to-water and heating mode on (i.e. sensor not used for control): Normal control, message from table 2 in machine status menu shown on LCD, unit fault LED flashes, fault saved in fault

memory, general fault relay.
 . If water outlet control and (cooling mode on or P2 = 3): Unit shut off, message from table 1 in machine status menu shown on LCD, unit fault LED lit steady, fault saved in fault memory, general fault relay

•Circuit suction sensor: CTN 10 K at 25°C (all configurations)

If P42 = 2 (electronic expansion valve on CIAT board)

The sensor is connected to the expansion valve board and the temperature information is transmitted over the bus link.

The sensor monitors the suction temperature in order to:

- Display the superheat temperature (display range: -40 to 99.9°C, resolution: 0.1 K)
- This fault is acknowledged automatically
- If the sensor wire is cut or the sensor short-circuits:
- . If P43 = No: a secondary fault is displayed, the fault LED flashes; the circuit fault relay is in the On position and the fault is automatically acknowledged

. If P43 = Yes: The corresponding circuit is turned off and the auxiliary heaters are turned on if need be. If there are no auxiliary heaters, the boiler relay moves to the On position.
 If P111 = Boiler. A message appears on the LCD, the circuit fault LED is lit steady, and the fault is saved in the fault memory and automatically acknowledged.

➤ Fault message:

```

S U C T I O N   T E M P .   S E N S O R
F A U L T   C I R C U I . x   J x / x x - x x
    
```

•Circuit liquid sensor: CTN 10 K at 25°C (all configurations)

This sensor measures the liquid temperature in order to:

- Display the subcooling temperature (display range: -40 to 99.9°C, resolution: 0.1 K).
- This fault is acknowledged automatically

- If the sensor wire is cut or the sensor short-circuits, a secondary fault is displayed, the fault LED flashes, the circuit fault relay is in the On position, and the fault is automatically acknowledged

➤ Fault message:

```

L I Q U I D   T E M P .   S E N S O R
F A U L T   C I R C . x   J x / x x - x x
    
```

•Fault detection values:

- For the 50 K sensors: Cut-off fault (or sensor absent) if < 5°C and unit operating for 5 minutes, and sensor short-circuit if > 148°C.

- For the 10 K sensors: Cut-off fault (or sensor absent) if < -40°C and sensor short-circuit if > 99°C.

•Correspondence table:


Temperature (°C)	SENSOR RESISTANCE Ω	
	DISCHARGE SENSOR 50 KΩ	CONTROL AND OUTDOOR SENSOR 10 KΩ
10	-	55340
-5	-	42340
0	162250	32660
5	126977	25400
10	99517	19900
15	78570	15710
20	62468	12490
25	50000	10000
30	40280	8058
35	32650	6532
40	26624	5326
45	21834	4368
50	18005	3602

10.2 Pressure sensor

The high and low values for the HP/LP pressure sensors are given below:
 The sensors are adjusted using parameters P30 to P39.
 Measurement range:

Low value from	High value to	
P31	P30	HP1
P33	P32	HP2
P37	P36	LP1
P39	P38	LP2

- Power supply: 5 V DC
- Signal: 0.5 - 4.5 V



Short-circuit faults will be detected by a voltage ≥ 4.75 V.
 Open-circuit faults will be detected by a voltage ≤ 0.25 V.

The pressure values given are for **relative pressure**.

•The HP sensor will:

- Monitor the HP pressure in the circuit and relay this information
- Control the unit using the HP

- Control the condensing pressure

•The LP sensor will:

- Monitor the LP pressure in the circuit and relay this information

- Monitor for refrigerant leaks before turning on stages

When reading the operation parameters for the pressure levels, the sensors can be adjusted with the **OK button** if a difference is found between a value that is read and the corresponding value measured by a pressure gauge.

Example:

```

P 3 x x H P x   P R E S S U R E   ↑
                                   ↓
                                   x x . x b
    
```

Press **OK** to access and change the adjustment value.

```

S E N S O R   A D J U S T M E N T   H P x
                                   0 . 0 b
    
```

{ [- 1 + 1] 0 by default

Press **OK** to confirm the new adjustment value and go back to the operation parameter.
 Press **ESC** to cancel any changes made and go back to the operation parameter.

This readjustment will be used to correct the difference between the value measured by a pressure sensor and the value read on a pressure gauge. The resulting new slope will then be used for control.

11 MANAGEMENT OF THE WATER PUMPS

11.1 Pump 1

Pump 1 is assigned to the main hydraulic network. Therefore, it is used in all configurations:

- If P2 = air-to-water or reversible air-to-water and P25 = 2, it will be managed alternately with Pump 2.
- The pump that has run for the shortest amount of time starts up first.

- Otherwise, the pumps may be turned on using the On/Off button (and automatic operation control input closed).
- The pump is shut off 1 minute after the last control stage turns off.

11.2 Pump 2

Pump 2 is used only in certain configurations:

- A) If P2 = water-to-water, pump 2 is assigned to the customer's secondary network and its control mode is determined by P108.
- If P108 = depending on control mode, the pump control is linked to the unit control:

P U M P x O N

x x s

Pump x is turned on before the first control stage (where x is the value entered in P109).

The pump is shut off 1 minute after the last control stage turns off.

Automatic time delay countdown.

This time delay is maintained during test mode.

- If P108 = depending on On/Off, the pump control is linked to the operation of the unit.:

. The pump is turned on (via On/Off and with the automatic operation control input closed; or via On/Off, with the automatic

operation control input closed and winter protection activated by outdoor temperature; or remotely via a PC, modem or other).

The pump is immediately turned off when P108 is changed and switches from On/Off control to Depending on control mode (unless control mode called for).

The pump is shut off 1 minute after the last control stage turns off.

- B) If P2 = air-to-water or reversible air-to-water, it depends on P25
- If P25 = 0 or 1 (only one pump supplied.) there is no pump 2.
- If P25 = 2, the unit is supplied with a backup pump. This pump is managed by On/Off control and runs alternately with pump 1. The pump that has run for the shortest amount of time starts up first.

The next time the machine is turned off by the control after 7 days of operation with the same pump, the pumps are switched (by turning off the one that was running) in order to balance the runtimes.

The pump is shut off 1 minute after the last control stage turns off.

11.3 Pump management if P2 = 3 (reversible air-to-water) + heating mode + P111 = Boiler

Parameter P27 is used to have the pump controlled by the operation of the boiler.

- A) If P27 = Yes: When the boiler is turned on, the pump is shut off unless there is a risk of the unit freezing (outdoor temperature \leq P52 and $P261 \leq 30^{\circ}\text{C}$).

A tank with four nozzles must be installed on the system and the boiler must have its own pump and its own control with its own protections

P 2 7 P U M P C O N T R O L L E D
B Y B O I L E R Y E S

The boiler will continue to operate if the heat pump malfunctions.

- B) If P27 = No: The pump is controlled by the On/Off button. It continues to run even when the boiler is authorised to operate.

P 2 7 P U M P C O N T R O L L E D
B Y B O I L E R N O

11.4 Unseizing and switching the pumps

If any of the pumps remains off (for a reason other than a fault) for over 7 days, it must be turned on between 9.00 am and 9.00 pm and be allowed to run for 2 minutes.

- If P25 = 2, the pump with the longest runtime is turned off after being unseized.
- If the unit is turned off via the On/Off button or the automatic

operation control and a water flow fault occurs during unseizing, both pumps are turned off.

12 WINTER PROTECTION

12.1 Frost protection of pumps and heat exchangers while unit is off

This function protects the pump(s) and the heat exchanger(s) from freezing.

The heater and heat trace cable outputs are enabled only when P2 = air-to-water and reversible air-to-water.

P265 becomes visible if P2 = air-to-water and reversible air-to-water

12.1.1 Use with pure water: If P52 \geq its standard adjustment value based on the refrigerant type:

1) Heater control:

- If exchanger ambient temperature \leq P220 or ambient temp. sensor fault and water inlet temperature \leq (P52 + 2) + all compressors off + pump off if P25 \neq 0 \rightarrow Heaters on.
- If ambient temperature sensor fault and water inlet temperature \leq (P52 + 2) + all compressors off + pump off if P25 \neq 0 \rightarrow Heaters on.
- If exchanger ambient temperature $>$ P220 + P222 or water inlet temperature \geq (P52 + 2) + P222 or if a compressor or a pump is on if P25 \neq 0 \rightarrow Heaters off.

2) Heat trace cable control:

- If outdoor temperature sensor \leq P220 and water inlet temperature $\leq 20^{\circ}\text{C}$ + all compressors off + pump off if P25 \neq 0 \rightarrow Heat trace cables on
- If outdoor temperature sensor fault and water inlet temperature $\leq 20^{\circ}\text{C}$ + all compressors off + pump off if P25 \neq 0 \rightarrow Heat trace cables on
- If outdoor temperature $>$ P220 + P222 or water inlet temperature $\geq 20^{\circ}\text{C}$ + P222 or if a compressor or a pump is on \rightarrow Heat trace cables off.

12.1.2 Use with glycol/water mix: If P52 < its standard adjustment value based on the refrigerant type:

1) Heater control:

- If exchanger ambient temperature and water inlet temperature $\leq P52 + 2 K$ + all compressors off + pump off if P25 $\neq 0$ → Heaters on.
- If exchanger ambient temp. sensor fault and water inlet temperature $\leq P52 + 2 K$ + all compressors off + pump off if P25 $\neq 0$ → Heaters on.
- If exchanger ambient temperature P265 or water inlet temperature $> P52 + 2 + P222$ or if a compressor or a pump is on if P25 $\neq 0$ → Heaters off.

2) Heat trace cable control:

- If outdoor temperature ≤ 0 and water inlet temperature $\leq 0^\circ C$ + all compressors off + pump off if P25 $\neq 0$ → Heaters on.
- If outdoor temperature sensor fault and water inlet temperature $\leq 0^\circ C$ + all compressors off + pump off if P25 $\neq 0$ → Heaters on.
- If outdoor temperature $> 0 + P222$ or water inlet temperature $\geq 0^\circ C + P222$ or if a compressor or a pump is on if P25 $\neq 0$ → Heat trace cables off.

➤ Output state displays:

P 4 3 5 H E A T T R A C E C A B L E O U T P U T O N
P 4 3 6 H E A T E R O U T P U T O N

12.1.3 Controlling frost protection for partial recovery (desuperheater) or total recovery option:

P 2 9 . 1 H E A T R E C O V . E X C H . F R O S T P R O T E C T I O N Y E S

Parameter visible only if P2 (unit type) = air-to-water or reversible air-to-water:

➤ Default value:

- No if P29 (total recovery) = No
- Yes if P29 = Yes
- If P29.1 = Yes and outdoor temperature $\leq P220$: heat trace cables on
- If P29.1 = Yes and outdoor temperature sensor fault: heat trace cables on
- If P29.1 = Yes and outdoor temperature $> P220 + P222$: heat trace cables off.

The heat trace cables will be controlled by output 4 on terminal block J5 on additional board 1 (1-circuit cycle reversal). If P29.1 is set to 'Yes' and the link with ADDitional board 1 is missing, a link fault should appear.

➤ Output state display:

P 4 3 7 R E C O V E R Y F R O S T P R O T . O U T P U T O N
--

12.2 Water loop winter protection

➤ In heating mode:

This function is possible only if P142 = Yes, the automatic operation control input is open and the On/Off button on the console is set to 'On'. In this case the function must maintain water inlet temperature on

the heat exchanger at 30°C as soon as the outdoor temperature falls below 3°C (2 K differential). The return temperature will be maintained at 30°C if the outdoor temperature sensor ever malfunctions.

➤ In cooling mode:

This function is possible only if P142 = Yes, the automatic operation control input is open and the On/Off button on the console is set to 'On'. In this case the pump is turned on if the

outdoor temperature falls below P220 and shut off at P220 + P222. The pump will be forced on if the outdoor temperature sensor ever malfunctions.

13 MANAGEMENT OF THE FUNCTIONS

13.1 Management of the compressor protections

13.1.1 Short-cycle protection:

Information from compressor manufacturer:

Compressors are not allowed to start more than 12 times an hour (on/off time of 5 minutes and minimum of 3 minutes between starts). The on time + off time will be adjustable via parameter P50.

The auxiliary heaters do not operate during short-cycle protection. On power-up, the SCP = 0 minutes and the minimum off time = 3 minutes.

In test mode, the short-cycle protection is shunted. The compressor can start up immediately at the end of the pump start-up time delay.

S H O R T - C Y C L E P R O T E C T I O N S T A G E x C I R x x x m n x x s
S T A G E x C I R C U I T x A T M I N . S T O P x x m n x x s

The information is displayed only if a call is made to turn on the stage while the time delay is counting down.

13.1.2 Forced stop of compressors

This function prevents the compressor stages from operating individually.

It is enabled and disabled via the following parameters:

P230: On authorisation, stage 1 circuit 1

P231: On authorisation, stage 2 circuit 1

P232: On authorisation, stage 1 circuit 2

P233: On authorisation, stage 2 circuit 2

13.2 Management of the time counters

The number of hours of operation in each mode (cooling and heating) can be viewed for each pump and each compressor stage.

The parameters are as follows:

P285: Heating mode runtime (in hours)

P286: Cooling mode runtime (in hours)

P287: Pump 1 runtime

P288: Pump 2 runtime

P311: Stage 1, circuit 1 runtime

P314: Stage 2, circuit 1 runtime

P341: Stage 1, circuit 2 runtime

P344: Stage 2, circuit 2 runtime

There are also monitoring counters: P289, P290, P308, P309, P310, P313, P322, P323, P324, P338, P339, P340, P343, P352, P353, and P354.

➤ In heating mode (P285):

The time delay increments if heating mode is on via the On/Off button and the automatic operation control input is closed or the winter protection is on with a control stage on.

➤ In defrost mode (P285):

These counters are visible if P285 is opened, Enter is pressed on the console and P159 = optimised.

The top line corresponds to the total runtime in heating mode (excluding defrosting). The second line corresponds to the total defrosting time. These counters have been added in order to know the gain compared to frosting during a fixed period of time.

➤ In cooling mode (P286):

The time delay increments if cooling mode is on via the On/Off button and the automatic operation control input is closed or the winter protection is on with a control stage on.

13.3 Management of compressor start-up

Applies only for units with several compressors and if the number of stages on circuit 1 \neq 1 and the number of stages on circuit 2 \neq 1.

Parameter P13 is visible only:

- if P3 (No. of circuits) = 1 and P4 (No. of stages on circuit 1) = 2

- if P3 (No. of circuits) = 2 and P4 (No. of stages on circuit 1) = 2 and P5 (No. of stages on circuit 2) = 2

13.3.1 With balanced tandem compressors:

Before stages are turned on, the runtime of each stage is always checked so that the stage that has run the least is started first.

When only one of the two compressors on each circuit is running, it is turned off after 4 hours and the other compressor is turned on.

➤ **With 1 circuit and 1 stage:** No runtime balancing.

➤ **With 1 circuit and 2 stages:** The two stages on the circuit are balanced (during operation and at start-up).

➤ **With 2 circuits and 3 stages:** On circuit X, the first of the three stages to be turned on is the one that has run the least amount of time. On circuit Y, the second stage to be turned on (circuit change) is the one that has run for the second-shortest time. Then the third and last stage is started.

➤ **With 2 circuits and 4 stages:** On circuit X, the first of the four stages to be turned on is the one that has run the least amount of time. On circuit Y, the second stage to be turned on (circuit change) is the one that has run for the second-shortest time. The third stage to be turned on is the stage that has run for the third-shortest time. Then the fourth and last stage is turned on.

This function must take into account:

- The stage restriction

- The short-cycle protection

- The authorisation for the stages to turn on

- Compressor faults

The compressors are turned off in sequence, starting with the compressor that has run the longest.

13.3.2 With unbalanced tandem compressors and partial-load control:

Partial-load control is enabled on water chillers equipped with scroll compressors with one or two refrigerating circuits with two or four control stages.

It makes it possible to manage up to six control stages using four compressor outputs on CONNECT 2.

On machines equipped with unbalanced tandem compressors, this type of control is particularly useful in obtaining the following breakdown:

If P3 (number of circuits) = 1 → 33%, 66%, 100%

If P3 = 2 → 16%, 33%, 50%, 66%, 83%, 100%

The stages must therefore be assigned on the compressor outputs on CONNECT 2

Motherboard

- Terminal 2 on terminal block J3, output of stage 1 on circuit 1 = most powerful stage on circuit 1

- Terminal 3 on terminal block J3, output of stage 2 on circuit 1 = most powerful stage on circuit 1

Additional board 2, circuit 2 function

- Terminal 2 on terminal block J3, output of stage 1 on circuit 2 = most powerful stage on circuit 2

- Terminal 3 on terminal block J3, output of stage 2 on circuit 2 = most powerful stage on circuit 2

➤ **With 1 circuit and 1 stage:** No partial-load operation

➤ **With 2 circuits and 3 stages:** No partial-load operation as the compressors are of the same size (LGN and LJA range). The compressor that has run the least is turned on first.

This function must take into account:

- The stage restriction,

- The short-cycle protection,

- The authorisation for the stages to turn on

- Compressor faults

➤ **Compressor switching management:**

When only one of the two compressors on each circuit is running, it is turned off after 4 hours and the other compressor is turned on.

➤ Short-cycle protection management (SCP):

- Call for power:

If the only available stage is in SCP mode, the machine remains in its current state and SCP is indicated by the flashing LED on the console. Before a stage is turned on, the runtime of each stage is always checked so that the stage that has run the least is started first.

13.4 Management of the reversing valves

The reversing valves are fitted on reversible units only.

They are managed by the following convention:

- In cooling mode: the reversing valves are supplied.
- In heating mode: the reversing valve are not supplied.

The supply to the reversing valves is cut off 30 minutes after the last stage on the corresponding circuit is turned off. This time delay becomes 30 seconds in test mode.

13.5 Management of configurable output P111:

The output between terminals 9-10 on terminal block J3 on the motherboard is configurable so that the customer can define its function.

Max. power: The NC contact informs the customer that the unit is running at full power (all compressors and all electric stages).

Boiler: The NC contact allows the customer to activate an auxiliary heater. This type of operating mode is described in section 21 "Management of the back-up boiler".

Cooling/Heating: The NC contact informs the customer of the heating operation of the unit. The NO contact informs the customer of the cooling operation of the unit.

Backup on all faults (on air-to-water machines only):

The NC contact informs the customer that the machine is either not operating at full capacity (a compressor is off) or has been shut off following the detection of a fault. The machine will remain off until the fault is acknowledged with the Reset button.

Display:

```
M A C H I N E   O F F
F A U L T S   O R   L I M I T E R
```

Machine fault output on

- General fault LED on console lit steady

To see which type fault caused the machine to be shut off, go to the fault memory.

List of faults and impairments that shut off the machine if P111 is set to 'backup on all faults':

- Pump fault
- Intermediate and final water flow fault
- Limiter on water outlet
- Intermediate and final water frost fault
- Limiter on refrigerant
- Intermediate and final frost fault on refrigerant
- Exchanger frosting fault
- Limiter on high pressure
- Intermediate and final high pressure control fault
- Manual high pressure fault
- Motor fault
- Limiter on discharge
- Intermediate and final discharge fault
- Intermediate and final low pressure fault
- Water inlet sensor fault
- Exchanger 1 or 2 water sensor fault
- Refrigerant sensor fault
- Discharge sensor fault
- Manifold water outlet sensor fault if control on outlet
- Sensor fault
- Excessively low outdoor temperature fault
- Electronic expansion valve fault
- Fan fault if P3 and P180 = 1
- Maximum superheat fault
- Minimum superheat fault
- Limiter on max. air during cooling
- Phase controller fault
- Suction sensor fault if P43 = Yes
- Excessively high outdoor temperature fault

14 SELF-ADJUSTING FUNCTIONS

These functions allow the machine to adjust itself to certain occasionally extreme operating conditions and thus avoid stops caused by faults.

14.1 Self-adjusting function: water frost limit

➤ Operation:

- Before shutting down after a fault occurs, the unit reduces its power by turning off a stage (if there are two on the circuit), or by reducing the compressor to half speed. In the case of INVERTER units, they shut off if they are already running at half speed.
- The threshold is detected by the water outlet sensor at P52 + 0.8 K.
- The unit returns to normal operation at P52 + 2 K for 5 minutes and then the HP gradually rises to its set threshold (P181).
- This function operates on each circuit.

➤ Display:

```
C I R C . x   W A T E R   F R O S T   L I M
P O W E R   R E D U C .
```

14.2 Self-adjusting function: refrigerant frost limit

➤ Operation:

Before shutting down after a fault occurs, the unit reduces its power by turning off a stage (if there are two on the circuit), or by reducing the compressor to half speed. In the case of INVERTER units, they shut off if they are already running at half speed. It raises the high pressure level by decreasing the speed of the fans (units with air-cooled condensers only).

The threshold is detected by the sensor placed on the freon pipe at the evaporator inlet at P52 - P53 + 2 K for 10 seconds. The unit returns to normal operation at P52 - P53 + 3.5 K and then the HP gradually rises to its set threshold (P181).

➤ Display:

```
C I R C . x   R E F R I G   F R O S T   L I M
P O W E R   R E D U C .
```

Exception: P08 = "SWEP DOUBLE":

The limit is detected by the saturation temperature (LP side), at P52 – P53 for 60 seconds. Normal operation resumes when the saturation temperature (LP side) rises to a sufficient level.

➤ Display:

```
C X   E V A P   T . / F R E E Z E   L I M . X
U N I T   I N   P A R T   L O A D
```

14.3 Self-adjusting function: HP pressure limit

➤ Operation:

- Before shutting down after a fault occurs, the unit reduces its power by turning off a stage, or by slowing the compressor to 50 Hz, or by shutting off Inverter units for 30 minutes.
- The threshold is detected by the HP sensor at P54-P195 and returned to normal operation after 30 minutes.
- This time period becomes 30 seconds in test mode.

This function is turned on on both circuits at the same time.

➤ Display:

```
C I R C U I T   x   H P   L I M I T
P W R   R E D U C T I O N   x x m n
```

Special case of Inverter machines in water heating mode: If the HP pressure \geq P54 - P195, the CONNECT2 controller adjusts the control setpoint so as not to push the compressors near their limits too often. If necessary, a coil defrosting cycle will be forced on.

14.4 Self-adjusting function: discharge protection, circuit 1 or 2

➤ Operation:

- Before shutting down after a circuit fault occurs, the unit reduces its power for 30 minutes by turning off a stage.
- The threshold is detected by the discharge sensor at value P51 and the stage that was turned off is returned to normal operation after 30 minutes.
- This time period becomes 30 seconds in test mode.

➤ Display:

```
C I R C . X   D . T E M P   L I M I T
P W R   R E D U C T I O N   x x m n
```

Special case for reversible machines in water heating mode: If the discharge circuit temperature \geq P151, the CONNECT controller adjusts the control setpoint so as not to push the compressors near their limits too often. If necessary, a coil defrosting cycle will be forced on.

14.5 Self-adjusting function: minimum HP, circuit 1 or 2

➤ Operation:

- If the pressure measured by the HP sensor is \leq P63 for water-to-water units, the controller lowers the circuit's power to avoid an excessive drop in LP. Normal operation is restored at P63 + 1b.

➤ Display:

```
C I R C . x   M I N .   H P   L I M .
P O W E R   R E D U C .
```

14.6 Self-adjusting function for high water return temperatures

➤ Operation:

- The water return temperature may be high as the installation warms up in cooling mode. This causes all the compressor stages to turn on one after the other and can result in HP cuts and unwanted voltage spikes.
- To prevent this, the controller limits the turning-on of the stages if the water inlet temperature on the heat exchanger is higher than P171 as long as the temperature does not drop below P171-5K.

➤ Display:

```
W A T E R   R E T U R N   T .   L I M I T
U N I T   P W R   R E D U C T I O N
```

15 FAULT FUNCTIONS**15.1 Water frost limit fault on circuits 1 and 2**

➤ Operation:

- Should the self-adjusting function be insufficient, a fault will occur on the unit when the temperature measured on the heat exchanger water outlet is at P52 (measured for 15 seconds, or P52 – 1 K).

If this fault causes fewer than 3 shutdowns in 24 hours:

- Corresponding circuit shut off.
- Circuit fault output off
- Frost protection fault relay on optional board in Off position
- Circuit fault LED on console **flashes**

➤ Display:

```
C I R C   X   H 2 O   F R O S T   F A U L T
x   C U T ( S )   I N   2 4 H
```

If this fault causes more than 3 shutdowns in 24 hours:

- Corresponding circuit shut off.
- Fault output on
- Frost protection fault relay on optional board in On position

- Circuit fault LED on console lit **steady**
- Boiler on if P111 = Boiler and heating mode.
- Auxiliary heaters on if P22 = Yes and heating mode.

➤ Display:

```
C I R C U I T   X   O F F
W A T E R   F R O S T   F A U L T
```

➤ Saved in fault memory:

```
x . W A T E R   x   F R O S T   P R O T .
```

➤ Resetting:

- If the number of faults in 24 hours ≤ 3 → the fault is automatically acknowledged if the temperature rises back above P52 + 6 K.
- If the number of faults in 24 hours > 3 → the fault is acknowledged if the temperature rises back above P52 + 6 K and **Reset** is pressed on the console.

15.2 Refrigerant frost limit fault on circuits 1 and 2

Frost on the heat exchangers is detected in two ways on most CIAT machines.

- Detection method 1: sensors monitor for deviations in low pressure and in the water outlet temperature. Such deviations indicate that ice has started to form on the heat exchanger. There is no self-adjusting function; the risk of freezing is immediately handled as a fault. This method of detection is standard on all CIAT units.

Parameters P58 and P59 are used in this mode of detection. Therefore, the lower their values, the more the frost protection is sensitive.

➤ Display:

```
C I R C U I T   X   O F F
E X C H .   A N T I F R E Z E   F A U L T
```

This function can be turned off via parameter P115 in order to perform maintenance.

- Detection method 2: frost is detected by a freon sensor on the heat exchanger inlet:

```
C I R C   X   R E F   F R O S T   F A U L T
x   C U T ( S )   I N   2 4 H
```

➤ Operation:

- Should the self-adjusting function be insufficient, a fault will occur on the unit when the temperature measured on the freon pipe at the heat exchanger inlet is at P52 - P53 (measured for 60 seconds).

If this fault causes fewer than 3 shutdowns in 24 hours

- Corresponding circuit shut off.
- Circuit fault output off
- Frost protection fault relay on optional board in Off position

- Circuit fault LED on console **flashes**

➤ Display:

```
C I R C   X   R E F   F R O S T   F A U L T
x   C U T ( S )   I N   2 4 H
```

If this fault causes more than 3 shutdowns in 24 hours:

- Corresponding circuit shut off.
- Fault output on
- Frost protection fault relay on optional board in On position

- Circuit fault LED on console lit **steady**
- Boiler on if P111 = Boiler and heating mode.
- Auxiliary heaters if P22 = Yes + heating mode

➤ Display:

```
C I R C U I T   X   O F F
R E F R I G .   F R O S T   F A U L T
```

➤ Saved in fault memory:

```
x . R E F R I G .   x   F R O S T   P R O T
```

➤ Resetting:

- If the number of faults in 24 hours ≤ 3 → the fault is automatically acknowledged if the temperature rises back above P52 - P53 +10 K.
- If the number of faults in 24 hours > 3 → the fault is acknowledged if the temperature rises back above P52 - P53 +10 K and **Reset** is pressed on the console.

15.3 HP pressure fault, circuits 1 and 2

➤ Operation:

- Information is sent by the pressure sensors on each circuit. This function prevents manual HP cuts during brief increases in HP during momentary blockages in the condenser.
- Should the self-adjusting function be insufficient, a fault will occur on the circuit when the pressure measured is at P54.

If this fault causes fewer than 5 shutdowns in 24 hours:

- Corresponding circuit shut off.
- 30 min. time delay (in seconds in test mode).
- Fault output off
- Circuit x HP fault relay on optional board in Off position

- Circuit fault LED on console **flashes**.
- The number of faults over a 24 hour period is managed (P308 for circuit 1 and P338 for circuit 2).

➤ Display:

```
C I R x   H P   F A U L T   x x m n
X   C U T ( S )   I N   2 4 H
```

If this fault causes shutdowns in 24 hours:

more than 5

- Corresponding circuit shut off.
- Fault output off.

- Circuit x HP fault relay on optional board in On position.
- Circuit LED on console lit **steady**.

➤ Display:

```
C I R C U I T   X   O F F
H P   F A U L T
```

➤ Saved in fault

memory:

```
x . C I R C U I T x   H P
```

➤ Resetting:

- If the number of faults in 24 hours ≤ 5 → the fault is acknowledged after 30 minutes.
- If the number of faults in 24 hours > 5 → the fault is acknowledged if **Reset** is pressed on the console

15.4 Discharge temperature fault, circuit 1 or 2

➤ Operation:

- Information is sent by the sensors placed on the discharge pipes (one per control stage).
- The maximum discharge temperature limit is set by parameter P51 + 1 K.

If this fault causes fewer than 5 shutdowns in 24 hours:

- Corresponding circuit shut off.
- 30 min. time delay (in seconds in test mode)
- Fault output off

- Circuit x discharge temperature fault relay on optional board in Off position
- Circuit fault LED on console **flashes**.

➤ Display:

```
D . T E M P   F A U L T   C x   x x m n
x   C U T ( S )   I N   2 4 H
```

If this fault causes shutdowns in 24 hours:

more than 5

- Corresponding circuit shut off.
- Fault output on
- Circuit x discharge temperature fault relay on optional board

- in On position
- Circuit fault LED on console lit **steady**

➤ Display:

```
C I R C U I T   X   O F F
D I S C H A R G E   F A U L T
```

➤ Saved in fault

memory:

```
x - D I S C H . T .   C I R C U I T x
```

➤ Resetting:

- If the number of faults in 24 hours ≤ 5 → the fault is acknowledged after 30 minutes.
- If the number of faults in 24 hours > 5 → the fault is acknowledged if DISCH.T. $\leq P51 - 15^\circ\text{C}$ and **Reset** is pressed on the console.

15.5 LP fault on circuit 1 or 2

➤ Operation:

- If the pressure measured by the LP pressure sensor is $\leq P55$, the controller records an LP fault.
- This input is checked 2 minutes after the first stage on the circuit is turned on. It is also checked when power is shut off but ignored both during and 2 minutes after defrosting.
- Both of these time delays are maintained in test mode.

If this fault causes fewer than 3 shutdowns in 24 hours:

- Corresponding circuit shut off.
- Fault output off

- Circuit x LP fault relay on optional board in Off position
- Circuit fault LED on console **flashes**

➤ Display:

```
C I R C U I T   x   L P   F A U L T
x   C U T ( S )   I N   2 4 H
```

If this fault causes more than 3 shutdowns in 24 hours:

- Corresponding circuit shut off.
- Fault output on

- Circuit x LP fault relay on optional board in On position
- Circuit fault LED on console lit **steady**

➤ Display:

```
C I R C U I T   X   O F F
L P   F A U L T
```

➤ Saved in fault memory:

X . C I R C U I T X L P

➤ Resetting:

- If the number of faults in 24 hours ≤ 3 → the fault is automatically acknowledged if BP > P55 + 2b.
- If the number of faults in 24 hours > 3 → the fault is acknowledged if BP > P55 + 2b and **Reset** is pressed on the console.

If a fault occurs on the sensor on the open circuit, the fault is preceded in the fault memory by an LP fault.

Special case for reversible machines and water chilling: the fault threshold switches to P55+1 b and normal operation is restored if BP > P55 + 3 b.

Special case for reversible machines and water heating:

Defrosting is forced on when the LP is < P55 for 1 minute.

If defrosting is forced on 3 times in 1 hour, the circuit with a LP fault is turned off the fourth time the LP drops below P55.

15.6 Management of superheat faults

The superheat temperature on the suction end of each circuit can be monitored by comparing the LP saturation temperature to the suction temperature.

This protection is enabled by setting P43 to 'Yes' (No by default). It protects the compressor(s) from excessively low or high superheat values. If superheat protection = Yes → This function is turned on when at least the first control stage (per circuit) is on and 5 minutes after the first stage is turned on.

Minimum superheat fault:

- If the superheat value (P307 or P337) drops below the minimum superheat limit value (P44) for 1 minute, the circuit is shut off and the minimum superheat error message is displayed.
- The unit automatically restarts after 5 minutes (5 seconds in test mode).
- This function remains on in test mode.

➤ Display:

M I N S U P E R H E A T F A U L T C X
X C U T (S) I N 1 H

If there are more than 3 cuts in 1 hour

The unit is turned off by the superheat protection. The **Reset** button must be pressed in order to restart the circuit.

➤ Display:

C I R C U I T X O F F
M I N . S U P E R H E A T F A U L T

Maximum superheat fault:

- If the superheat value (P307 or P337) rises above the maximum superheat limit value (P45) for 1 minute and the evaporating temperature < 15°C, the circuit is shut off and the maximum superheat error message is displayed.
- This function is turned off during defrosting.
- The unit automatically restarts after 5 minutes (5 seconds in test mode).
- This function remains on in test mode.

➤ Display:

M A X S U P E R H E A T F A U L T C X
X C U T (S) I N 1 H

If there are more than 3 cuts in 1 hour, the unit is turned off by the maximum superheat protection and the **Reset** button must be pressed in order to restart the circuit.

➤ Display:

C I R C U I T X O F F
M A X . S U P E R H E A T F A U L T

➤ If a permanent fault occurs:

- Fault stored in memory in case of a mains power failure
- Fault saved in fault memory
- Relay in On position

➤ If a temporary fault occurs:

- Fault not stored in memory if a mains power failure occurs
- Fault saved in fault memory
- The minimum or maximum superheat fault relay on the relay board is in the Off position
- During test mode, the time delays are counted down in seconds, not minutes.

➤ Messages in the fault memory:

C X M I N . O V E R H E A T

C X M A X . O V E R H E A T

16 CONTROLS

16.1 Main control in cooling and heating modes

Definition and principle:

The chilled water and hot water temperatures are measured and compared with the setpoint value. Depending on the result, the compressor stages are turned on or off. This check is performed on the heat exchanger's water outlet (water supply = PID_T) or water inlet (water return).

16.1.1 Operating mode selection (P119):

- If P119 = 1 (Cooling)

Cooling only.

- If P119 = 2 (Heating)

Heating only

- If P119 = 3 (Cooling/Heating via console)

The operating mode can be changed only with the machine stopped (automatic operation control input set to on, On/Off button).

The Heating/Cooling button will be disabled if it is pressed while the machine is running.

- If P119 = 4 (Cooling/Heating via on/off input)

The operating mode can be changed only with the machine stopped (automatic operation control input set to on, On/Off button).

Attempting to change the operating mode while the machine is running will result in a fault:

. Machine stopped.

. General fault LED on.

. Machine fault relay in On position.

. Initial operating mode LED flashes

```

M A C H I N E   O F F
O P E R A T I N G   M O D E   C H A N G E
    
```

Automatic reset:

- Either the machine changes its operating mode if the change is confirmed by pressing On/Off or if the automatic operation control input is open;

- Or it resumes its initial operating mode if the input is restored to its initial value.

If P119 = 5, the machine switches between heating and cooling depending on the outdoor temperature:

- This function is visible only if P2 = reversible air-to-water

- When this function is turned on, the minimum heating limit and the maximum cooling limit (depending on the outdoor temperature) are re-enabled and are set to the following values:

. For a minimum air temperature of -10°C if P7 ≠ INVERTER

-20°C if P7 = INVERTER

. For a maximum air temperature of 46°C.


However, they can be disabled.

```

P 1 3 6   M A X   A I R   T E M P .
A U T O   H E A T I N G   M O D E   - x x
    
```

```

P 1 3 7   M I N   A I R   T E M P .
A U T O   C O O L I N G   M O D E   - x x
    
```



- When an operating mode reaches its end temperature setpoint in automatic mode, the following message is displayed until a mode is turned on:

```

D E A D   B A N D   A U T O
H E A T I N G / C O O L I N G
    
```

The two heating and cooling LEDs flash while this message is displayed.
The pump is shut off in the deadband.

16.2 Water temperature setpoint adjustment

The control mode is set using parameter P141.

Value 1: set to water return.

Value 2: set to water supply.

Value 3: set to water supply with compensation by water return.

Setpoint 2 allows a similar shift if control adjusted based on the outdoor air (If P127 = Yes or P131 = Yes) or allows the control mode to be changed if P54 (storage) = Yes.

16.3 Adjustment of water temperature setpoint if P7 ≠ INVERTER

16.3.1 Water return control (P141 = 1):

The temperature used to adjust the setpoint is measured by:

- the inlet sensor on heat exchanger 1 if P2 = air-to-water or reversible air-to-water, if P2 = water-to-water and cooling mode,
- the hot water sensor if P2 = water-to-water and heating mode.

The difference between the control temperature the setpoint is compared to the stage differential and the interstage differential. Depending on the result, it will be necessary to either turn on an additional stage or to turn one off.

Each stage is turned on at 60-second intervals and the shut off at 1-second intervals.

The related parameters are as follows:

P143: Stage differential

P251: Control setpoint

P144: Interstage differential

➤ In cooling mode:

- A call is made for an additional stage if $T > \text{Setpoint} + \text{SD} + (\text{ISD} \times \text{NSO})$
- A call is made to stop a stage if $T < \text{Setpoint} + (\text{ISD} \times \text{NSO} - 1)$

Where:

T: Control temperature (measured).

ISD: Interstage Differential (P144)

STP: Setpoint


NSO: Number of Stages On

SD: Stage Differential (P143)

Example: Two-stage water chiller

Parameter settings: STP = 10°C, SD = 2 K, ISD = 1.5 K

Stage 1		Stage 2	
On	Off	On	Off
12	10	13.5	11.5



➤ In heating mode:

- A call is made for an additional stage if $T < \text{STP} - \text{SD} - (\text{ISD} \times \text{NSO})$
- A call is made to stop a stage if $T > \text{STP} - (\text{ISD} \times \text{NSO} - 1)$

Where:

T: Control temperature (measured).

ISD: Interstage Differential (P144)

STP: Setpoint


NSO: Number of Stages On

SD: Stage Differential (P143)

Example: Two-stage water heater for a water temperature range of 35-40°C.

Parameter settings: STP = 40°C, SD = 2 K, ISD = 1.5 K.

Stage 1		Stage 2	
On	Off	On	Off
38	40	36.5	38.5



R	E	T	U	R	N	T	E	M	P	.	:	-	x	x	.	x	°
S	E	T	P	O	I	N	T	:	:	-	x	x	.	x	°		

16.3.2 Water supply control (P141 = 2)

If heating mode is selected with a water-to-water unit, the setpoint is adjusted based on the temperature measured by the hot water supply sensor. If cooling mode is selected and P6 = 1, the setpoint is adjusted based on the temperature measured by the heat exchanger outlet sensor. If P6 = 2 in the same mode, it is adjusted based on the temperature measured by the manifold sensor.

The type of control used is PID_T.

The temperature is measured periodically (τ) then compared to the setpoint and multiplied by a proportional coefficient (P) -- taking into account the difference between the measurement and the setpoint (D) and the change in the difference between the measurement and the setpoint (I) -- in order to approach the setpoint quickly.

Formula: $DV = P (M-S) t1 + \Sigma (M-S)*I + [(M-S) t0 - (M-S) t1]*D$

M = Measurement, S = Setpoint.

When P146 = 0 and P147 = 0 (standard setting), the PID_T function becomes PT (the Integral and Derivative functions are disabled)

The related parameters are as follows:

- P251: Calculated setpoint
- P121: Setpoint 1 in cooling mode
- P123: Setpoint 1 in heating mode
- P145: P coefficient
- P146: I coefficient
- P147: D coefficient
- P148: T coefficient

➤ In cooling mode:

A call is made for an additional stage if:
 DV > +1.0 K for the first stage and +0.5 K for the additional stages.

A call is made to turn off a stage if:
 DV < -0.5 K for a stage and -1.0 K for the last stage.

Example: Two-stage unit with a 5°C setpoint, where D = 0 and I = 0.

P	Stage 1		Stage 2		Stage 1
	Off	On	Off	On	
0.5	3	4	6	7	
1	4	4.5	5.5	6	
1.5	4.33	4.66	5.33	5.66	
2	4.5	4.75	5.25	5.5	

➤ In heating mode:

A call is made for an additional stage if:
 DV < -1.0 K for the first stage and -0.5 K for the additional stages.

A call is made to turn off a stage if:
 DV > +0.5 K for a stage and +1.0 K for the last stage.

Example: Two-stage unit with a 45°C setpoint. I = 0 and D = 0.

P	Stage 1		Stage 2		Stage 1
	On	Off	On	Off	
0.5	43	44	46	47	
1	44	44.5	45.5	46	
1.5	44.34	44.66	45.33	45.66	
2	44.5	44.75	45.25	45.9	

S	U	P	P	L	Y	T	E	M	P	.	:	-	x	x	.	x	°
S	E	T	P	O	I	N	T	.	:	-	x	x	.	x	°		

16.3.3 Adjusting the setpoint to the water supply with compensation on the water return (P141 = 3):

➤ Aim:

Allow the control system to anticipate changes in load on the loop by monitoring for variations in the water inlet temperature.

➤ Action:

Adjusts the controller time delay.

➤ Principle:

The water return temperature is measured: θt0; evaporator in cooling mode, condenser in heating mode at time t0 then t0 + P151.

The calculated temperature variation [θt1 - θt0] is used to define the compensator coefficient.

The PID control polling time then becomes: remaining time x compensator coefficient.


Configuring the compensator coefficient: The compensator coefficient can be set to between 0.1 and 1 (parameter P150).

- If the compensator coefficient = 1 → the function is disabled.


- If the water return temperature variation < 0.5°C → no compensation.

The compensator coefficient is maximum when the temperature variation = 10°C between each time. α.

➤ Compensator coefficient diagram:



Example with a compensation factor of 0.5
 Controller time delay P148 = 100 seconds
 Compensation time = 10 seconds



A: 1st compensation result. The controller's remaining time is $(100 - 10 = 90 \text{ seconds}) \times 0.5 = 45 \text{ seconds}$.
B: 2nd compensation result. The controller's remaining time is $(45 - 10 = 35 \text{ seconds}) \times 0.5 = 17.5 \text{ seconds}$

C: 3rd compensation result. The controller's remaining time is $(17.5 - 10 = 7.5 \text{ seconds}) \times 0.5 = 3.75 \text{ seconds}$.
R = 0: Moment when the controller's time delay = 0.
 The two time delays are resynchronised at this moment.

The related parameters are as follows:

P145: P coefficient
 P146: I coefficient
 P147: D coefficient

P148: T coefficient (polling time)
 P150: Minimum compensation setpoint
 P151: Compensation time

S	U	P	P	L	Y	T	E	M	P	.	:	-	x	x	.	x	°
S	E	T	P	O	I	N	T			:	:	-	x	x	.	x	°

16.4 Adjustment of setpoint for the water supply and return temperatures (P141 = 1 or 2) if P7 = INVERTER

The difference between the control temperature the setpoint is compared to the stage differential and the interstage differential. Depending on the result, it will be necessary to either turn on the compressor and increase its speed or to decrease its speed and turn it off.

➤ In cooling mode

- A call will be made to turn on the compressor if: $T > STP + \text{Stage differential}$
- The compressor rotation speed will be progressively increased if $(STP + \text{Stage differential}) < T < (STP + \text{Stage differential} + \text{Interstage differential})$

Conversely, the compressor speed will be progressively decreased as the water return temperature approaches the setpoint value.

- The compressor will be shut off when $T < STP$


➤ In heating mode

- A call will be made to turn on the compressor if $T < STP + \text{Stage differential}$
- The compressor rotation speed will be progressively increased if $(STP - \text{Stage differential} - \text{Interstage differential}) < T < (STP - \text{Stage differential})$
- The compressor will be shut off as soon as $T > STP$


Conversely, the compressor speed will be progressively decreased as the water return temperature approaches the setpoint value

The temperature used to adjust the setpoint is measured by the sensor on the water outlet or inlet of the heat exchanger based on the value of P141.

➤ In cooling mode:



➤ In heating mode:



➤ Correction management:

Correction is enabled if P7 = Inverter and if P141 = supply and return.

The correction factor is used to prevent the compressor from running during short-cycle protection and too-short runtimes caused by a lack of inertia in the system.

The correction factor On/Off button is set to '0' at power-up.

16.5 Storage control


If P154 = No → The control mode remains standard and may be adjusted to the return or supply line depending on the value of P141 (control mode).

If P154 = Yes → Storage control is enabled. The control mode is managed based on the setpoint selected:

This type of control makes it possible to generate maximum capacity at a given time, often when electricity is cheapest.

- One after the other, the compressor stages turn on in 10-second intervals at value P122 + P155. When P122 is reached, the stages are shut off at the rate of one per second.
- The setpoint 2 LED lights up.
- All limits are maintained.

- If setpoint 1 is selected, the control remains standard and the mode (supply or return) is selected by P141 (control mode).
- If setpoint 2 is selected, the control automatically switches to 'return with storage' mode.



NOTE: Control based on the outdoor temperature is not available if setpoint 2 is selected. It is, however, available with setpoint 1. This operating mode is available in cooling mode only.

R	E	T	U	R	N	T	E	M	P	.	-	x	x	.	x	°
S	E	T	P	O	I	N	T			:	-	x	x	.	x	°

16.6 Control setpoint (P251) management

16.6.1 If P142 (water loop winter protection) = No:

• If P120 (setpoint No.) = 1

➤ In cooling mode:

If P127 cooling setpoint adjustment = f (outdoor temperature) = 0 or outdoor sensor fault; Control setpoint = P121

If P127 = 1 and no fault on outdoor sensor, setpoint f (outdoor temperature) is calculated using P121.

➤ In heating mode:

If P131 heating setpoint adjustment = f (outdoor temperature) = 0 or outdoor sensor fault; Control setpoint = P123

If P131 = 1 and no fault on outdoor sensor, setpoint f (outdoor temperature) is calculated using P123.

• If P120 (setpoint No.) = 2 selected via console

➤ In cooling mode:

If P127 cooling setpoint adjustment = f (outdoor temperature) = 0 or outdoor sensor fault; Control setpoint = P121 or P122 depending on selection on console

If P127 = 1 and no fault on outdoor sensor; Setpoint f (outdoor temperature) is calculated using P121 or P122 based on the selection made via the console.

➤ In heating mode:

If P131 heating setpoint adjustment = f (outdoor temperature) = 0 or outdoor sensor fault; Control setpoint = P123 or P124 depending on selection on console

If P131 = 1 and no fault on outdoor sensor; Setpoint f (outdoor temperature) is calculated using P123 or P124 based on the selection made via the console.

• If P120 (setpoint No.) = 2 selected via on/off input

The on/off input corresponds to terminals 4-5 on terminal block J6 on the motherboard.

➤ In cooling mode:

If P127 cooling setpoint adjustment = f (outdoor temperature) = 0 or outdoor sensor fault; Control setpoint = P121 if on/off input open; P122 if on/off input closed.

If P127 = 1 and no fault on outdoor sensor:

- Setpoint f (outdoor temperature) is calculated using P121 if the on/off input is open.

- Setpoint f (outdoor temperature) is calculated using P122 if the on/off input is closed.

➤ In heating mode:

If P131 = 0 or outdoor sensor fault; control setpoint = P123 if on/off input open; P124 if on/off input closed.

If P131 heating setpoint adjustment = f (outdoor temperature) = 1 and no fault on outdoor sensor:

- Setpoint f (outdoor temperature) is calculated using P123 if the on/off input is open.

- Setpoint f (outdoor temperature) is calculated using P124 if the on/off input is closed.

16.6.2 If P142 (water loop winter protection) = Yes and automatic operation control input open:

The control setpoint = 30°C.

16.6.3. Management of the setpoint based on the outdoor temperature:

P127 cooling setpoint adjustment = f (outdoor temperature) or P131 heating setpoint adjustment = f (outdoor temperature) = 1

This control is used to adjust the cooling or heating setpoint based on the outdoor temperature. In either case, the setpoint with the highest value is the one that is adjusted.

NOTE: Minimum setting of 5 K between start and end of setpoint drift.

➤ Slope adjustment in cooling mode

The related parameters are as follows:

P121: Cooling setpoint 1


P122: Cooling setpoint 2

P128: Outdoor temperature at start of drift in cooling mode


P129: Outdoor temperature at end of drift in cooling mode

P130: Maximum setpoint at end of drift in cooling mode

P251 setpoint



P251 setpoint



➤ Slope adjustment in heating mode

The related parameters are as follows:

P123: heating setpoint 1


P124: heating setpoint 2

P132: Outdoor temperature at start of drift in heating mode

P133: Outdoor temperature at end of drift in heating mode

P134: Maximum setpoint at end of drift in heating mode

P251 setpoint



16.7 Automated self-regulating control

If the compressor runtime drops below 3 minutes, the stage differential is increased by 1.0 K for control on the return line (maximum value of 7.0 K). For control on the supply line, the calculated difference is changed by 1.0 K in order to delay the starting of the compressor. The maximum shift value is 7.0 K for the first stage and 6.5 K for the following stages.

The following message appears:

```

S E L F - R E G U L A T I N G
C O N T R O L   M O D E
    
```

If the compressor runtime rises above 5 minutes and the automated self-regulating control is on, the stage differential for the control on the return line is lowered by 1.0 K until the initial values are reached.

For control on the supply line, the calculated difference by 1.0 K is changed in order to hasten the starting of the compressor until the initial values are reached.

The function is disabled if the initial values are reached, if the unit is turned off (via On/Off button on console or automatic operation control on with winter water loop protection off), if a unit fault occurs, if parameter P141 (control mode) is changed and if a power failure occurs.

16.8 Control with AEROCONNECT link in FREE COOLING mode

The thermodynamic unit can control only the cooling return line because the FREE COOLING module driven by AEROCONNECT adjusts the cooling capacity using its own return line sensor and by retrieving the setpoint set by CONNECT.

17 CONTROL OF CONDENSING PRESSURE FOR AIR-COOLED UNITS

17.1 Control during normal operation or on/off control

➤ In heating mode:

All the fan stages are turned on at maximum speed:

- Once a compressor stage is running on the unit when P11 = intertwined
- Once a compressor stage is running on the circuit when P11 = split.

➤ In cooling mode:


- Control mode is turned on as soon as a compressor stage is running on the circuit.

A) On/Off, where P21 (variable speed control) = No, P10 = Propeller and P11 = Split

The fans turn on once the compressor on the corresponding circuit starts up.

P180 = 2 or 3 corresponds to 2 or 3 fan stages per circuit.


- Fan 1 on circuit 1 will be controlled by stage 1, motherboard terminal block J3 (terminal 5)
- Fan 2 on circuit 1 will be controlled by stage 2, motherboard terminal block J3 (terminal 6)
- Fan 1 on circuit 2 will be controlled by stage 1 on circuit 2, ADD 2 board terminal block J3 (terminal 5)
- Fan 2 on circuit 2 will be controlled by stage 2 on circuit 2, ADD 2 board terminal block J3 (terminal 6)



1 condenser fan module per circuit = 2 single-phase stages

1er = stage 1, 2ème = stage 2,
DEE = Interstage differential


- The two fans 1 on circuit 1 will be controlled by stage 1 on circuit 1, motherboard terminal block J3 (terminal 5)
- Fan 2 on circuit 1 will be controlled by stage 2 on circuit 1, motherboard terminal block J3 (terminal 6)
- Fan 3 on circuit 1 will be controlled by stage 3 on circuit 1, ADD 2 board terminal block J3 (terminal 7)
- The two fans 1 on circuit 2 will be controlled by stage 1 on circuit 2, ADD 2 board terminal block J3 (terminal 5)
- Fan 2 on circuit 2 will be controlled by stage 2 on circuit 2, ADD 2 board terminal block J3 (terminal 6)
- Fan 3 on circuit 2 will be controlled by stage 3 on circuit 2, ADD 2 board terminal block J3 (terminal 8)



B) On/Off, where (P21 = No), P10 = propeller and P11 = intertwined

- Control mode is turned on as soon as a compressor stage is running on the unit.
 - If one of the two circuits is shut off (by a temporary or permanent fault, or control fault or other fault), the fan continues to operate using the pressure from the circuit this is still on.
- When both refrigerating circuits are on, the fans are turned on and off by the circuit with the highest pressure.


Fan 1 will be controlled by stage 1, motherboard terminal block J3 (terminal 5)
 Fan 2 will be controlled by stage 2, motherboard terminal block J3 (terminal 6)



1er = stage 1,
 2ème = stage 2,
 3ème = stage 3,
 4ème = stage 4


C) On/Off, where (P21 = No), P10 = propeller and P11 = intertwined

- Control mode is turned on as soon as a compressor stage is running on the unit.
- Stages 1 and 2 are controlled by each circuit.
- Common stage 1 is turned on as soon as the first control stage for circuits 1 and 2 is turned on.
- Common stage 3 is turned on as soon as the third control stage for circuits 1 and 2 is turned on.



Fan 1 on circuit 1 will be controlled by stage 1, motherboard terminal block J3 (terminal 5)
 Fan 2 on circuit 1 will be controlled by stage 2, motherboard terminal block J3 (terminal 6)
 Fan 1 on circuit 2 will be controlled by stage 1 on circuit 2, ADD 2 board terminal block J3 (terminal 5)

Fan 2 on circuit 2 will be controlled by stage 2 on circuit 2, ADD 2 board terminal block J3 (terminal 6)
 "Common" fan 1 will be controlled by common stage 1, ADD 2 board terminal block J3 (terminal 7)
 "Common" fan 3 will be controlled by common stage 3, ADD 2 board terminal block J3 (terminal 8)



17.2 Forced and self-adjusting control

The condensing pressure control can be forced in cooling mode in two cases:

Case 1: If $HP > P54 - P195 - 0.5$, the fans run at maximum speed for 30 minutes and the stages turn on at 1-second intervals. This 30-minute runtime applies in case 2 as well.

- If intertwined coils are used, the first fan is turned on by the sensor that reads the highest value.
- If split coils are used, the function is managed by each circuit.
- If mixed coils are used, fans 1 and 2 are managed by each circuit. In the case of common fans 1 and 3, they are turned on by the sensor that reads the highest value.

Case 2: Management of control stage 1 (case of propeller fans with on/off control).

If fan stage 1 turns on more than 5 times in 10 minutes while the other stages are off, increase the stage differential by 4.5 b to shut off the other stages. Normal control mode resumes (extra 4.5 b pressure eliminated and other stages allowed to turn on) if $HP > P54 - P195 - P196$ or if $HP > P181 + P183$ for 10 minutes.

If the common fan 1 stage (common to both circuits) turns on more than 5 times in 10 minutes and the other higher stages on both circuits are off, increase the stage differential by 4.5 b on both circuits.

The following message appears when P11 = split and mixed if stage 1 or 4 turns on more than 5 times in 10 minutes:

```

H P X   P R E S S U R E   C O N T R O L
S T A G E   1   O N L Y
    
```

The following message appears when P11 = intertwined and mixed if stage 3 turns on more than 5 times in 10 minutes:

```

H P   P R E S S U R E   C O N T R O L
S T A G E   1   O N L Y
    
```

17.3 Fan speed control

The speed of the fans is controlled by the HP pressure sensor and the 0-10 V outputs on the motherboard and additional board 2. This control functions in cooling mode only in order to reduce the sound level of the units. In heating mode, the fans run at maximum speed once a compressor stage turns on.

If $P21 = 2$ or 3 (speed control with energy or acoustic optimisation) the speed of fan 1 on each circuit will be controlled; the other fans will be adjusted to P180 by the on/off inputs.

The moment the fan starts in speed control mode and the moment the other stages are turned on must be separated by an interval of 3 seconds.

Variable speed drive (VSD):

In order for it to adjust the speed based on the 0-10 V signal, the variable speed drive selected must first be supplied electrically and informed of the direction of rotation.

➤ VSD power supply:

Power will be supplied, via the power contactors, by the control for fan 1 on circuit 1 (terminal 5 on terminal block J3), the control for fan 1 on circuit 2 (terminal 6 on terminal block J3 on additional card 2) and the control for fan 1 common to both circuits (terminal 5 on terminal block J3 on additional board 2).

In both **heating** and **cooling** mode, these three outputs must be powered as soon as the unit is turned on by pressing the **On/Off** button on the console or by turning off the Automatic Operation control. They will shut off after the Automatic Operation control is turned on or if the **On/Off** button on the console is pressed.

➤ Authorisation of VSD operation:

External VSDs (ALTIVAR) will not be controlled by the software. Instead, they will be controlled electromechanically via two auxiliary relays on the KGs of the compressors (as soon as a compressor turns on, the associated relay sends the information to the VSD). As a result, running the VSDs without the compressors will not be possible.

In the case of electronically commutated fans (built-in variable speed drive), authorisation for the VSDs to turn on is given by the board when the fan contactor outputs are in the On position (no relay needed).

17.3.1 Fan speed control with split coils (P11 = split):

This configuration requires a variable speed drive for each circuit.


- 0-10 V output, stage 1, circuit 1, terminals 1-2 on motherboard terminal block J2
- 0-10 V output, stage 1, circuit 2, terminals 2-1 on terminal block J6 of additional board 2

Speed control mode is turned on as soon as the circuit is on.

a) P21 = 2 with acoustic optimisation


1 condenser fan module per circuit = 1 stage (1 fan) with speed control + 1 single-speed stage (same as standard)

2 condenser fan modules per circuit = 1 stage (2 fans) with speed control + 2 single-speed stages (same as standard)



1er: stage 1, 2ème: stage 2
3ème: stage 3,
DEE = Interstage differential

b) P21 = 3 with energy optimisation (Available only if P42 = ALCO or CIAT)



If P180 = 3 stages: 15-30% and 70-85% for stages 2-3

If P180 = 2 stages: 20 and 80% for stage 2

The values of P181 and P183 must be set.

P181 = 17.8 b for R410A, 12 b for R407C, 11.0 b for R22 and

6.8 b for R134a

P183 = 7.8 b for R410A or 5.5 b for R407C, 5.0 b for R22 and 3.8 b for R134a

In this case parameters P181 and P183 can be adjusted (resolution of 0.1) and parameter P184 becomes needless and therefore inaccessible.

The minimum value of P181 becomes 16 bar for R410A.

The minimum value of P183 becomes 8 bar for R410A.


17.3.2 Fan speed control with intertwined coils (P11 = intertwined):

Speed control mode is turned on as soon as the unit is on.

With 1 circuit running: speed is controlled by the circuit's HP sensor.

With 2 circuits running: the speed is controlled by the sensor with the highest pressure.

a) P21 = 2 with acoustic optimisation




1er: stage 1

2ème: stage 2

3ème: stage 3

4ème: stage 4

b) P21 = 3 with energy optimisation (Available only if P42 = ALCO or CIAT)



If P180 = 4 stages: 10-25-40% and 60-75-90% for stages 2-3-4

If P180 = 3 stages: 15-30% and 70-85% for stages 2-3

If P180 = 2 stages: 20 and 80% for stage 2

The values of P181 and P183 must be set.

P181 = 17.8 b for R410A, 12 b for R407C, 11 b for R22 and 6.8 for R134a

P183 = 7.8b for R410A or 5.5b for R407C, 5.0b for R22 and 3.8 b for R134a

In this case parameters P181 and P183 can be adjusted (resolution of 0.1) and parameter P184 becomes needless and therefore inaccessible.

- The minimum value of P181 becomes 16 bar for R410A.


- The minimum value of P183 becomes 8 bar for R410A.

17.3.3 Fan speed control with mixed coils (P11 = mixed)

- 0-10 V output, stage 1, circuit 1, terminals 1-2 on motherboard terminal block J2
- 0-10 V output, stage 1, circuit 2, terminals 2-1 on terminal block J6 of additional board 2
- 0-10 V output, stage 1 common to circuits 1 and 2, terminals 2-3

- of terminal block J6 of additional boards 2
- Common stage 1 is controlled by the highest value of the two signals on circuits 1 and 2
- Common stage 3 is turned on as soon as the third control stage for circuits 1 and 2 is turned on.


a) P21 = 2 with acoustic optimisation



b) P21 = 3 with energy optimisation (Available only if P42 = ALCO or CIAT)

- If P180 = 3 stages: 15-30% and 70-85% for stages 2-3
- If P180 = 2 stages: 20 and 80% for stage 2
- The values of P181 and P183 must be set.
- P181 = 17.8 b if R410A, 12 b if R407C, 11.0 b if R22 and 6.8 b if R134a
- P183 = 7.8 b if R410A or 5.5 b if R407C, 5.0 b if R22 and 3.8 b if R134a

- In this case parameters P181 and P183 can be adjusted (resolution of 0.1) and parameter P184 becomes needless and therefore inaccessible.
- The minimum value of P181 becomes 16 bar for R410A.
- The minimum value of P183 becomes 8 bar for R410A.




17.3.4 Fan speed control if P7 = INVERTER:

- The rotation speed is limited by parameter P192 (default value of 7.8 V). It can be set at between 5 and 10 V (resolution of 0.1 V).
- If P7 = Inverter, the standard setting value of P181 becomes 13.4 bar as long as LP < 8.3 bar.
- If the LP rises above this value, the HP control setpoint becomes equal to P181 + 4.4 bar.
- The HP control setpoint returns to P181 when the LP drops to < 7.8 bar.
- The maximum shift in the HP STP is 33.9 bar (recovery function included).

17.3.5 Forced control of variable-speed fans:

- The condensing pressure control can be forced in cooling mode in two cases:
- If $HP > P54 - P195 - 0.5$, the fans run at maximum speed for 30 minutes and the stages turn on at 3-second intervals.
- During defrosting in order to defrost the coils as quickly as

- possible. The HP will have to be as high as possible without turning on the protections.
- Parameter P166 (3 by default) is used to adjust the fan control.



Adjustment adopted during defrosting (once the cycle has been reversed by the reversing valve). The other fans are off during this time.

17.3.6 Speed control of centrifugal fans (P10 = Centrifugal):

P21 is hidden. This configuration is not available. The HP is controlled via the air blades. Refer to the section on controlling the air blades.

17.3.7 Speed control of electronically commutated pressure fans (P10 = Pressure):

This function provides the same functionalities as the variable speed drive described above with the added possibility of allowing the customer to limit the speed of the fans in order to lower the sound level or best adjust the available pressure..

This function is enabled when:

P10 = pressure P2 = Air-to-Water or Reversible Air-to-Water,
P180 (No. of HP control stages) = 1 = hidden,

P21 (speed control) = 2 hidden,
P181 and P183 = visible and P11 (coil type) visible.

In cooling mode, the speed is controlled by the HP pressure sensor and the 0-10 V outputs on the main board. In heating mode, the fans run at maximum speed once a compressor stage turns on.

If several electronically controlled fans are on the same circuit, the 0-10 V supplies must be wired in series (two maximum).


The speed of the fans is limited by parameter P192 which is set by default to 8 V but may be adjusted to between 5 and 10 V in increments of 0.5 V.

Control:

Regardless of the value of P11, the control system is on as soon as a compressor stage is on.

- Two circuits used: The fans are controlled in response to the highest pressure read by either sensor on the two circuits. The fans are controlled simultaneously.

- One circuit used: The fans are controlled in response to the high pressure on the circuit.



The cases for forced control and control during defrosting are the same as those described in section 17.3.5.

17.4 Low Noise control (single-fan units only – Aquaciat2)

This function is available only on single-fan units, i.e. if P180 = 1. To see if the function is enabled, go to parameter P191 (Low Noise operation), which is set to 'Yes' by default. Visible only if P180 = 1.

This function disappears if a variable speed drive is used (P21 = Yes).

The fan must be shut off when switching from LS to HS and back. To do so, open contact J3, terminal 2 before actuating J3, terminal 3.

LS is obtained by energising fan relay 1 (terminal 2 on terminal block J3) and fan relay 2 remains open.

HS is obtained by energising fan relay 2 (terminal 3 on terminal block J3) and fan relay 1 remains open.

➤ In cooling mode:

- If P191 (LOW NOISE) = Yes:

As long as $HP < P54 - P195 - 3 b$, low speed must remain on. When the HP rises above this value, shift to high speed (cut off terminal 2, terminal block J3; cut off terminal 3 on terminal block J3; restore terminal 2 on terminal block J3). LS is resumed when $HP < P54 - P195 - 7 b$.

- If P191 (LOW NOISE) = No:

The system must be switched to high speed very quickly in order to deliver a maximum amount of power to the customer.

- If $HP > P181 + P183$, turn on LS

- If $HP > P181 + P183 + P184$, turn on HS

The system does not switch to LS before turning off. It is shut off when $HP = P181$.

- Forced and self-adjusting control:

Case1: On if P64 (optimised frost protection) = No

- If $HP > P54 - P195 - 0.5$, the fans are already running at HS unless the frost limiter on the water or refrigerant line is on. In this case, remain at LS and let the HP protection do its job.

Case2: Regardless of the value of P191

- If the fan turns on more than 5 times in 10 minutes, increase the stage differential by 4.5 b. Normal control mode resumes (extra 4.5 b pressure eliminated) if $HP > P54 - P195 - P196$ or if $HP > P181 + P183$ for 10 minutes.

The following message appears when P180 = 1 and stage 1 turns on more than 5 times in 10 minutes:

```
P R E S S U R E   C O N T R O L
H P   S H I F T E D
```

➤ In heating mode:

The fan runs at HS.

17.5 Total recovery control

The total recovery function and its associated parameters (P29 and P193) are accessible only if P2 = air-to-water:

```
P 2 9   T O T A L
R E C O V E R Y           N O
```

- P193 visible If P29 = Yes

P 1 9 3 H P S T P S H I F T
D U R I N G R E C O V E R Y

Recovery input (10/11 on J6) will be used by the customer to define the operating mode: STANDARD or RECOVERY

Two operating modes are possible if parameter P29 = Yes:

Contact J6 - 10/11 on motherboard **open** without recovery:
- Standard fans controlled based on the values of P10, P20 and P21

B) Contact J6 - 10/11 motherboard **closed** with recovery:
- The turning-on of the fans is shifted using parameter P193 → The HP control setpoint then becomes equal to P181 + P193
- The control logic will then be identical to standard control using the values of P10, P20 and P21.

17.6 Management of the air blades if P10 = Centrifugal

This "all season" option will be offered for air-to-water units with centrifugal fans.

- If P20 = Yes:

• **Heating mode:** The centrifugal fan starts up 3 seconds after the compressor, regardless of the HP1 and HP2 values.

The fan is turned off during defrosting

• **Cooling mode:** The air blades are controlled by the 0-10 V output (terminals 1-2 on terminal block J2 on motherboard) as shown below:




	Diagram 1		Diagram 2	
	Value A	Value B	Value C	Value D
R22/R407C	12b	16b	19b	23b
R134a	7.5b	10.5b	12.5b	15.5b
R404a	14b	18b	20b	23b
R410a	20b	25b	30b	37b

⇒ One-circuit unit (or fault on one circuit of a two-circuit unit):
Adjust as shown in diagram 1.

⇒ Two-circuit unit and if the compressor on circuit 2 running for at least 5 seconds:

- If HP1 or HP2 < A → Control shown in diagram 1 and taking into account the sensor with the lowest pressure.
- If A < (HP1 and HP2) < C → Control shown in diagram 1 and taking into account the sensor with the lowest pressure.
- If HP1 or HP2 > C → Control shown in diagram 2 and comparison of:

- . Voltage U1 = Diagram 1 (lowest HP)
- . Voltage U2 = Diagram 2 (highest HP)

And voltage U adjusted to highest value of U1 and U2.

- If HP1 and HP2 > C → Control shown in diagram 1 and taking into account the sensor with the highest pressure.

- P20 = No:

Output = 0 V

18 CONTROL OF CONDENSING PRESSURE FOR WATER-TO-WATER UNITS

1) Operation with a two-way valve

If municipal wastewater is used to cool the condenser, we recommend installing the two-way valve so as to be able to set the condensing pressure to a value that will ensure correct operation of the unit and save on cooling water.

Set P26 to 'two-way valve'. The valve will open linearly from P197 to P198 based on the high pressure.

For more details, refer to the instruction manual supplied with the kit. To obtain high cooling capacity, set P197 and P198 to their lowest values. To save on water, set P197 and P198 to their highest values.

These adjustments depend solely on your installation. It is essential that you ensure the correct operation of your unit.

2) Operation with a three-way valve

We recommend installing our three-way valve kit if our units are used with cooling towers. This valve will allow you to adjust the condensing pressure better and thus optimise your unit's performance. Set P26 to 'three-way valve'. The valve will open linearly from P197 to P198 based on the water return temperature. For more details, refer to the instruction manual supplied with the kit.

19 RESTRICTION OF OPERATION OF THE MACHINES BASED ON THE OUTDOOR TEMPERATURE

19.1 Restriction to the minimum air temperature in heating mode

```
P 2 2 5 M I N . A I R T E M P .  
I N H E A T I N G M O D E - x x °
```

- This parameter can be set to between -25°C and 5°C in 1°C increments.

- Default setting: -10°C if P119 ≠ Cooling where P2 = 3 reversible air-to-water and P7 ≠ INVERTER -20°C if P119 ≠ Cooling where P2 = 3 reversible air-to-water and P7 = INVERTER

This function is disabled if at least one circuit is being defrosted.

The thermodynamic unit shuts off once the outdoor temperature \leq P225. The auxiliary heaters or the boiler are substituted for the thermodynamic control stages. The (thermodynamic) unit restarts once the temperature rises to above P225 + 2K.

Display in heating mode and if auxiliary electric heater P22 = No and P111 ≠ Boiler:

```
M A C H I N E O F F I N H T G M O D E  
O U T T E M P . T O O L O W
```

➤ If a fault occurs:

- Fault stored in memory in case of a mains power failure
- Fault saved in fault memory

- Relay in On position
- Unit fault LED lit steady.

Display in heating mode and if auxiliary electric heater P22 = Yes:

```
E L E C A U X C T R L  
O U T T E M P . T O O L O W
```

➤ If a fault occurs:

- Fault not stored in memory if a mains power failure occurs
- Fault not saved in memory if a mains power failure occurs

- Fault relay in Off position
- Unit fault LED off.

Display in heating mode and if P111 = Boiler:

```
B O I L E R C O N T R O L  
O U T D O O R T E M P . T O O L O W
```

➤ If a fault occurs:

- Fault not stored in memory if a mains power failure occurs
- Fault not saved in memory if a mains power failure occurs

- Fault relay in Off position
- Unit fault LED off.

- To disable this function:

- Simply press the - button until the maximum value of the parameter appears. Below this value, the following message appears:

```
P 2 2 5 M I N . A I R T E M P .  
I N H T G M O D E D I S A B L E D
```

- To turn off the function, simply press **Enter**.

- To re-enable it, simply enter a value of between -25°C and +5°C and press **Enter**.

19.2 Restriction to the maximum air temperature in cooling mode

Visible only if P2 = air-to-water or reversible air-to-water and cooling mode

```
P 2 2 5 . 1 M A X . A I R T E M P .  
I N C L G M O D E + x x °
```

- This parameter can be set to between 35°C and 50°C in 1°C increments.

- Default setting: DISABLED

The unit shuts off once the outdoor temperature \geq P225.1.

The unit restarts once the temperature rises back to above P225.1- 2K.

➤ Fault message:

```
M A C H I N E   O F F   I N   C L G   M O D E
O U T   T E M P .   T O O   H I G H
```

➤ If a fault occurs:

- Fault stored in memory in case of a mains power failure
- Fault saved in fault memory
- Relay in On position
- Unit fault LED lit steady.

To disable this function:

- Simply press the + button until the maximum value of the parameter appears. Above this value, the following message appears:

```
P 2 2 5 . 1   M A X .   A I R   T E M P .
I N   C L G   M O D E   D I S A B L E D
```

- To turn off the function, simply press **Enter**.
- To re-enable it, simply enter a value of between 35°C and 50°C and press **Enter**.

19-3- Restriction to the maximum air temperature in heating mode:

This function is used to prohibit the machine operating in heating mode when the outdoor temperature rises above a configurable value. This function is disabled if at least one circuit is being defrosted
Visible if P2 = water-to-water and reversible air-to-water when P119 ≠ 1 (Cooling only)

```
P 2 2 5 . 2   M A X .   A I R   T E M P .
I N   H T G   M O D E           - x x °
```

- This parameter can be set to between -5°C and 20°C in 1°C increments.
- Default setting: DISABLED

The unit shuts off once the outdoor temperature \geq P225.2
The unit restarts once the temperature rises back to above P225.2 - 2K.

➤ Display

```
M A C H I N E   O F F   I N   H T G   M O D E
O U T   T E M P .   T O O   H I G H
```

This limit is not managed as a fault if the machine is shut off because of it:

- Not stored in memory if a mains power failure occurs
- Fault not saved in memory
- Fault relay in Off position
- The unit fault LED is off

To disable this function:

- Simply press the + button until the maximum value of the parameter appears. Below this value, the following message appears:

```
P 2 2 5 . 2   M A X .   A I R   T E M P .
I N   H T G   M O D E   D I S A B L E D
```

- To turn off the function, simply press **Enter**.
- To re-enable it, simply enter a value of between -5°C and +20°C and press **Enter**.

19-4- Restriction to the minimum air temperature in cooling mode:

This function is used to prohibit the machine operating in cooling mode when the outdoor temperature rises above a configurable value.
Visible if P2 = Reversible Water-to-Water and Air-to-Water when P119 ≠ 2 (Heating only)

```
P 2 2 5 . 3   M I N .   A I R   T E M P .
I N   C L G   M O D E           + x x °
```

- This parameter can be set to between -20°C and 12°C in 1°C increments.
- Default setting: DISABLED

The unit shuts off once the outdoor temperature \leq P225.3.
The unit restarts once the temperature rises back to above P225.3 + 2K.

➤ Display

```
M A C H I N E   O F F   I N   C L G   M O D E
O U T   T E M P .   T O O   L O W
```

This limit is not managed as a fault if the machine is shut off because of it:

- Not stored in memory if a mains power failure occurs
- Fault not saved in memory
- Fault relay in Off position
- The unit fault LED is off.

20 MANAGEMENT OF THE AUXILIARY HEATER BOARD AND THE ELECTRIC AUXILIARY HEATERS

The auxiliary electric heater board is the ADDitional board 1 with the rotary switch set to position 2.

It is used to obtain up to four additional control stages in heating mode.

Example:

When used on a unit with two control stages, the board brings the total number of stages to six (two thermodynamic stages and four electric stages). Although the electric stages are managed as control stages, the last control stages will turn on last.

➤ The electric stages are turned on if:

- the thermodynamic power is insufficient
- faults occur on the compressor stages
- the outdoor temperature is less than P225
- the water return temperature is too low to allow defrosting

➤ The electric stages are shut off if a water flow fault occurs.


➤ The auxiliary electric heater board has three separate on/off inputs:

- Input 1 → ADDitional board 1, auxiliary electric heaters used, terminal block J4 between terminals 2-3 (if the input is open, the electric auxiliary heaters are shut off by fault 1 and the corresponding message appears).
- Input 2 → ADDitional board 1, auxiliary electric heaters used, terminal block J4 between terminals 4-5 (if the input is open, the electric auxiliary heaters are shut off by fault 2 and the corresponding message appears).
- Input 3 → ADDitional board 1, auxiliary electric heaters used terminal block J4 between terminals 1-2


Value of P113:

- If P113 = DISABLED, the input is disabled regardless of its state.
- If P113 = LOAD SHEDDING, two cases apply:
 - 1) The input is open: the electric auxiliary heaters operate normally
 - 2) The input is closed: the electric auxiliary heaters are turned off
- If P113 = OVERRIDE:
 - 1) The input is open: the thermodynamic stages and the electric auxiliary heaters operate normally
 - 2) The input is closed: the thermodynamic stages are turned off

The outputs always close in the same order (1, 2, 3, 4) and always open in the reverse order (4, 3, 2, 1).



Management of the electrical auxiliary heaters under normal operation:



- If the air temperature \geq P226: heat pump alone
- If the air temperature $<$ P226: heat pump and electric auxiliary heaters. If a call is made for control, the thermodynamic control stages are the first stages.
- If the air temperature $<$ P225: the heat pump is shut off and only the electric stages operate.

Management of the electric auxiliary heaters when the thermodynamic control stage is shut off by a setpoint corrected by the discharge protection:

- The electric stages take the place of the thermodynamic stages and become the first control stages, and the outdoor air temperature at that exact moment is stored in memory.
- The auxiliary heaters are set to the initial setpoint if P131 (setpoint adjustment based on outdoor temperature) = No. They are set to the calculated setpoint if P131 = Yes.
- The thermodynamic stages adjust to the setpoint corrected by the discharge temperature protection.
- Whether the machine is on or off, the corrected setpoint will increase by 1°C for an equivalent rise in the air temperature

until:

- . Initial setpoint if P131 = No
- . Calculated setpoint if P131 = Yes
- When the air temperature is $>$ than the air temperature stored in memory + 2, the thermodynamic stages revert to being the first control stages and the electric stages are the last and adjust to the original setpoint:
 - . Initial setpoint if P131 = No
 - . Calculated setpoint if P131 = Yes


Management of the electric auxiliary heaters when the machine is shut off by a general fault:

The electric stages take the place of the thermodynamic stages.

21 MANAGEMENT OF THE BACK-UP BOILER

If P111 = Boiler

➤ Management under normal operation:



- If the air temperature \geq P226: heat pump alone
 - If the air temperature $<$ P226: heat pump and boiler. If a call is made for control. The thermodynamic control stages are the first stages.

- If the air temperature $<$ P225: heat pump shut off and boiler turned on.

➤ Management of the electric auxiliary heaters when the thermodynamic control stage is shut off by a setpoint corrected by the discharge protection:

- The boiler contact (terminals 2-3 on terminal block J3 on the main board) is closed, the outdoor air temperature at the time of closing is stored in memory. P226 takes on the value of the outdoor temperature if it is lower.
 - The boiler is set to the initial setpoint if P131 (setpoint adjustment based on outdoor temperature) = No. It is to the calculated setpoint if P131 = Yes
 - The thermodynamic stages adjust to the setpoint

corrected by the discharge temperature protection.
 - Whether the machine is on or off, the corrected setpoint will increase by 1°C for an equivalent rise in the air temperature until:
 . Initial setpoint if P131 = No
 . Calculated setpoint if P131 = Yes
 - The boiler relay is open when the air temperature $>$ P226 + 2.

➤ Management of the boiler when the machine has been shut off by a general fault:

- Boiler contact closed
 - Control with a minimum setpoint P135 = 50°C


By default, this minimum setpoint must be adjusted based on the technology of the boiler.

➤ Management of the boiler when the machine has been shut off by a water flow fault:

(Depending on state of P27: pump controlled by boiler operation)

- If P27 = Yes, boiler operation authorised.

- If P27 = No, the boiler is shut off.



22 MASTER/SLAVE CONTROL

22.1 Case of two parallel-connected machines

For a master/slave setup involving two parallel-connected machines, the machines must be connected by a bus link and one must be designated as the master machine in control of the slave machine.

Menu 12 (Master/Slave) appears when parameter P28 is set to 'Yes'.

1 2 - M A S T E R / S L A V E

➤ Designation of master machine:

P 8 0 0	M A S T E R	M A C H I N E
O N	L O O P	Y E S

Important:

only one machine may be configured as the master on each loop. If the master machine has already been configured and you try to configure the slave machine as the master, the slave machine's parameter will be locked and not be accessible. Parameter P808 sets the minimum time delay between the turning-on of machines 1 and 2.

22.1.1 Operating principle:

The master machine sends the following information to the slave machine:

- ON-OFF. - Control temperature.
- Heating/cooling mode

The master machine will not have access to detailed information about the slave machine (fault details, operating readings, machine parameters, operating parameters, etc.) and vice versa.

If a BMS is used, each machine will have access to all the information on the other machine.

Important:

The master machine's BMS link manages information from the loop and the master machine. To obtain information on the slave machine, its BMS link must be connected.

➤ Loop description:

- The loop is limited to two units. Both may be assigned to the loop's operation or one may be assigned as a backup. master/slave control).
 - The loop may be controlled in either heating or cooling mode. - Each machine will be adjusted by its own software and the adjustments made to the master machine will control the units on the loop in cascade mode..
- Switching between modes is managed in the same way as when a single machine is running (no

22.1.2 General:

In all cases, the slave machine's On/Off button can be used to cut the master machine's control over the slave machine.

Once a machine is configured as the master, it has control over the slave machine.

The machine with the most control stages must always be designated as the master machine.

The slave machine's control parameters become locked when P28 = Yes.

The time on the master machine's console is sent to the slave machine so that both have the same time.

If communication between the master and slave machine is lost for more than 10 minutes, the slave machine switches to independent operation with its own information and displays the following message:

M U L T I U N I T	M A N A G E M E N T
L I N K	F A U L T

➤ Automatic acknowledgment:

- The automatic operation controls are managed by each machine as if the machines were not linked.
- Load shedding via the on/off inputs is managed by each machine as if the machines were not linked.
- The pumps are also managed by each machine as if the machines were not linked.

Parameters P801 to P810 are hidden if P800 = No (i.e. on the slave machine).

22.1.3 Management of the functions:

A) Machine operation priority and balancing of runtimes:

- The order in which machines are started is determined based on faults and the number of hours of operation.
- **A machine is available** when it is off, has no faults, and is authorised to operated.
- The first machine to start is one that is available and has the fewest hours of operation.

➤ Balancing of runtimes:

- After every 50 hours of machine operation, the system switches to the machine which has operated the least in order to balance the runtimes.
 - While the system is on (and before it is shut off), compare the time counters of the machines that are running and change the order number so that the machine with the longest runtime is shut off first.
 - If a fault occurs on an active stage (or the stage is forced off), stage "n" becomes "n-1".
 - Stages are shut off in the reverse order that they were turned on regardless of their number of hours of operation.
- The total runtime of each machine calculated by adding P285 and P286 on each machine.

B) Backup or auxiliary machine (P801 = Yes):

➤ Without changeover:

The backup machine is designated by the customer (P803 = x).

WARNING: In this configuration, the customer will have to run this machine twice a year to prevent the pump from seizing.

➤ With changeover:

- The machine with the longest runtime and which is off is automatically set as the backup.
 - If a partial fault occurs on a machine on the loop, that machine is automatically made the backup.
 - If parameter P807 ≠ 0, the backup machine also serves as the auxiliary machine. It is started up if the temperature >setpoint + P807, and stopped at 1 K below this value.
- The backup machine may operate if:
- A machine has a link fault
 - A machine has a total fault
 - Operation of backup authorised if P807 ≠ 0 and temperature > setpoint + P807

On the backup machine the pumps are off, the LED flashes on and off at 1-second intervals and the following message is displayed:

M U L T I U N I T M A N A G E M E N T
B A C K U P M A C H I N E

C) Forced stop of machines:

This function can be configured to prevent a machine from operating.

D) Water loop winter protection:

If parameter P142 on the master machine = Yes

➤ In heating mode:

- This function is possible if P142 on the master machine = Yes, if the automatic operation control inputs on both machines are open, and both machines are set to On. The function must maintain the water inlet temperature on the heat exchanger at 30°C as soon as the outdoor temperature $\leq 3^\circ\text{C}$ (2 K differential = pump and compressors shut off immediately)(Cascade control on

the return line).

- Adjust water-to-water units to the hot water sensor.

- The heating LED is lit; the On/Off LED flashes.

- If a fault occurs on the outdoor sensor, maintain the water loop at 30°C.

Corresponding message on each machine:

M A I N T A I N W A T E R L O O P
T E M P E R A T U R E A T 3 0 °

➤ In cooling mode:

- This function is possible if P142 on the master machine = Yes, the units are set to On, and the automatic operation control inputs on both machines are open. In this mode, the pump is turned on

when the outdoor temperature $\leq P220$ and shut off at $P220 + P222$.

Corresponding message on both machines:

W A T E R C I R C U L A T I O N
P U M P F O R C E D O N

If a fault occurs on the outdoor temperature sensor, the pump is forced on.

Note regarding the circulation of water during freezing weather: the customer must install a bypass so as to avoid creating a temperature problem during use.

22.1.4 Controls:

➤ Operating mode:

Note: The slave machine's operation is determined by the master unit (P119). If P28 = Yes, its operation cannot be changed via the corresponding on/off input, via the console or because of the outdoor temperature.

If the slave machine has a different P199 value than the master machine (e.g. master set to cooling/heating while slave set to cooling only) and a call is made for the slave to operate in a different mode than the master, the slave machine is shut off and the following message is displayed:

S L A V E F A U L T
P 1 1 9 O P E R A T I N G M O D E

The machine is then shut off.

➤ Control setpoint calculation:

The control setpoint is set by the master machine. If a fault occurs on the master machine, the slave machine operates using its own setpoint and its own sensors.

Return control (P141 = 1 on master machine):

- The control sensor used is on the master machine. If it is shut off (On/Off by automatic operation controls) or a fault has occurred

on it, the slave machine

will operate using its own setpoint and its own sensors.

Supply control (P141 = 3 on master machine):

- A sensor must be added to the water outlet manifold connecting both machines. To do so, the sensor must be connected to the slave machine in place of the water inlet sensor on this machine (terminals 2-3 on terminal block 7 of the motherboard)..


- The control temperature is sent by the slave machine connected to the water inlet on the slave's heat exchanger.

- The manifold water outlet temperature is the water outlet temperature on the master machine's manifold.

- The water inlet temperature on the slave's heat exchanger is the temperature from the master machine, including in parameter P255.

- The water outlet temperature on the slave's manifold is the temperature of the water outlet on the slave's manifold.


A) Cascade control:



Note: P804 = Cascade → parameter P143 on each machine becomes equal to 1°C. This is because the interstage differential on each machine will be adjusted by the value of P143 on each machine.

Machine 2's setpoint is shifted by P806 relative to machine 1's setpoint. The value of P806 will have to be selected based on machine 1 in order to achieve an operating order similar to the start-up of the last stage (see figure above).{

B) Control in parallel with "shifted setpoint":



Machine 1 adjusts itself to the master machine's setpoint. Machine 2's setpoint is shifted by the value of P805. Thus, the machine 2's setpoint is machine 1's setpoint + P805.

C) Water return control for storage (P154 on master machine = Yes):

This type of control makes it possible to generate maximum capacity at a given time, often when electricity is cheapest. Both machines are turned on at an interstage time delay of 10 seconds when P122 + P155 is achieved. The machines are shut off at P122 at an interstage time delay of 1 second.

- If P154 = Yes, storage control is enabled and the control mode based on the selected setpoint is controlled by the master machine.

Cascade control is used by default for both machines when setpoint 1 selected (standard control).

The 'Yes' value of P154 on the slave machine becomes inaccessible if P28 = Yes.

D) Hourly scheduling:

If P27 = Yes, the hourly schedules of two parallel-connected machines will be controlled by the control parameters on the master machine and the hourly schedule on the slave machine will become inaccessible.

22.1.5 Machine status menu:

If there are no general faults and the automatic operation inputs are closed, a submenu (overrides the fault message) is added to the machine status menu:

```

M A S T E R   S L A V E   C T R L
M A S T E R   M A C H I N E
or
S L A V E   M A C H I N E

```

23 ACTUATION OF THE ELECTRONIC EXPANSION VALVEE

23.1 With Alco driver and display

Only fault feedback signals from the valve are managed in this case

23.2 With CIAT driver

This configuration corresponds to using the electronic expansion valve with the CIAT expansion board and on which the Alco EXV miniboard with the software is connected.

When P42 is set to this value, the control and view parameters for the Alco electronic expansion valve can be accessed.

The compressor on/off signals authorising the expansion valve to move, as well as the low temperature and suction temperature signals, will be transmitted over a bus link.

23.2.1 Menus if P42 = CIAT:

> Main menu:

```

1 0 - E L E C   E X P .   V A L V E

```

> Electronic valve configuration menu:

expansion

```

P 6 0 1   C I R C U I T   1
V A L V E   T Y P E           E X 4

```

```

P 6 0 2   C I R C U I T   1
S U P E R H E A T   S T P       6 ° C

```

```

P 6 0 3   C I R C U I T   1
M O P   P O I N T           Y E S

```

```

P 6 0 4   C I R C U I T   1
M O P   V A L U E           1 5 ° C

```

```

P 6 0 5   O P N G   C 1   E X V
S T A R T   A I R   C O N     X X X %

```

```

P 6 0 6   O P N G   C 1   E X V
S T A R T   H E A T   P U M P   X X X %

```

```

P 6 0 7   P 6 0 7   O P E N I N G   T I M E
S T A R T - U P   C I R C U I T   1     X X S

```

```

P 6 0 8   S L O W   M O D E
C I R C U I T   1   E X V           N O

```

```

P 6 1 1   C I R C U I T   2
V A L V E   T Y P E           E X 4

```

P 6 1 2	C I R C U I T	2	S U P E R H E A T	S T P	6 ° C
P 6 1 3	C I R C U I T	2	M O P	P O I N T	Y E S
P 6 1 4	C I R C U I T	2	M O P	V A L U E	1 5 ° C
P 6 1 5	O P N G	C 2	E X V	S T A R T	A I R C O N X X X %
P 6 1 6	O P N G	C 2	E X V	S T A R T	H E A T P U M P X X X %
P 6 1 7	O P E N I N G	T I M E	S T A R T	C 2	X X S
P 6 1 8	C I R C U I T	2	S L O W	M O D E	N O

Parameters P608 and P618 are visible only if P2 ≠ reversible air-to-water

➤ Operation parameters:

P 3 2 5	C 1	E X V	O P E N I N G	X X X %
P 3 5 5	C 2	E X V	O P E N I N G	X X X %
P 5 5 8	C I R 1	E X V	V E R S I O N	N O . X X . Y Y V C M X X . Y Y
P 5 5 9	C I R 2	E X V	V E R S I O N	N O . X X . Y Y V C M X X . Y Y

23.2.2 Manual EXPANSION VALVE MODE if P42 = CIAT:

If Test Mode is set to 'Yes' it retains all standard testing functionalities and provides access to the manual override menu for the electronic expansion valves when – is pressed.

➤ Manual override of expansion valves (opening and closing)

If P3 = 1, access to EXV TEST.1 mode only.

Press + and – to change expansion valves.

➤ Display:

E X V	T E S T . 1
E X V	T E S T . 2

When either test mode is confirmed (OK), access to the settings menu is provided.

➤ Display:

E X V	T E S T	C X
A U T O		

The expansion valve remains in automatic mode the entire time AUTO is displayed. To enter settings mode, press **OK**.

- To send a signal to open the valve, press + → The percentage immediately higher than the percentage of opening requested by the controller will appear.

- To send a signal to close the valve, press – → The percentage immediately lower than the percentage of opening requested by the controller will appear.

To adjust the valve's percentage of opening to the desired value, press + and –. This percentage can be changed in increments of 1%.

➤ Display:

E	X	V	T	E	S	T	C	X		
O	P	E	N	I	N	G	X	X	X	%

To exit manual mode, press **Reset**.

The expansion valve will automatically return to automatic mode if no buttons are pressed on the console for 15 minutes.

23.2.3 Control of electronic expansion valve at start-up if P42 = CIAT:

➤ Comment:

- The expansion valve's percentage of opening and slow mode (set to 'No') are forced when the compressor is turned on.
- The percentage of opening values in air conditioning and heat pump modes as well as the forcing time can be adjusted using their corresponding parameters.

23.2.4 Control of the LP sensor:

➤ If P42 = CIAT:

- The LP sensor fault has a time delay of 120 seconds at power-up. It is not taken into account when the unit is off or at the end of the defrosting cycle during pressure balancing.
- The default value of P36 and P38 becomes 17.3 b.

24 IMPORTANT INFORMATION REGARDING THE CONTROL OF AN INVERTER COMPRESSOR

- Parameters P195 (ΔP for power reduction) and P144 (interstage differential) are visible even though there is just one compressor. P144 (interstage differential) has an adjustment range of 0.5 to 10°C.
- Parameters P145, P146, P147 and P148 are hidden if P7 = INVERTER and supply control is selected. On the other hand, when P141 = supply or return, parameters P143 and P144 remain visible and are set to a default value of 1.5°C.
- Output 3 (stage 2, circuit) on terminal block J3 on the motherboard is used to inform the variable speed drive of any faults requiring the compressor to be shut off. As a result, the compressor will be shut off if a fault is detected (the contact opens).
- Start-up time delay: P66 (Visible only if P7 = INVERTER. Default value of 120 seconds. Adjustable between 0 to 300 seconds in 30-second increments). This time delay corresponds to the minimum time allowed for the compressor control voltage to reach its maximum value of 10 V (value corresponding to the compressor's 90 Hz frequency). In other terms, the compressor will not reach 90 Hz until the end of this time delay even if it is requested to do so by the network's heat load.
- Parameter P192 (maximum fan speed threshold) becomes visible. Its default value is 8.0 V.
- The order in which the compressors turn on and off will be given via output 2 on terminal block J3 on the motherboard (stage 1, circuit 1).
- The compressor speed will be adjusted by an 0-10 V modulating signal (output 2-3 on terminal block J2 on the motherboard).

The following protections are enabled only if P7 = INVERTER:

These limitations are due to the compressor technology.

A) If the evaporating temperature drops to or below -20°C for 1 minute:

The minimum frequency in both heating mode and cooling mode becomes 50 Hz until the evaporating temperature rises to or above -15°C for 1 minute.

B) If the condensing temperature rises to or above 60°C for 1 minute:

The minimum frequency in both heating mode and cooling mode becomes 50 Hz until the condensing temperature rises to or above 58°C for 1 minute.

C) Maximum pressure difference:

- During water heating:

If $HP \geq 4 \times LP + 13.5$, 120 after start-up, CONNECT 2 adjusts the control setpoint so as not to push the compressors near their limits too often. If necessary, a coil defrosting cycle will be forced on.

➤ Information message:

U	N	I	T	Δ	P	b	a	r	L	I	M	I	T				
O	P	T	I	M	I	S	E	D	O	P	E	R	A	T	I	O	N

- During water chilling:

If $HP \geq 4 \times LP + 13.6$, the unit reduces its power by either reducing the compressor speed to 50 Hz or by turning off the compressor.

➤ Information message:

C	P	D	E	L	T	A	P	L	I	M	I	T			
P	W	R	R	E	D	U	C	T	I	O	N	x	x	m	n

➤ Fault function: (enabled in cooling mode and heating mode)

Operation:

The max. Δp threshold is set at $HP \times 4 + BP + 15.6$

If this fault causes at least 5 shutdowns in 24 hours:

- Corresponding circuit shut off.
- 30 min. time delay (in seconds in test mode)
- Fault output off
- Circuit fault LED on console flashes.

F	A	U	L	T	D	E	L	T	A	P	x	x	m	n
x	C	U	T	(S)	I	N	2	4	H			

If this fault causes more than 5 shutdowns in 24 hours:

- Corresponding circuit shut off.
- Fault output on
- Circuit fault LED on console lit steady.

```
C I R C U I T   x   O F F
C P   D E L T A   P   F A U L T
```

D) Compressor driver fault:

Terminals 2-3 on terminal bloc J5 on the CONNECT 2 board receive signals indicated faults on the Danfoss compress driver. Only alarms that shut down the compressor are received.

When contact 4-6 on the driver opens, the driver is in alarm mode. The following message should appear on the CONNECT 2 console: This function is activated 5 seconds after the power is turned on.

```
M A C H I N E   O F F
O U T   T E M P .   T O O   L O W
```

- Compressor shut off
- Fault acknowledged automatically
- Fault stored in memory in case of a mains power failure
- Fault saved in fault memory
- Relay in On position
- Compressor driver fault relay on relay board in On position
- General fault LED lit steady

25 DEFROSTING OF THE EVAPORATOR COILS

CIAT has developed an optimised frosting control system. Called DEGIPAC (P159 = optimised), it defrosts the evaporator coils only when frost has actually formed on them instead of based on the frosting time (P159 = fixed). It does so by continuously monitoring the difference in temperature between the coil and the outdoor air. If this difference is abnormally high, it turns on the defrost cycle. DEGIPAC makes it possible to

continue producing hot water for hours during cold, dry weather without having to defrost the coils. As a result, it improves the seasonal COP. Parameter P161 is used to advance (if P161 < default value) or delay (if P161 > default value) the start of the defrost cycle.

- Defrost cycle for reversible machines with **split** circuits (where P2 = 3 and P11 = split)
The defrost cycle is turned on when any of the following occur:
The discharge temperature is too high (see discharge protection in heating mode);
Ice is detected on the coil by the sensors on the coils. In this case, defrosting is performed by only one circuit at a time to ensure a minimum supply of hot water for the system;
A difference in pressure, where HP > LP +13.5 for 120 seconds if INVERTER compressors are used.

- Defrost cycle for reversible machines with **intertwined** or **mixed** circuits (where P2 = reversible air-to-water and P11 = intertwined or mixed). In this case, defrosting is performed by both circuits at the same time.
Defrosting is possible only when the water return temperature is high enough to ensure that the heat exchanger will not freeze when the cycle is reversed.
Defrosting is triggered by the low-pressure sensor that reads the lowest value.

```
C I R C U I T   x
B E I N G   D E F R O S T E D
```

- If this temperature is too low (< P52 + 8 K if there are 2 compressors per circuit and < P52+16 K if there is 1 compressor per circuit) and there is no way to increase it, the unit will shut off, save the fault in memory, and display the following message:

```
C I R C U I T   x   O F F
D E F R O S T I N G   I M P O S S I B L E
```

- If the temperature can be raised via the second circuit, a boiler or electric auxiliary heaters, the following message will appear:

```
W A T E R   T E M P .   R I S I N G
F O R   D E F R O S T I N G
```

- If this temperature exceeds 26°C, the circuit rises to maximum temperature before the four-way valve reverses and stays at maximum temperature during defrosting in order to minimise the defrosting time.
- If this temperature drops below 26°C, the circuit rises to maximum temperature before the four-way valve reverses and lowers in temperature during defrosting to prevent frost from forming on the heat exchanger.

Note: During the defrost cycle, CONNECT 2 continuously monitors the temperatures and pressures to prevent frost from forming on the heat exchanger and thus turning on the protections. This is why the fans may turn on during a defrost cycle.

26 HOURLY PROGRAMMING

26.1 Presentation

This function allows the weekly management of liquid chillers by selecting:

- 6 programming stages (maxi).
- 6 holidays zones (maxi).

26.2 Definition of the programming stages

Setting:

Starting time

Ending time

Selected days (M.T.W.T.F.S.S.)

Type of regulation: Setting 1 – Stop/Setting 2 – Stop/setting 1 – setting 2 / setting 2 – setting 1/non valid.

Setting by fault:

Starting hour: 0h00

Ending hour: 0h00

Validated days: none

Type of regulation not validated.

26.3 Definition of holiday zones

Settings:

Type of zone: non valid, stop, running on setting 1, running on setting 2.

Starting date dd-mm

Ending date dd-mm

Setting by fault Non valid, from 01-01 to 01-01

26.4 Operation

When putting under voltage or when setting the time, the information on the machine status are updated as a function of the programming settings. The user can change the status of his unit (Run/Stop – ½ setting regulation) but if a time range or a holiday zone is active, the information will be updated at the starting or ending time of the programming

In the case where at least one time range or one holiday zone is validated, the parameter P120 is forced on « 2 per console or BMS » and cannot be modified.

When going under test mode, the programming becomes non active. When leaving the test mode, the unit status information are updated as a function of the programming settings.

In case of range overlapping, the running mode has priority over the stop mode and setting 1 over setting 2.

Same thing in case of overlapping of zones.

If a programme stage is active (# non validated) and the real day is selected, the status of the unit is as follows:

Type of programme	Status before starting time	Status before starting time and ending time	Status after ending time
CSG1 -stop	Stop	Running on setting 1	Stop
CSG2 -stop	Stop	Running on setting 2	Stop
CSG1-CSG2	Running on setting 2	Running on setting 1	Running on setting 2
CSG2-CSG1	Running on setting 1	Running on setting 2	Running on setting 1

If at least one time range or one holiday zone is validated, alternate the message machine stopped or setting/temp with a message in order to signal to the user that the status will be updated on next status change of time range. Display of each of these messages for 3 seconds.

Message to be displayed:

T I M E P R O G R A M M I N G O N

Access principle:

Through menu 9: "9 PROGRAMMING"

9 - P R O G R A M M I N G

-If validated by key "ENTER", 2 sub-menus "HOURLY PROGRAMMING" and "HOLIDAY ZONES" appear.

T I M E T A B L E
D A Y S O F F

Through keys + and –, select one of the 2 sub- menus, then validate with "ENTER"

Position of the cursor:

When surfing in the various menus, the cursor is located at the top, on the left.

For modifying the settings, it is located at the bottom right side, last but one character.

- When entering the « TIME RANGE » menu "

Display:

2nd line display:
type of regulation

T I M E T A B L E N ° x

{ N° of selected spacing,
from 1 to 6

Unroll the time range with key + or – then validate with key "ENTER"

Once the time range has been selected, the regulation type has to be chosen..

By pressing "Enter", we have access to the setting. By pressing key + or –, the following menus appear. For validation, press "Enter".

T Y P E O F C O N T R O L S E T P O I N T 1 - O F F	↑ ↓
T Y P E O F C O N T R O L S E T P O I N T 2 - O F F	↑ ↓
T Y P E O F C O N T R O L S E T P . 1 - S E T P . 2	↑ ↓
T Y P E O F C O N T R O L S E T P . 2 - S E T P . 1	↑ ↓
T Y P E O F C O N T R O L N O V A L I D	↑ ↓

Once the regulation has been validated, « days selected » appears

S E L E C T D A Y S M T W T F S S	↑ ↓
--------------------------------------	--------

By pressing Enter, days are selected: key "+" to validate the day – key "-" to remove the validation.
Set in this order the starting hour/starting minute/ending hour/ending minute.

S T A R T O F T I M E y y H x x	↑
E N D O F T I M E y y H x x	↓

By pressing "ENTER", set hours, then minutes.

Any modification leads to the updating of the unit status.

Any type of setting is possible (starting time < ending time, starting time = ending time, starting time > ending time)

If the ending time ≤ starting time, the programme is considered to be ending on the following day.

If one enters in the menu "HOLIDAY ZONES"

Display:

Display 2nd line:
zone type

D A Y S O F F N ° x	↑ ↓
---------------------	--------

{ N° of zone selected,
from 1 to 6

Select the n° of the holiday zone to be set by pressing key "ENTER".

Setting text:

T Y P E O F Z O N E N O V A L I D	↑ ↓
T Y P E O F Z O N E O F F	↑ ↓
T Y P E O F Z O N E S E T P O I N T 1	↑ ↓
T Y P E O F Z O N E S E T P O I N T 2	↑ ↓

Starting day and ending day

Set in the following order:

Starting day / starting month / ending day / ending month.

D A T E O F S T A R T D D / M M	↑
D A T E O F E N D D D / M M	↓

All types of settings are possible (starting day < ending day, starting day = ending day, starting day > ending day)

If the ending day < starting day, the programme is considered to be ending the year after.

Operation of holiday zones:

If a holiday zone is active (starting date ≤ present date ≤ ending date), **the time ranges become non active.**

The unit operating status becomes the one of the active zone (stop, running on setting 1 or running on setting 2).



At the end of the holiday zone, if no time zone is validated, the operation is the one existing at the start of the holiday zone

Example:



Prog 1: 7-12h CSG1-CSG2 MTW TF

Prog 2: 10-18h CSG1-stop MT TF

Holiday zone: 10-08 / 30-08 : stop



Result:



Saturday and Sunday not being selected in the hourly programming, the unit is therefore stopped.
The unit is stopped between 10th August and 30th August, this period being selected as holiday zone.

27 COMMUNICATION PROTOCOL

A) Communication medium

- RS485
- 3-pin connector on terminal 1 of terminal block J11: A or +
Terminal 2: B or -
Terminal 3: connected to earth for shielding if desired

Two lights provide information on the status of the transmission (see Section 3.1, control board)

- D50 → Receive LED. Usually off; flashes when a message is received by the board.
If this light remains on, the bus is reversed. Swap terminals 1 and 2 on J11.
- D52 → Send LED. Usually off; lights up when the CPU sends a message over the bus.

B) Transmission mode

Serial, asynchronous, half duplex, RTU mode.

- 1 start bit,
- 8 data bits,
- The parity is set via parameter P702,
- The number of stop bits is set via parameter P703,
- The transmission speed is set via parameter P701,
- The unit number on the bus is set via parameter P705.

Coding of analogue values

Standard 32-bit IEEE format (2 registers).

Order of values:

- If P704 = No → low order, high order.
- Si P704 = Yes → high order, low order.

Function codes used.

- 1 or 2: read n bits
- 3 or 4: read multiple registers (16 bits)
- 5: write one bit
- 6: write register function.....
- 8: read diagnostics counters
- 11: read event counter
- 15: write n bits
- 16: write multiple registers (16 bits)

Note: the write functions are enabled if parameter P103 is set to "Remote, BMS..."

Error codes:

- 1: function code unknown
- 2: address incorrect
- 3: data error

27.1 Registers accessible by customer

Register No. hexadecimal	Register No. decimal	Description	Format	Type	
Registers accessible in read-only mode (Functions 3 or 4)					
0x01	1	Controller name	Decimal	Read-only	33 = CONNECT 2
0x02	2	Actual operating mode	Decimal	Read-only	
0x3 and 0x4	3 and 4	Outdoor temperature	Float	Read-only	
0x5 and 0x6	5 and 6	Control setpoint	Float	Read-only	
0x7 and 0x8	7 and 8	Evaporator inlet temperature	Float	Read-only	
0x9 and 0xa	9 and 10	Evaporator outlet temperature	Float	Read-only	
0xb and 0xc	11 and 12	Condenser temperature	Float	Read-only	
0x13	19	Number of stages on	Char	Read-only	Available with versions 09.00 and higher
0x20 and 0x21	32 and 33	P285 Heating mode runtime (in hours)	Float	Read-only	

Register No. hexadecimal	Register No. decimal	Description	Format	Type	
Registers accessible in read-only mode (Functions 3 or 4) CONTINUED					
0x22 and 0x23	34 and 35	P286 Cooling mode runtime (in hours)	Float	Read-only	
0x24 and 0x25	36 and 37	P287 Pump 1 runtime (in hours)	Float	Read-only	
0x26 and 0x27	38 and 39	P288 Pump 2 runtime (in hours)	Float	Read-only	
0x28 and 0x29	40 and 41	P310 Number of starts, stage 1, circuit 1	Float	Read-only	
0x2a and 0x2b	42 and 43	P311 Stage 1, circuit 1 runtime	Float	Read-only	
0x2c and 0x2d	44 and 45	P313 Number of starts, stage 2, circuit 1	Float	Read-only	
0x2e and 0x2f	46 and 47	P314 Stage 2, circuit 1 runtime	Float	Read-only	
0x30 and 0x31	48 and 49	P340 Number of starts, stage 1, circuit 2	Float	Read-only	
0x32 and 0x33	50 and 51	P341 Stage 1, circuit 2 runtime	Float	Read-only	
0x34 and 0x35	52 and 53	P343 Number of starts, stage 2, circuit 2	Float	Read-only	
0x36 and 0x37	54 and 55	P344 Stage 2, circuit 2 runtime	Float	Read-only	
Registers accessible in read mode (Functions 3 or 4) and write mode (Function 16)					
0x101 and 0x102	257 and 258	P121 Cooling setpoint 1	Float	Read/Write	
0x103 and 0x104	259 and 260	P122 Cooling setpoint 2	Float	Read/Write	
0x105 and 0x106	261 and 262	P123 Heating setpoint 1	Float	Read/Write	
0x107 and 0x108	263 and 264	P124 Heating setpoint 2	Float	Read/Write	
0x109 and 0x10a	265 and 266	P125.1 Setpoint for 4 mA in cooling mode	Float	Read/Write	
0x10b and 0x10c	267 and 268	P125.2 Setpoint for 4 mA in heating mode	Float	Read/Write	
0x10d and 0x10e	269 and 270	P126.1 Setpoint for 20 mA in cooling mode	Float	Read/Write	
0x10f and 0x110	271 and 272	P126.2 Setpoint for 20 mA in heating mode	Float	Read/Write	
Registers accessible in read mode (Functions 3 or 4) and write mode (Functions 6 or 16)					
0x200	512	Year	Decimal	Read/Write	0 to 99
0x201	513	Month	Decimal	Read/Write	1 to 12
0x202	514	Day of the month	Decimal	Read/Write	1 to 31
0x203	515	Day of the week	Decimal	Read/Write	1 to 7 (1: Monday, 2: Tuesday, etc.)
0x204	516	Hours	Decimal	Read/Write	0 to 23
0x205	517	Minutes	Decimal	Read/Write	0 to 59

27.2 Customer access bits

Hexadecimal bit No.	Bit No. decimal	Description	Type	
Read-only bit (functions 1 or 2)				
0x01	1	P103 Control type	Read-only	0: Local, 1: Remote
0x02	2	Operating summary (On/Off and automatic operation input closed)	Read-only	1 = On
0x03	3	State of pump 1 output	Read-only	1 = On
0x04	4	State of pump 2 output	Read-only	1 = On
0x05	5	Output state, stage 1, circuit 1	Read-only	1 = on
0x06	6	Output state, stage 2, circuit 1	Read-only	1 = On
0x07	7	Output state, stage 1, circuit 2	Read-only	1 = On
0x08	8	Output state, stage 2, circuit 2	Read-only	1 = On
0x09	9	State of auxiliary electric heater 1 or boiler	Read-only	1 = On
0x0a	10	State of auxiliary electric heater 2	Read-only	1 = On
0x0b	11	State of auxiliary electric heater 3	Read-only	1 = On
0x0c	12	State of auxiliary electric heater 4	Read-only	1 = On
0x0d to 0x0f reserved				
0x10	16	General fault summary (1 fault below present)	Read-only	1 = Fault
0x11	17	Phase controller fault	Read-only	1 = Fault
0x12	18	Water flow fault	Read-only	1 = Fault
0x13	19	Pump 1 fault		
0x14	20	Pump 2 fault	Read-only	1 = Fault

Hexadecimal bit No.	Bit No. decimal	Description	Type	
0x0d to 0x0f reserved (continued)				
0x15	21	Pump fault, 1 loop	Read-only	1 = Fault
0x16	22	Pump fault, 2 loops	Read-only	1 = Fault
0x17	23	Heat exchanger inlet sensor fault	Read-only	1 = Fault
0x18	24	Heat exchanger outlet sensor fault	Read-only	1 = Fault
0x19	25	Outdoor temperature sensor fault	Read-only	1 = Fault
0x1a	26	Condenser sensor fault	Read-only	1 = Fault
0x1b	27	Manifold outlet sensor fault	Read-only	1 = Fault
0x1c	28	Fan fault	Read-only	1 = Fault
0x1d	29	EEPROM FAULT	Read-only	1 = Fault
0x1e	30	Loop inlet sensor fault (MULTICONNECT)	Read-only	1 = Fault
0x1f	31	Loop outlet sensor fault (MULTICONNECT)	Read-only	1 = Fault
0x20	32	AEROCONNECT link fault	Read-only	1 = Fault
0x21	33	Outdoor temperature too high in cooling mode	Read-only	1 = Fault
0x22	34	Change of operating mode fault	Read-only	1 = Fault
0x23	35	Winter protection	Read-only	1 = Fault
0x24	36	Exchanger ambient sensor fault	Read-only	1 = Fault
0x25 to 0x3f reserved				
0x40	64	Circuit 1 fault summary	Read-only	1 = Fault
0x41	65	Stage 1, circuit 1 fault	Read-only	1 = Fault
0x42	66	Stage 2, circuit 1 fault	Read-only	1 = Fault
0x43	67	Manual HP fault, circuit 1	Read-only	1 = Fault
0x44	68	HP fault, circuit 1 pressure sensor	Read-only	1 = Fault
0x45	69	Circuit 1 LP fault	Read-only	1 = Fault
0x46	70	Water frosting fault, circuit 1	Read-only	1 = Fault
0x47	71	Refrigerant frosting fault, circuit 1	Read-only	1 = Fault
0x48	72	Exchanger frosting fault, circuit 1	Read-only	1 = Fault
0x49	73	Discharge fault, stage 1, circuit 1	Read-only	1 = Fault
0x4a	74	Discharge fault, stage 2, circuit 1	Read-only	1 = Fault
0x4b	75	Defrosting fault, circuit 1	Read-only	1 = Fault
0x4c	76	Expansion valve fault, circuit 1	Read-only	1 = Fault
0x4d	77	Stepper motor fault, circuit 1 expansion valve	Read-only	1 = Fault
0x4e	78	Low superheat fault, circuit 1	Read-only	1 = Fault
0x4f	79	High superheat fault, circuit 1	Read-only	1 = Fault
0x50	80	VCM module fault, expansion valve 1	Read-only	1 = Fault
0x51	81	Exchanger outlet sensor fault, circuit 1	Read-only	1 = Fault
0x52	82	Exchanger freon sensor fault, circuit 1	Read-only	1 = Fault
0x53	83	Sensor fault, coil A, circuit 1	Read-only	1 = Fault
0x54	84	Sensor fault, coil B, circuit 1	Read-only	1 = Fault
0x55	85	Sensor fault, coil C, circuit 1	Read-only	1 = Fault
0x56	86	Sensor fault, coil D, circuit 1	Read-only	1 = Fault
0x57	87	Discharge sensor fault, stage 1, circuit 1	Read-only	1 = Fault
0x58	88	Discharge sensor fault, stage 2, circuit 1	Read-only	1 = Fault
0x59	89	Circuit 1 HP sensor fault	Read-only	1 = Fault
0x5a	90	Circuit 1 LP sensor fault	Read-only	1 = Fault
0x5b	91	Circuit 1 suction sensor fault	Read-only	1 = Fault
0x5c	92	Circuit 1 liquid sensor fault	Read-only	1 = Fault
0x5d	93	Circuit 1 exp. valve board link fault	Read-only	1 = Fault
0x5e	94	Link fault, additional board for reversible	Read-only	1 = Fault
0x5f	95	Tsat discharge fault, Inverter compressor	Read-only	1 = Fault
0x60	96	Mechanical fault, Inverter compressor	Read-only	1 = Fault
0x61 to 0x7f reserved				
0x80	128	Load shedding, stage 1, circuit 1	Read-only	1 = Load shedding
0x81	129	Load shedding, stage 2, circuit 1	Read-only	1 = Load shedding

Hexadecimal bit No.	Bit No. decimal	Description	Type	
0x82 to 0x9f reserved				
0x100	256	Circuit 2 fault summary	Read-only	1 = Fault
0x101	257	Stage 1, circuit 2 fault	Read-only	1 = Fault
0x102	258	Stage 2, circuit 2 fault	Read-only	1 = Fault
0x103	259	Manual HP fault, circuit 2	Read-only	1 = Fault
0x104	260	HP fault, circuit 2 pressure sensor	Read-only	1 = Fault
0x105	261	Circuit 2 LP fault	Read-only	1 = Fault
0x106	262	Water frosting fault, circuit 2	Read-only	1 = Fault
0x107	263	Refrigerant frosting fault, circuit 2	Read-only	1 = Fault
0x108	264	Exchanger frosting fault, circuit 2	Read-only	1 = Fault
0x109	265	Discharge fault, stage 1, circuit 2	Read-only	1 = Fault
0x10a	266	Discharge fault, stage 2, circuit 2	Read-only	1 = Fault
0x10b	267	Defrosting fault, circuit 2	Read-only	1 = Fault
0x10c	268	Expansion valve fault, circuit 2	Read-only	1 = Fault
0x10d	269	Stepper motor fault, circuit 2 expansion valve	Read-only	1 = Fault
0x10e	270	Low superheat fault, circuit 2	Read-only	1 = Fault
0x10f	271	High superheat fault, circuit 2	Read-only	1 = Fault
0x110	272	VCM module fault, expansion valve 2	Read-only	1 = Fault
0x111	273	Exchanger outlet sensor fault, circuit 2	Read-only	1 = Fault
0x112	274	Exchanger freon sensor fault, circuit 2	Read-only	1 = Fault
0x113	275	Sensor fault, coil A, circuit 2	Read-only	1 = Fault
0x114	276	Sensor fault, coil B, circuit 2	Read-only	1 = Fault
0x115	277	Sensor fault, coil C, circuit 2	Read-only	1 = Fault
0x116	278	Sensor fault, coil D, circuit 2	Read-only	1 = Fault
0x117	279	Stage 1, circuit 2 discharge sensor fault	Read-only	1 = Fault
0x118	280	Stage 2, circuit 2 discharge sensor fault	Read-only	1 = Fault
0x119	281	Circuit 2 HP sensor fault	Read-only	1 = Fault
0x11a	282	Circuit 2 LP sensor fault	Read-only	1 = Fault
0x11b	283	Circuit 2 suction sensor fault	Read-only	1 = Fault
0x11c	284	Circuit 2 liquid sensor fault	Read-only	1 = Fault
0x11d	285	Circuit 2 exp. valve board link fault	Read-only	1 = Fault
0x11e	286	Link fault, additional board for reversible	Read-only	1 = Fault
0x11f to 0x13f reserved				
0x140	320	Load shedding, stage 1, circuit 2	Read-only	1 = Load shedding
0x141	321	Load shedding, stage 2, circuit 2	Read-only	1 = Load shedding
Read (Functions 1 or 2) and write (Functions 5 or 15) bit				
0x200	512	On/Off	Read/Write	1 = On
0x201	513	Control set to setpoint 1 or 2	Read/Write	1 = Control set to setpoint 2
0x202	514	Heating or cooling operation	Read/Write	1 = Heating
0x203	515	Load shedding via Modbus, stage 1, circuit 1 (different from 0 x 140)	Read/Write	1 = Off
0x204	516	Load shedding via Modbus, stage 2, circuit 1	Read/Write	1 = Off
0x205	517	Load shedding via Modbus, stage 1, circuit 2	Read/Write	1 = Off
0x206	518	Load shedding via Modbus, stage 2, circuit 2	Read/Write	1 = Off
Read bit (Functions 1 or 2) → Available with versions 09.00 and higher				
0x220	544	On/Off summary (1 = keypad on/off = 1 and all automatic operation controls closed and no oil warm-up time and no faults)	Read-only	
0x221	545	1 = Cooling possible	Read-only	
0x222	546	1 = Heating possible	Read-only	
0x223	547	1 = 1 stage on	Read-only	
0x224	548	1 = Maximum available power reached	Read-only	
0x225	549	1 = A major fault preventing output has occurred	Read-only	
0x226	550	1 = A reset fault has occurred but output is possible	Read-only	
0x227	551	1 = A fault requiring servicing has occurred	Read-only	



Siège social & Usines

Avenue Jean Falconnier B.P. 14 - 01350 Culoz - France

Tél. : 04 79 42 42 42 - Fax : 04 79 42 42 10

Internet : www.ciat.com

Compagnie Industrielle d'Applications Thermiques

S.A. au capital de 26.728.480 d'euros - R.C.S. Bourg-en-Bresse B 545.620.114



SYSTEME QUALITE CERTIFIE ISO 9001
CERTIFIED ISO 9001 QUALITY SYSTEM
QUALITÄTSMANAGEMENT - SYSTEM
NACH ISO 9001 ZERTIFIZIERT
SISTEMA CUALIDAD GARANTIZADA ISO 9001

CIAT Service

Tel. : +33 (0)4 79 42 42 90 – Fax : +33 (0)4 79 42 42 13

Document non contractuel.
Dans le souci constant,
d'améliorer son matériel,
CIAT se réserve le droit de
procéder sans préavis à toutes
modifications techniques.

*This document is non-contractual.
As part of its policy of continual
product improvement, CIAT reserves
the right to make any technical
modification it feels appropriate
without prior notification.*

Dokument nicht bindend.
Aufgrund der ständigen
Verbesserung seiner Geräte,
behält sich CIAT das Recht vor,
technische Änderungen ohne
Vorankündigung vorzunehmen.

*Documento no contractual.
Preocupado por la mejora
constante de su material, CIAT se
reserva el derecho a realizar
cualquier modificación técnica sin
previo aviso.*